

INTERNATIONAL STANDARD

NORME INTERNATIONALE

**Environmental testing –
Part 2-57: Tests – Test Ff: Vibration – Time-history and sine-beat method**

**Essais d'environnement –
Partie 2-57: Essais – Essai Ff: Vibrations – Méthode par accélérogrammes et
sinusoïdes modulées**

IECNORM.COM : Click to view the full PDF of IEC 60068-2-57:2013



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2013 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester.

If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de la CEI ou du Comité national de la CEI du pays du demandeur.

Si vous avez des questions sur le copyright de la CEI ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de la CEI de votre pays de résidence.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
Fax: +41 22 919 03 00
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

Useful links:

IEC publications search - www.iec.ch/searchpub

The advanced search enables you to find IEC publications by a variety of criteria (reference number, text, technical committee,...).

It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available on-line and also once a month by email.

Electropedia - www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing more than 30 000 terms and definitions in English and French, with equivalent terms in additional languages. Also known as the International Electrotechnical Vocabulary (IEV) on-line.

Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: csc@iec.ch.

A propos de la CEI

La Commission Electrotechnique Internationale (CEI) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications CEI

Le contenu technique des publications de la CEI est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

Liens utiles:

Recherche de publications CEI - www.iec.ch/searchpub

La recherche avancée vous permet de trouver des publications CEI en utilisant différents critères (numéro de référence, texte, comité d'études,...).

Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

Just Published CEI - webstore.iec.ch/justpublished

Restez informé sur les nouvelles publications de la CEI. Just Published détaille les nouvelles publications parues. Disponible en ligne et aussi une fois par mois par email.

Electropedia - www.electropedia.org

Le premier dictionnaire en ligne au monde de termes électroniques et électriques. Il contient plus de 30 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans les langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (VEI) en ligne.

Service Clients - webstore.iec.ch/csc

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: csc@iec.ch.

INTERNATIONAL STANDARD

NORME INTERNATIONALE

Environmental testing –

Part 2-57: Tests – Test Ff: Vibration – Time history and sine-beat method

Essais d'environnement –

Partie 2-57: Essais – Essai Ff: Vibrations – Méthode par accélérogrammes et sinusoïdes modulées

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

PRICE CODE
CODE PRIX



ICS 19.040

ISBN 978-2-83220-745-1

Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.

CONTENTS

FOREWORD.....	4
INTRODUCTION.....	6
1 Scope.....	8
2 Normative references	8
3 Terms and definitions	8
4 Test requirements and associated parameters.....	15
4.1 General.....	15
4.2 Requirements for testing	15
4.3 Vibration response investigation.....	16
4.3.1 General	16
4.3.2 Basic motion.....	16
4.3.3 Transverse motion.....	16
4.3.4 Rotational motion	16
4.3.5 Measuring points	16
4.3.6 Vibration amplitude tolerances.....	17
4.3.7 Frequency tolerances	17
4.3.8 Sweeping	17
4.3.9 Damping ratio.....	17
4.4 Time-history testing.....	18
4.4.1 Basic motion.....	18
4.4.2 Transverse motion.....	18
4.4.3 Rotational motion	18
4.4.4 Tolerance zone for the required response spectrum	18
4.4.5 Frequency range	19
4.5 Sine-beat testing	19
4.5.1 General description	19
4.5.2 Vibration amplitude tolerances.....	19
4.5.3 Test frequency tolerances	19
4.5.4 Transverse motion.....	19
4.6 Mounting.....	20
5 Severities	20
5.1 General.....	20
5.2 Time history	20
5.3 Test frequency range.....	21
5.4 Required response spectrum.....	21
5.5 Number and duration of time-histories	21
5.5.1 Number of time histories.....	21
5.5.2 Time-history duration.....	21
5.5.3 Duration of the strong part of the time history	22
5.5.4 Number of high stress cycles.....	22
5.6 Sine-beat test level.....	23
5.6.1 General	23
5.6.2 Test frequency determination	29
5.6.3 Sine-beat test wave	29
5.6.4 Number of cycles in the sine beat.....	29
5.6.5 Modulating frequency	30

5.6.6	Number of sine beats.....	31
5.6.7	High-stress low-cycle fatigue effects.....	31
6	Preconditioning	31
7	Initial measurements	31
8	Testing	31
8.1	General	31
8.2	Vibration response investigation	31
8.3	Time-history testing	32
8.4	Sine-beat testing	32
8.5	Multi-axis testing	32
8.5.1	General	32
8.5.2	Single axis testing	32
8.5.3	Biaxial testing	32
8.5.4	Triaxial testing	32
9	Intermediate measurements	33
10	Recovery	33
11	Final measurements	33
12	Information to be given in the relevant specification.....	33
13	Information to be given in the test report	34
	Annex A (informative) Guidance for time-history and sine-beat methods	35
	Bibliography.....	41
	Figure 1 – Sequence of five sine beats with five cycles.....	7
	Figure 2 – Number of cycles per sine beat	13
	Figure 3 – Typical time history	14
	Figure 4 – Typical logarithmic plot of a required response spectrum, test response spectrum and tolerance zone	14
	Figure 5 – Typical response of an oscillator excited by a specific time history during a test	22
	Figure 6 – Recommended test level with crossover frequency at 0,8 Hz	24
	Figure 7 – Recommended test level with crossover frequency at 1,6 Hz	26
	Figure 8 – Recommended test level with crossover frequency at 8 Hz	28
	Figure 9 – Amplification factors of different sine beats, continuous sine and a typical natural time-history	30
	Figure A.1 – Recommended shape of a required response spectrum in generalized form.....	37
	Figure A.2 – Standardized presentation of matched sine beats of acceleration, velocity and displacement (five cycles within the sine beat of acceleration)	40
	Table 1 – Comparison of tolerances	15
	Table 2 – Recommended test frequency ranges.....	21
	Table 3 – Recommended test levels with a crossover frequency of 0,8 Hz (see Figure 6)	23
	Table 4 – Recommended test levels with a crossover frequency of 1,6 Hz (see Figure 7)	25
	Table 5 – Recommended test levels with a crossover frequency of 8 Hz (see Figure 8)	27

INTERNATIONAL ELECTROTECHNICAL COMMISSION

ENVIRONMENTAL TESTING –**Part 2-57: Tests – Test Ff: Vibration –
Time-history and sine-beat method****FOREWORD**

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 60068-2-57 has been prepared by IEC technical committee 104: Environmental conditions, classification and methods of test.

This third edition cancels and replaces the second edition, published in 1999. It also replaces IEC 60068-2-59:1990, which will be withdrawn.

This edition includes only minor technical changes with respect to the previous edition:

- editorially combines IEC 60068-2-57 and IEC 60068-2-59;
- the title has been modified to include a sine beat method.

The text of this standard is based on the following documents:

FDIS	Report on voting
104/595/FDIS	104/612/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all the parts in the IEC 60068 series, published under the general title *Environmental testing*, can be found on the IEC website.

This standard is to be used in conjunction with IEC 60068-1.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IECNORM.COM : Click to view the full PDF of IEC 60068-2-57:2013

INTRODUCTION

This part of IEC 60068 details methods for testing components, equipment and other electrotechnical products (hereinafter referred to as “specimens”) which in service can be subjected to random or oscillating type dynamic forces of short duration, typical examples of which are the stresses induced in equipment as a result of earthquakes, explosions and certain phases of transportation, or by transient, short time vibration in machinery.

The characteristics of these forces and the damping of the specimen may be such that the vibration response of the specimen will not reach a steady-state condition.

The time-history test consists, after any preliminary vibration response investigation with sinusoidal or random vibration, in subjecting the specimen to a vibration (acceleration, velocity or displacement) the time history being specified by a response spectrum with characteristics simulating the effects of the dynamic forces.

A time history may be developed or obtained from

- a natural event (natural time history),
 - a random sample
 - a synthesized signal
- } artificial time history.


In general, to adapt to the required testing severity, some modification is necessary.

The use of a time history allows a single test wave to envelop a broadband response spectrum.

It is possible for all the modes of the structure in the excitation axis (or axes) to be excited at the same time and consequently the stresses derived from the combined effects of the coupled modes are generally taken into account.

In the sine beat test, the specimen is excited at fixed frequencies with a preset number of sine beats (see Figure 1). These fixed test frequencies are predetermined test frequencies, or critical frequencies identified by means of a sinusoidal vibration test (IEC 60068-2-6), or both. Pauses are provided between the individual sine beats in order to allow decay of the free response of the specimen.

In Clause 12 specification writers will find a list of details to be considered for inclusion in specifications and, in Annex A, guidance giving necessary extra information.



IEC 907/13

Figure 1 – Sequence of five sine beats with five cycles

ENVIRONMENTAL TESTING –

Part 2-57: Tests – Test Ff: Vibration – Time-history and sine-beat method

1 Scope

This part of IEC 60068 provides a standard procedure for determining, by the time-history and sine-beat methods, the ability of a specimen to withstand specified severities of transient vibration.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60068 (all parts), *Environmental testing*

IEC 60068-1, *Environmental testing – Part 1: General and guidance*

IEC 60068-2-6:2007, *Environmental testing – Part 2-6: Tests – Test Fc: Vibration (sinusoidal)*

IEC 60068-2-47:2005, *Environmental testing – Part 2-47: Tests – Mounting of specimens for vibration, impact and similar dynamic tests*

IEC 60068-2-64:2008, *Environmental testing – Part 2-64: Tests – Vibration, broadband random and guidance*

IEC 60068-3-3:1991, *Environmental testing – Part 3: Guidance – Seismic test methods for equipments*

IEC 60068-3-8, *Environmental testing – Part 3-8: Supporting documentation and guidance – Selecting amongst vibration tests*

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

NOTE Some of the following terms can be found in ISO 2041, IEC 60068-1 or in IEC 60068-2-6. Where, for the convenience of the reader, a definition from one of those sources is included here, it is indicated.

3.1

critical frequency

frequency at which

- malfunctioning and/or deterioration of performance of the specimen which are dependent on vibration are exhibited, and/or
- mechanical resonances and/or other response effects occur, for example chatter

[SOURCE: IEC 60068-2-6:2007, definition 3.9]

3.2**crossover frequency**

frequency at which the characteristic of a vibration changes from one relationship to another

Note 1 to entry: For example, a crossover frequency may be that frequency at which the test vibration amplitude changes from a constant displacement value versus frequency to a constant acceleration value versus frequency.

[SOURCE: ISO 2041:2007, definition 2.118]

3.3**damping**

progressive reduction of the amplitude with time due to the dissipation of energy in a system

Note 1 to entry: In practice, damping depends on many parameters, such as the structural system, mode of vibration, strain, applied forces, velocity, materials, joint slippage, etc.

[SOURCE: IEC 60068-2-6:2007, definition 3.8, modified – original text reads "generic term ascribed to the numerous energy dissipation mechanisms in a system"; Note remains same]

3.4**viscous damping**

damping that occurs when an element or a part of a vibration system is resisted by a force the magnitude of which is proportional to the velocity of the element and the direction of which is opposite to the direction of the velocity

3.5**critical damping**

C_c

minimum viscous damping that will allow a displaced system to return to its initial position without oscillation

3.6**damping ratio**

ratio of actual viscous damping to critical damping in a system with viscous damping

Note 1 to entry: The damping ratio (DR) can be calculated using the formula $DR = C/C_c$ where C is actual viscous damping value and C_c is the critical damping.

Note 2 to entry: This parameter is normally expressed as a percentage value.

3.7**signal tolerance**

signal tolerance $T = \left(\frac{NF}{F} - 1 \right) \times 100$ (per cent)

where

NF is the r.m.s value of the unfiltered signal;

F is the r.m.s value of the filtered signal.

Note 1 to entry: This parameter applies to whichever signal, i.e. acceleration, velocity or displacement, is being used to control the test (see A.2.2 of IEC 60068-2-6:2007)

3.8**fixing point**

part of the specimen in contact with the fixture or vibration table at a point where the specimen is normally fastened in service

Note 1 to entry: If a part of the real mounting structure is used as the fixture, the fixing points are taken as those of the mounting structure and not of the specimen.

[SOURCE: IEC 60068-2-6:2007, definition 3.1, modified – omission of the second NOTE]

3.9 standard acceleration

g_n
standard acceleration due to the earth's gravity, which itself varies with altitude and geographical latitude

Note 1 to entry: For the purposes of this standard, the value of g_n is rounded up to the nearest whole number, that is 10 m/s².

3.10 high stress cycles

response cycles giving rise to values of stress which may cause degradation, deformation or low cycle fatigue in the specimen

Note 1 to entry: Stresses in the specimen are normally not measured or controlled. High stress is used here as a circumscription for high excitation, see A.1.4.

3.11 measuring points

specific points at which data are gathered for conducting the test

Note 1 to entry: These points are of two main types, as defined below

Note 2 to entry: Measurements may be made at points within the specimen in order to assess its behaviour; these are not considered as measuring points in the sense of this standard.

[SOURCE: IEC 60068-2-6:2007, definition 3.2]

3.11.1 check point

point located on the fixture, the real mounting structure, on the vibration table or on the specimen as close as possible to one of its fixing points and in any case rigidly connected to it

Note 1 to entry: A number of check points are used as a means of ensuring that the test requirements are satisfied.

Note 2 to entry: If four or fewer fixing points exist, each is used as a check point. If more than four fixing points exist, four representative fixing points will be defined in the relevant specification to be used as check points.

Note 3 to entry: In special cases, for example for large or complex specimens, the check points will be prescribed by the relevant specification if not close to the fixing points.

Note 4 to entry: Where a large number of small specimens are mounted on one fixture, or in the case of a small specimen where there are a number of fixing points, a single check point (that is the reference point) may be selected for the derivation of the control signal. This signal is then related to the fixture rather than to the fixing points of the specimen(s). This procedure is only valid when the lowest resonance frequency of the loaded fixture is well above the upper frequency of the test.

3.11.2 reference point

point, chosen from the check points, whose signal is used to control the test, so that the requirements of this standard are satisfied

[SOURCE: IEC 60068-2-6:2007, definition 3.2.2]

3.12 modulating frequency

frequency with which the test frequency is modulated

Note 1 to entry: See A.2.2 and Figure 1.

3.13**natural time history**

recording, as a function of time, of the acceleration, velocity or displacement, etc., resulting from a given event

3.14**oscillator**

single degree of freedom system intended to produce or be capable of maintaining mechanical oscillations

3.15**pause**

interval between two consecutive time histories or sine beats

Note 1 to entry: A pause should be such as to result in no significant superposition of the response motion of the specimen.

For sine beats, this is:

$$T > \frac{1}{f} \frac{100}{C_c}$$

where

T is the duration (s);

f is the sine beat test frequency (Hz);

C_c is the critical damping at the test frequency (in per cent).

3.16**preferred testing axes**

three orthogonal axes which correspond to the most vulnerable axes of the specimen

3.17**required response spectrum**

response spectrum specified by the user (customer)

3.18**response spectrum**

plot of the maximum response to a defined input motion of a family of single-degree-of-freedom bodies as a function of their natural frequencies and at a specified damping ratio

3.19**sine beat**

continuous sinusoidal wave of one frequency which is modulated by a sinusoidal wave of a lower frequency

Note 1 to entry: The duration of one sine beat is half the period of the modulating frequency (see Figure 2).

Note 2 to entry: See A.2.2.1 for a mathematical explanation of the sine-beat signal.

3.20**strong part of the time history**

part of time history from the time when the plot first reaches 25 % of the maximum value to the time when it falls for the last time to the 25 % level (see Figure 3)

3.21**sweep cycle**

traverse of the specified frequency range once in each direction, for example 1 Hz to 35 Hz to 1 Hz

[SOURCE: IEC 60068-2-6:2007, definition 3.4, modified – values changed, were "10 Hz to 150 Hz to 10 Hz"]

3.22

synthesized time history

artificially generated time history such that its response spectrum envelops the required response spectrum

3.23

test frequency

frequency at which the specimen is to be excited with sine beats during a test

Note 1 to entry: A test frequency is one of two types which are defined below.

3.23.1

predetermined test frequency

frequency prescribed by the relevant specification.

3.23.2

investigated test frequency

frequency obtained by a vibration response investigation

3.24

test level

largest peak value within a test wave

Note 1 to entry: This definition is not applicable to time-history testing.

Note 2 to entry: For the sine beat method, this is equal to or a negligibly smaller value than the peak value of the modulating half-wave for sine beats.

3.25

test response spectrum

response spectrum derived from the real motion of the vibration table either analytically or by using spectrum analysis equipment

3.26

time history

recording, as a function of time, of acceleration, velocity or displacement


Note 1 to entry: A definition of a mathematical term "time-history" is given in ISO 2041 and relates to the magnitude of a quantity expressed as a function of time.

3.27

zero period acceleration

high frequency asymptotic value of acceleration of the response spectrum

Note 1 to entry: The zero period acceleration is of practical significance as it represents the largest peak value of acceleration, for example in a time history. This is not to be confused with the peak value of acceleration in the response spectrum. For an example see Figure 4.



IEC 908/13

Figure 2 – Number of cycles per sine beat




Figure 3 – Typical time history




Figure 4 – Typical logarithmic plot of a required response spectrum, test response spectrum and tolerance zone

4 Test requirements and associated parameters

4.1 General

The purpose of this test is to determine mechanical weakness and/or degradation in specified performance and to use this information, in conjunction with the relevant specification, to decide whether a specimen is acceptable or not. It may also be used, in some cases, to demonstrate the mechanical robustness of specimens and/or to study their dynamic behaviour.

The extent to which a specimen has to function during vibration or merely to survive conditions of vibration shall be stated in the relevant specification.

Procedures are described for conducting the test and for the measurement of the vibration at given points. The requirements for the vibration motion and for the choice of severities (including frequency range, required response spectrum, number of high-stress cycles and number of time-histories, sine-beat cycles and number of sine beats) are also detailed.

It is emphasized that vibration testing always demands a certain degree of engineering judgement and both supplier and purchaser should be fully aware of this fact. The writer of the relevant specification is expected to select the testing procedure and the values of severity appropriate to the specimen and its use.

For the purpose of this test, the specimen is always fastened directly to the vibration table with its real mounting or a fixture.

In order to facilitate the use of this standard, references are given in the main body of the standard where the reader is invited to refer to Annex A; at the same time, clause numbers in the main body of the standard are also referred to in Annex A. These clauses provide specific information on the correlation between sine beats of displacement, velocity and acceleration.

4.2 Requirements for testing

The requirements for a vibration response investigation are given in 4.3, those for time-history testing in 4.4, those for sine-beat testing in 4.5 while 4.6 deals with mounting for testing. The tolerances applicable to the vibration response investigation and to sine-beat and time history testing are compared in Table 1.

Table 1 – Comparison of tolerances

Parameter	Tolerance	
	Vibration response investigation	Sine-beat and time-history testing
Signal tolerance	5 % (see 4.3.5.3) of basic motion	Not applicable
Vibration at reference point	±15 % (see 4.3.6 a)) of basic motion	
Vibration at check points	±25 % up to 500 Hz (see 4.3.6 b)) of acceleration ±50 % above 500 Hz (see 4.3.6 b)) of acceleration	
Transverse motion	50 % or 25 % (for special cases see 4.3.3)	25 % (see 4.4.2)
Test frequency	(for alternatives see 4.3.7) ±0,05 Hz up to 0,5 Hz ±10 % from 0,5 Hz to 5 Hz ±0,5 Hz from 5 Hz to 100 Hz ±0,5 % above 100 Hz	a) Predetermined (see 4.5.3.2) ±0,05 Hz up to 0,5 Hz ±10 % from 0,5 Hz to 5 Hz ±0,5 Hz from 5 Hz to 100 Hz ±0,5 % above 100 Hz b) Investigated (see 4.5.3.3): ±2 %

4.3 Vibration response investigation

4.3.1 General

When prescribed by the relevant specification, the vibration response investigation shall (see 8.2) be carried out with single axis excitation in a manner based on that of IEC 60068-2-6 particularly taking account of 4.3.2 to 4.3.9 below in order to determine the critical frequencies and, where required, the damping ratio. If considered appropriate, or if specified by the relevant specification, the vibration response investigation may be performed using random vibration in a manner based upon that of IEC 60068-2-64.

4.3.2 Basic motion

The basic motion shall be a sinusoidal function of time and such that the fixing points of the specimen on the vibration table, which shall be prescribed by the relevant specification, move substantially in phase and in straight parallel lines, subject to the limitations imposed in 4.3.3, 4.3.4 and 4.3.6.

4.3.3 Transverse motion

The maximum vibration amplitude at the check points in any axis perpendicular to the specified axis shall not exceed 50 % of the basic motion amplitude. In special cases, for example a small specimen, the peak value of the permissible transverse motion may be limited to 25 % if required by the relevant specification.

At some frequencies, or with large size or high mass specimens, it may be difficult to achieve these values (see also A.1.1). In such cases, the relevant specification shall state which of the following applies:

- a) transverse motion in excess of that stated above shall be reported in the test report;
- b) transverse motion need not be monitored.

4.3.4 Rotational motion

Where spurious rotational motion of the vibration table is likely to be important, a tolerable level, which shall then be reported in the test report, may be prescribed in the relevant specification.

4.3.5 Measuring points

4.3.5.1 Reference point

The relevant specification shall state whether single point or multipoint control is to be used. Where multipoint control is prescribed by the relevant specification, it shall specify whether the average value of the signal at the check points or the value of the signal at a selected point is to be controlled at the specified level.

4.3.5.2 Check points

At some frequencies, or with large size or high mass specimens, it may be difficult to achieve the required tolerances in 4.3.6 b) (see also A.1.1). In these cases, it is expected that a wider tolerance will be prescribed by the relevant specification or that the use of an alternative method of assessment will be reported in the test report.

4.3.5.3 Signal tolerance

The signal tolerance measurement shall be carried out at the reference point at frequencies up to five times the test frequency.

The signal tolerance as defined in 3.7 shall not exceed 5 % of the basic motion.

NOTE In some instances it may not be possible to achieve this, in which case a value of signal tolerance greater than 5 % is acceptable if the test amplitude of the control signal at the fundamental frequency is restored to the specified value, for example by the use of a tracking filter.

In the case of large or complex specimens, where the specified values of signal tolerance cannot be satisfied at some parts of the frequency range and it is impracticable to use a tracking filter, the acceleration amplitude need not be restored and the signal tolerance shall then be reported in the test report (see A.1.1).

The relevant specification may require that the signal tolerance, together with the frequency range affected, is stated in the test report (see Clause 13), and whether or not a tracking filter has been used.

4.3.6 Vibration amplitude tolerances

The basic motion along the required axis at the check and reference points shall be equal to the specified values within the following tolerances. These tolerances include instrument errors:

a) Reference point

Tolerance on the control signal at the reference point shall be ± 15 % of basic motion.

b) Check points

Tolerance at each check point: up to 500 Hz shall be ± 25 % of acceleration; above 500 Hz: ± 50 % of acceleration (see also 4.3.5.2).

4.3.7 Frequency tolerances

The tolerances on the critical frequencies shall be as follows:

- up to 0,25 Hz: $\pm 0,05$ Hz;
- from 0,25 Hz to 5 Hz: ± 20 %;
- from 5 Hz to 50 Hz: ± 1 Hz;
- above 50 Hz: ± 2 %.

When the critical frequencies (see 8.2) are to be compared before and after testing, the relevant specification should specify the comparison criteria; for determination of the critical frequencies, the following frequency tolerances apply:

- up to 0,5 Hz: $\pm 0,05$ Hz;
- from 0,5 Hz to 5 Hz: ± 10 %;
- from 5 Hz to 100 Hz: $\pm 0,5$ Hz;
- above 100 Hz: $\pm 0,5$ %.

4.3.8 Sweeping

Sweeping shall be continuous with the frequency changing exponentially with time at a rate not exceeding one octave per minute (see 3.20).

NOTE With a digital control system, it is not strictly correct to refer to the sweeping as being “continuous” but the difference is of no practical significance.

4.3.9 Damping ratio

The damping ratio of the specimen is normally determined from the vibration response investigation. This determination depends on the test apparatus used and demands engineering judgement. Other methods may be employed if justified in the test report.

4.4 Time-history testing

4.4.1 Basic motion

The time history used can be obtained from either:

- a) a natural time history;
- b) a synthesized time history by composition of frequencies included within the specified range. In this case, the synthesized time history shall be generated with the appropriate resolution, as follows:
 - not more than 1/12 octave bands when the specimen damping (= damping ratio) is lower than or equal to 2 %;
 - not more than 1/6 octave bands when the specimen damping lies between 2 % and 10 % (general case);
 - not more than 1/3 octave bands when the specimen damping is higher than or equal to 10 %.

The value of the damping ratio (see 3.6) may be defined by the relevant specification or otherwise obtained (see 4.3.9). A value of 5 % is normally taken.

4.4.2 Transverse motion

The maximum peak value of acceleration or displacement at the check points on any axis perpendicular to the specified axis (basic motion) shall not exceed 25 % of the specified peak value in the time history or in a sine beat unless otherwise stated in the relevant specification. The recorded measurements need only cover the specified frequency range.

At some frequencies, or with large size or high mass specimens, it may be difficult to achieve these values (see also A.1.1). In such cases, the relevant specification shall state which of the following applies:

- a) transverse motion in excess of that stated above shall be reported in the test report;
- b) transverse motion need not be monitored.

4.4.3 Rotational motion

See 4.3.4 above.

4.4.4 Tolerance zone for the required response spectrum

The tolerance zone to be applied to the required response spectrum shall be in a range between 0 % and +50 % as shown in Figure 4.

If a small proportion of the individual points on the test response spectrum lies outside this zone, the test may still be acceptable. The values for these points should then be reported in the test report (see also Clauses 13 and A.1).

In the range above $1/3 f_2$ (Figure A.1) a tolerance zone > 50 % is permitted.

The test response spectrum shall be checked at least:

- in 1/12 octave bands if the specimen damping is lower than or equal to 2 %;
- in 1/6 octave bands if the specimen damping lies between 2 % and 10 % (general case);
- in 1/3 octave bands if the specimen damping is higher than or equal to 10 %.

In some cases, the required response spectrum may have been so artificially shaped or broadened that the test response spectrum cannot be generated within this tolerance zone. The tolerances in the test specification may then require to be revised.

4.4.5 Frequency range

The signal from the reference point shall not contain any frequency higher than the test frequency range except those induced by the test facilities and specimen. The maximum value of the signal outside the test frequency range induced by the test facilities without specimen shall not exceed 20 % of the maximum value of the specified signal from the reference point. If the above values cannot be achieved, the values obtained shall be reported in the test report.

Frequencies outside the frequency range shall not be taken into account when evaluating the test response spectrum.

4.5 Sine-beat testing

4.5.1 General description

The basic motion shall be a sine-beat function of time and such that the fixing points of the specimen on the vibration table, which shall be prescribed by the relevant specification, move substantially in phase and in straight parallel lines, subject to the limitations imposed in 4.3.1, 4.3.2, 4.3.3 and 4.3.5. The sine-beat test applies only to single axis excitation (see Table 1 in IEC 60068-3-3:1991).

4.5.2 Vibration amplitude tolerances

4.5.2.1 Basic motion

The basic motion along the required axis at the check and reference points shall be equal to the specified values within the following tolerances. These tolerances include instrument errors.

4.5.2.2 Reference point

See 4.3.6 a).

4.5.2.3 Check points

See 4.3.6 b).

4.5.3 Test frequency tolerances

4.5.3.1 General

The tolerances on the test frequency are as follows for the two types:

4.5.3.2 Predetermined test frequency

- up to 0,5 Hz: $\pm 0,05$ Hz;
- from 0,5 Hz to 5 Hz: ± 10 %;
- from 5 Hz to 100 Hz: $\pm 0,5$ Hz;
- above 100 Hz: $\pm 0,5$ %.

4.5.3.3 Investigated test frequency

The deviation of the test frequency from the critical frequency obtained by the vibration response investigation shall not exceed ± 2 %.

4.5.4 Transverse motion

See 4.4.2 above.

4.6 Mounting

The specimen shall be mounted in accordance with IEC 60068-2-6, wherever that standard makes reference to IEC 60068-2-47.

If a specimen is normally mounted on isolators, but it is necessary to test without them, the specified excitation level shall be modified to take this into account.

If a specimen is tested in its real mounting, but the specified excitation is relevant for testing without real mounting, the specified excitation level shall be modified to take this into account, see Clause A.2 of IEC 60068-2-47:2005.

The influence of connections, cables, piping, etc., shall be taken into account when mounting the specimen.

The normal “in service” mounting structure of the specimen should be included in the test.

The response spectrum and the time history used for excitation of the real mounting structure should be different from those used for the excitation of the fixture or the specimen.

The orientation and mounting of the specimen during testing shall be prescribed by the relevant specification and is the only condition for which the specimen is considered as complying with the requirements of the standard, unless adequate justification can be given for extension to an untested condition (for instance, if it is proved that the effects of gravity do not influence the behaviour of the specimen).

5 Severities

5.1 General

The test severity for time history is determined by a combination of the following parameters:

- test frequency range;
- required response spectrum;
- number and duration of time histories;
- number of high stress cycles (if applicable).

The relevant specification shall state the values for each parameter on the basis of the information given in 5.2 to 5.5.

The test severity for sine beat is determined by the combination of the following parameters:

- test frequency range;
- test level;
- number of cycles in the sine beat;
- number of sine beats.

The relevant specification shall state the values for each parameter on the basis of the information given in 5.6.

5.2 Time history

The test frequencies and the test frequency range are obtained as shown in 5.3.

5.3 Test frequency range

The test frequency range shall be given in the relevant specification by selecting a lower frequency from 0,1 Hz, 1 Hz, 5 Hz, 10 Hz, 55 Hz, 100 Hz and an upper frequency from 10 Hz, 20 Hz, 35 Hz, 55 Hz, 100 Hz, 150 Hz, 300 Hz, 500 Hz, 2 000 Hz. The recommended ranges are shown in Table 2.

Table 2 – Recommended test frequency ranges

Recommended test frequency ranges from f_1 to f_2 Hz
0,1 to 10 ^a
1 to 35
1 to 100
5 to 35 ^a
10 to 100 ^a
10 to 500
10 to 2 000
55 to 2 000
^a These ranges are not in the recommended ranges of IEC 60068-2-6.

5.4 Required response spectrum

The relevant specification shall state the level and the shape of the required response spectrum to be used for the testing, including the zero period acceleration value. It shall also state the specimen axes along which the spectra are applied when they are not identical for all the axes.

Guidance for the development of a required response spectrum in the situation where environmental conditions are not well known is provided in A.1.3.

5.5 Number and duration of time-histories

5.5.1 Number of time histories

The relevant specification shall specify the number of time histories to be applied to the specimen and the axes concerned.

Unless otherwise specified, the number of time histories to be applied for each test axis and for each time-history level shall be selected from the following series: ... 1, 2, 5, 10, 20, 50.

When more than one time-history level is used, testing shall always begin with the lowest and continue with higher levels. Each time-history shall be followed by a pause.

5.5.2 Time-history duration

The relevant specification shall state the duration of each time history for which recommended values in seconds are given by the following series: ... 1, 2, 5, 10, 20, 50.

If the period of the test sample is known or can be calculated, the duration of each time-history shall be not less than 3 or 5 times the period.

If specified by the relevant specification 3 s duration may be used.

NOTE 2 Typical duration for earthquakes is 30 s.

5.5.3 Duration of the strong part of the time history

In some cases, the relevant specification may require the strong part of the time history to be a given percentage of the total duration. Otherwise, except when precluded by the requirements of 5.6, the value of the strong part shall be selected from the following percentages of the total duration:

25 %, 50 %, 75 %.

The selected value shall be reported in the test report.


5.5.4 Number of high stress cycles

The relevant specification may state a specified value and the number of high stress cycles leading to values of stress greater than a specified value (see A.1.4).

The number of high stress cycles shall, except when otherwise prescribed by the relevant specification, be selected from the following series: ... 4, 8, 16, 32. The alternate positive and negative cycles shall be approximately equally distributed as shown in Figure 5.

The acceleration value of these high stress cycles should be expressed as a percentage of the peak value of the required response spectrum value at specific critical frequencies that are located in the strong part of the required response spectrum (RRS). The specified value of acceleration shall be selected from the following values:

Specified value (as % of the RRS) 50 %, 70 % (preferred), 90 %



IEC 911/13

Figure 5 – Typical response of an oscillator excited by a specific time history during a test

5.6 Sine-beat test level

5.6.1 General

The relevant specification shall state the value of test level (displacement, velocity or acceleration or all) for each axis (see also A.2.1).

Below the crossover frequency, all peak values are specified at constant displacement and, above this frequency, peak values are specified at constant acceleration. The recommended values are given in Tables 3, 4 and 5 and Figures 6, 7 and 8 for the different chosen crossover frequencies.

Table 3 – Recommended test levels with a crossover frequency of 0,8 Hz (see Figure 6)

Displacement levels below the crossover frequency mm	Acceleration levels above the crossover frequency m/s ²
40	1
80	2
120	3
200	5
NOTE 1 All levels quoted are peak values in a sine beat.	
NOTE 2 For those wishing to continue giving values of acceleration in "g _n ", the value of 10 m/s ² is conventionally ascribed to "g _n " (see 3.9) for the purpose of this standard.	




Figure 6 – Recommended test level with crossover frequency at 0,8 Hz

Table 4 – Recommended test levels with a crossover frequency of 1,6 Hz (see Figure 7)

Displacement levels below the crossover frequency mm	Acceleration levels above the crossover frequency m/s ²
10	1
20	2
30	3
50	5
100	10
200	20

NOTE 1 All values quoted are peak values in a sine beat.

NOTE 2 For those wishing to continue giving values of acceleration in “ g_n ”, the value of 10 m/s² is conventionally ascribed to “ g_n ” (see 3.9) for the purpose of this standard.

IECNORM.COM : Click to view the full PDF of IEC 60068-2-57:2013




Figure 7 – Recommended test level with crossover frequency at 1,6 Hz

Table 5 – Recommended test levels with a crossover frequency of 8 Hz (see Figure 8)

Displacement levels below the crossover frequency mm	Acceleration levels above the crossover frequency m/s ²
0,4	1
0,8	2
1,2	3
2,0	5
4,0	10
8,0	20
12,0	30
20,0	50

NOTE 1 All values quoted are peak values in a sine beat.

NOTE 2 For those wishing to continue giving values of acceleration in “ g_n ”, the value of 10 m/s² is conventionally ascribed to “ g_n ” (see 3.9) for the purpose of this standard.

IECNORM.COM : Click to view the full PDF of IEC 60068-2-57:2013




Figure 8 – Recommended test level with crossover frequency at 8 Hz

Where it is not appropriate to adopt the crossover frequencies stated in this subclause, the relevant specification may couple peak values of displacement and acceleration giving a different crossover frequency. For special applications, more than one crossover frequency may be specified.

5.6.2 Test frequency determination

The test frequencies to be used are the critical frequencies as determined by the vibration response investigation, any predetermined frequencies or both.

In the event that no critical frequencies are identified during the vibration response investigation, and the relevant specification does not state the method to be used to select the test frequencies, the test shall be carried out at frequencies in steps of not greater than one-half octave over the test frequency range selected from the values given in 5.3.

5.6.3 Sine-beat test wave

The sine-beat test wave is determined by the test frequency and the number of cycles within the sine beat (see Figure 2) in accordance with 5.6.5 and 5.6.6.

5.6.4 Number of cycles in the sine beat

The number of cycles in the sine beat shall be prescribed by the relevant specification from the following values (see Figure 2):

3, 5, 10, 20.

NOTE A value of five cycles is preferred since this value represents a compromise, supported by practical experience, between a broad-band signal covering the uncertainties of the critical frequency and a need for a high response value (see Figure 9).

IECNORM.COM : Click to view the full PDF of IEC 60068-2-57:2013




Figure 9 – Amplification factors of different sine beats, continuous sine and a typical natural time-history

5.6.5 Modulating frequency

The modulating frequency is derived from the test frequency and the number of cycles in the sine beat (see also A.2.2.1).

5.6.6 Number of sine beats

The number of sine beats shall be prescribed by the relevant specification from the following series (see Figure 1):

1, 2, 5, 10, 20, 50.

5.6.7 High-stress low-cycle fatigue effects

The relevant specification may prescribe the required number of high-stress cycles each resulting in a greater than specified value of excitation/stress (see A.2.4).

6 Preconditioning

The relevant specification may call for preconditioning as, for example, conditioning the specimen with defined temperature and/or humidity.

7 Initial measurements

The specimen shall be submitted to the visual, dimensional and functional checks prescribed by the relevant specification.

8 Testing

8.1 General

The specimen shall be excited as described in 8.2 and 8.3 and 8.4 in each of the three preferred testing axes, unless otherwise prescribed by the relevant specification. The order of testing along these axes is not important, unless prescribed by the relevant specification.

When prescribed by the relevant specification, control of the specified test level shall be supplemented by a maximum limit of the driving force applied to the vibration table. The method of force limitation shall then also be prescribed by the relevant specification.

8.2 Vibration response investigation

When prescribed by the relevant specification, the test frequency range shall be investigated in order to study the behaviour of the specimen under vibration. The vibration response investigation is performed with a sinusoidal wave in a test frequency range and with a test level as prescribed by the relevant specification. Normally the vibration response investigation shall be carried out with a logarithmic sweep rate not higher than one octave per minute but it may be decreased if more precise determination of the response characteristics can thereby be obtained. Undue dwell should be avoided.

The peak value of the excitation should be selected so that the response of the specimen remains smaller than during time-history or sine-beat testing but at a sufficiently high level to detect critical frequencies.

Alternatively, the investigation can be conducted with random vibration as specified in 8.2 of IEC 60068-2-64:2008.

When a sine-beat test is specified, it is very important to use a sine-beat frequency close to the resonance frequency of the specimen. If the specimen has a nonlinear behaviour, for example surge arresters consisting of porcelain parts joined together with rubber pads in between, then it is preferable to conduct the investigation with sine vibration at a high level. However, if the investigation is only to be used as a dynamic characterization of the specimen, then an investigation using random vibration is suitable.

The specimen shall be functioning during this investigation if required by the relevant specification. Where the mechanical vibration characteristics cannot be assessed because the specimen is functioning, an additional vibration response investigation with the specimen not functioning shall be carried out. During this stage, the specimen shall be examined in order to determine the critical frequencies which shall then be reported in the test report.

In certain circumstances, the relevant specification may prescribe an additional vibration response investigation on completion of the time-history or sine-beat testing so that the critical frequencies can then be compared before and after the testing. The relevant specification shall state what action is to be taken if any change of frequency occurs. It is essential that both vibration response investigations are carried out in the same manner and at the same test level. For more information about vibration investigation, changes in critical frequencies (CCF) and the definition of a pass/fail criterion based on CCF, see IEC 60068-3-8.

8.3 Time-history testing

For time-history testing, values for the severity are given by the relevant specification according to Clause 5. Between consecutive time histories, a pause shall be included such that no significant superposition of response motion of the specimen occurs. The relevant specification shall also state whether single axis, biaxial or triaxial testing is required.

8.4 Sine-beat testing

For sine-beat testing, values for the severity are given by the relevant specification according to Clause 5. Between consecutive sine beats a pause shall be included such that no significant superposition of response motion of the specimen occurs. A recording of the actual control signal at the reference point, including the effects of any filters used, shall be provided in the test report. The relevant specification shall also state whether single axis or biaxial testing is required.

8.5 Multi-axis testing

8.5.1 General

The following applies to both time-history and sine beat testing.

8.5.2 Single axis testing

Single axis testing is preferred unless otherwise specified and is carried out successively along each preferred testing axis. The order of testing along these axes is not important, unless prescribed by the relevant specification.

8.5.3 Biaxial testing

For each series of tests, the two time histories or sine beats are applied simultaneously along two of the preferred testing axes of the specimen. If the time histories are not independent, each test is repeated with, firstly, a relative phase angle of 0° and then 180°. Biaxial testing is not recommended for the sine-beat method.

NOTE When biaxial testing is specified, testing is also possible in a single inclined axis installation but the movements along the two axes will always be dependent. The test response spectrum for each axis should be adjusted to envelop the required response spectrum in that axis.

8.5.4 Triaxial testing

For each series of tests, the time histories are applied simultaneously along all three of the preferred testing axes. For this method of testing, the use of single axis or biaxial installations is not appropriate. Triaxial testing is inappropriate for the sine-beat method.

9 Intermediate measurements

When prescribed by the relevant specification, the specimen shall function during a prescribed number of time-history or sine-beat tests and its performance shall be checked.

10 Recovery

It is sometimes necessary, when prescribed by the relevant specification, to provide a period of time after testing and before final measurements to allow the specimen to attain the same conditions, for example of temperature, as existed for the initial measurements.

11 Final measurements

The specimen shall be submitted to the visual, dimensional and functional checks prescribed by the relevant specification.

The relevant specification shall provide the criteria upon which the acceptance or rejection of the specimen is to be based.

12 Information to be given in the relevant specification

When either of these tests is included in a relevant specification, the following details shall be given, in so far as they are applicable, paying particular attention to the items marked with an asterisk (*) as this information is always required.

	Clause/subclause
a) Fixing points*	4.3.2 and 4.5.1
b) Transverse motion	4.3.3 and 4.4.2
c) Rotational motion	4.3.4 and 4.4.3
d) Measuring points	4.3.5
e) Signal tolerance	4.3.5.3
f) Vibration amplitude tolerances	4.3.6 and 4.5.2
g) Damping ratio	4.3.9
h) Mounting of the specimen*	4.6
i) Required response spectrum*(see also A.1.3)	5.4
j) Number of time histories*	5.5.1
k) Duration of time history*	5.5.2
l) Duration of strong part of time history	5.5.3
m) Number of high stress cycles	5.5.4
o) Test level* (see also A.2.3)	5.6
p) Number of cycles in the sine beat*	5.6.4
q) Modulating frequency	5.6.5
r) Number of sine beats*	5.6.6
s) Preconditioning	6
t) Initial measurements*	7
u) Preferred testing axes	8.1
v) Driving force limitation	8.1

w) Vibration response investigation	8.2
x) Performance and functional check	7, 9, 11
y) Single axis, biaxial or triaxial testing*	8.5
z) Intermediate measurements	9
aa) Recovery	10
bb) Final measurements*	11

13 Information to be given in the test report

As a minimum the test report shall show the following information:

a) Customer	(name and address)
b) Test laboratory	(name and address)
c) Test report identification	(date of issue, unique number)
d) Test dates	
e) Purpose of the test	(development test, qualification, etc.)
f) Test standard, edition	(relevant test procedure)
g) Test specimen description	(initial status, unique ID, quantity, photo, drawing, etc.)
h) Mounting of test specimen	(fixture identity, drawing, photo, etc.)
i) Performance of test apparatus	(cross motion, etc.)
j) Measuring system, sensor location	(description, drawing, photo, etc.)
k) Uncertainties of measuring system	(overall uncertainty, calibration data, if required by relevant specification last/next date of calibration)
l) Initial, intermediate and/or final measurements	
m) Required severities	(as specified in test specification)
n) Test severities with documentation	(test frequency range, required response spectrum, number and durations of time histories, number of high stress response cycles, test level, number of cycles in sine beat, number of sine beats etc.)
o) Test results	(final status of test specimen)
p) Observations during testing and actions taken	
q) Summary of test	
r) Test manager	(name and signature)
s) Distribution	(list of those receiving the report)
t) Testing axes	(single, biaxial, triaxial)

A test log should be written for the testing, where the test is documented by, for example, a chronological list of test runs with test parameters, observations during testing and actions taken and data sheets on measurements made. The test log can be attached to the test report.

NOTE See also ISO/IEC 17025.

Annex A (informative)

Guidance for time-history and sine-beat methods

A.1 Introductory remark

A.1.1 General

Many recognized testing procedures exist for demonstrating the ability of a specimen to withstand various types of vibrational forces. These procedures range from the simple continuous sinusoids to complex highly specialized, time-history and sine-beat methods, each being best suited for particular requirements or circumstances or for representing a particular vibration environment. This standard provides a method by which effects comparable with those likely to be experienced in practice can be reproduced in the test laboratory but the basic intention is not necessarily to reproduce the real environment.

The parameters given are standardized and suitable tolerances are chosen in order to obtain similar results when a test is conducted at different locations. The standardization of values also enables equipments to be grouped into categories corresponding to their ability to withstand certain given vibration severities.

In vibration testing, the usual approach is to conduct a vibration response investigation to search for the critical frequencies of the specimen in the required frequency range. This is followed by some form of endurance test, often by vibrating a specimen for prescribed times at each of these critical frequencies.

The vibration response investigation is normally carried out using single-axis sinusoidal excitation with a single sweep cycle over the required frequency range. The amplitude of vibration during this investigation should not be so large as to produce effects comparable to those of the endurance test itself and should be at a sufficiently low sweep rate to determine the critical frequencies.

A vibration response investigation before and after the endurance test can be used to identify changes in the frequency at which resonance or some other response change occurs. A change in frequency may indicate that some fatigue has occurred and the specimen may therefore be unsuitable for the operational environment, see IEC 60068-3-8.

Caution should be taken when testing large size or high mass specimens, or if the centre of gravity is greatly offset from the centre of the specimen. Such specimens may have a tendency to cause a transverse motion or rotational motion of the vibration table. In such cases, it may be difficult to achieve the required tolerances, such as at a check point.

A.1.2 Time-history method

The time-history method becomes important for

- a) applications where the vibration environment is to be reproduced as closely as possible;
- b) applications where little is known about the specimen, or there is great difficulty in determining critical aspects about the specimen, for example critical frequencies, etc.

Time-history testing avoids a tendency to over-test compared with other methods; this is because the time-history method reproduces, or closely represents, the real environment and the possibility of overstressing or fatiguing from a too conservative test method is reduced.

In reproducing the real or field environment, a response spectrum is developed by the specifier. Usually a damping ratio is assigned which represents the damping of the specimen. This developed response spectrum is called the required response spectrum and is a part of the specification and represents the test criterion which has to be fulfilled.

During the testing of the specimen, the test laboratory produces a similar environment and creates a test response spectrum. This test response spectrum is generated by monitoring the vibration table motion during a test run. The test response spectrum is then compared to the required response spectrum so that it can be determined whether the test criterion has been fulfilled. To fulfil the test criterion, the test response spectrum has to envelop the required response spectrum. In developing the test response spectrum, trial or preliminary runs are often made with the test specimen exchanged for an equivalent mass. Thus, the test laboratory can adjust the test levels and not fatigue and overstress the test specimen unnecessarily.

The tolerances to be applied to the required response spectrum will be stated in the specification; moreover, if a small proportion of the individual points lies outside the tolerance zone (see Figure 4) the test may still be acceptable. In some instances, when testing with high mass or large size specimens it may not be possible to achieve the required tolerances at certain frequencies. In these cases, either the specification will allow a wider tolerance to be applied, or an alternative method of testing will need to be used (see also 4.4.4).

Time-history testing requires the test laboratory to utilize sophisticated and accurate instrumentation, as well as digital computer equipment for control and analysis.

A.1.3 Recommendations for obtaining a required response spectrum

When the application or the environment is not well known the following recommendations are given for defining a required response spectrum according to Figure A.1:

- a) the test frequency range should be selected from Table 2;
- b) the zero period acceleration value, in g_n , (see 3.9) is normally selected from the series: ... 1, 2, 5, 10, 20;
- c) between f_1 and $2f_1$, the acceleration is specified by the slope of 12 dB/octave;
- d) the maximum value of the acceleration between $2f_1$ and $1/3f_2$ is equal to
 - 2,24 times that of zero period acceleration for a 10 % damping ratio,
 - 3 times that of zero period acceleration for a 5 % damping ratio,
 - 5 times that of zero period acceleration for a 2 % damping ratio.

It should be defined for each of the three translational degrees of freedom separately, or at least one spectrum should be given for the horizontal and one spectrum for the vertical direction of excitation.

When the typical damping ratio of the specimen lies between 2 % and 10 %, the required response spectrum at 5 % is recommended. If the typical damping ratio of the specimen is lower than or equal to 2 %, only the required response spectrum at 2 % is recommended, and if the damping ratio is higher than or equal to 10 %, the required response spectrum at 10 % is recommended.

NOTE When the frequency f_1 is lower than 0,8 Hz, the acceleration below 1,6 Hz will be specified by the slope of 12 dB/octave.




Figure A.1 – Recommended shape of a required response spectrum in generalized form

A.1.4 Number of high stress cycles

The reproduction of the effects of high-stress, low-cycle fatigue which would be produced by vibration (for example produced by earthquakes, explosions) requires that the specific environment be simulated as accurately as possible. When the environment is not sufficiently known or is difficult to simulate, a safety margin needs to be included to allow for uncertainties. It is therefore necessary that the peak value of the test level and the number of sine beats should be appropriate to the event being considered to take account of the worst case.

Occasionally this approach may not be sufficient as it does not completely take into account the effects of high-level alternating excitations. These excitations may be critical for a specimen when they occur at its resonance frequencies and generate non-elastic strains which may be detrimental for the specimen. In such cases, analysis of the signals simulating the event considered will help in confirming the adequacy of the test.

The first criterion for the above consists in ensuring that the test response spectrum envelops the required response spectrum. This envelope ensures that the maximum required level of each oscillator response has been reached.

The second criterion is to ensure that the duration of the strong part of the time history is equal to or longer than the considered phenomenon.

These two approaches may, however, not be sufficient as they do not take account completely of the effects of high-level alternating excitation. Indeed these excitations may be

vitally important for equipment when they occur at critical frequencies and generate non-elastic strains which may be detrimental to the specimen.

An analysis of both the signals simulating the phenomena under consideration and of the specimen characteristics allows these high-level stresses to be taken into account, if necessary. In practice, this is done by counting the number of high stress cycles exceeding a specified level for each oscillator centred on a specific frequency. Since the fatigue damage decreases very rapidly with decreasing amplitude, it is often sufficient to consider only the peaks higher than a specified maximum value, for example for the required response spectrum value (see Figure 5). This specified value very much depends on the fatigue properties of the material and where the failure occurs.

A.2 Sine-beat method

A.2.1 General

The sine-beat method is suitable for the testing of equipment which is subjected in service to pulsating or oscillating forces of short duration which are not accurately defined. It is particularly suitable for testing equipment which is to be mounted in structures that may then be subjected in service to random or multi-frequency excitations. These structures respond at their resonance frequencies, producing a sine-beat motion representing the input to the equipment of interest. Thus testing with a sine-beat wave subjects equipment mounted in this manner to excitation, close to that found in practice. In addition, the sine beat produces a broader, less damaging response than that obtained from a continuous sine wave.

The sine-beat test is undertaken at the frequencies determined by the vibration response investigation, at any other predetermined frequencies, or at both. If no frequencies have been determined or specified, the test is usually carried out in steps of one-half octave over the full frequency range of interest. As the number of critical frequencies increases, the sine-beat method may become less appropriate because of the problem of accumulated fatigue damage. In this situation, other test methods should be considered.

A.2.2 Correlation of sine beats of displacement, velocity and acceleration

A.2.2.1 Sine-beat function (see 3.19)

The general mathematical expression for a sine beat is:

$$a(t) = a_0 \times \sin 2\pi ft \times \sin \frac{2\pi ft}{\rho}$$

where

$$0 \leq t \leq \frac{\rho}{2f};$$

a_0 is the test level;

f is the test frequency;

ρ is, as a general rule, the ratio between the test frequency and the modulating frequency.

Since acceleration, velocity and displacement are interrelated, only one of these can be selected as the basic function and this will have some effect on the others.

With acceleration as the reference signal, there will be a residual displacement at the end of each beat.

To avoid this effect, formulae based on velocity as the reference signal are given in A.2.2.2.

A.2.2.2 Correlation of sine beats

The correlation of sine beats of acceleration, velocity and displacement with velocity as the reference function is as follows:

Sine beat of velocity

$$v(t) = \frac{a_o}{2\pi f} \times \sin 2\pi ft \times \sin \frac{2\pi ft}{m}$$

equivalent to:

$$v(t) = \frac{a_o}{2\pi f} \times \frac{1}{2} \left[\cos 2\pi \left(1 - \frac{1}{m}\right) ft - \cos 2\pi \left(1 + \frac{1}{m}\right) ft \right]$$

corresponding acceleration

$$a(t) = a_o \times \frac{1}{2} \left[\left\{ -\left(1 - \frac{1}{m}\right) \times \sin 2\pi \left(1 - \frac{1}{m}\right) ft \right\} + \left\{ \left(1 + \frac{1}{m}\right) \times \sin 2\pi \left(1 + \frac{1}{m}\right) ft \right\} \right]$$

corresponding displacement

$$d(t) = \frac{a_o}{(2\pi f)^2} \times \frac{1}{2} \left[\left(\frac{1}{1 - \frac{1}{m}} \right) \times \sin 2\pi \left(1 - \frac{1}{m}\right) ft - \left(\frac{1}{1 + \frac{1}{m}} \right) \times \sin 2\pi \left(1 + \frac{1}{m}\right) ft \right]$$


where

$0 \leq t \leq \frac{m}{2f}$ and m is the ratio of test frequency to the modulating frequency for acceleration and is equal to $2n$ where n is the number of cycles in the sine beat of acceleration.

NOTE 1 In the mathematical explanation, use is made of the possibility that a single sine beat can also be expressed as two superimposed cosinus vibrations. Signals resulting from this definition are shown in Figure A.2 for a five-cycle sine beat.

NOTE 2 All signals resulting from the differentiation or integration with respect to time of a sine beat as defined in A.2.2.1 are characterized as sine beats for the purpose of this standard.

NOTE 3 It should be noted that this explanation is not intended as a rigorous mathematical proof and in order to get zero values at the end of all sine-beat functions the value of ρ is slightly modified and becomes m (see A.2.3).



IEC 917/13

Figure A.2 – Standardized presentation of matched sine beats of acceleration, velocity and displacement (five cycles within the sine beat of acceleration)

A.2.3 Test level

The values of the test levels of displacement, velocity and acceleration can be derived with sufficient accuracy in the same way as for sinusoidal vibration with constant frequency, that is, based upon the test level a_0 of the sine beat of acceleration. The vibrational peak values of the velocity v_0 or displacement d_0 are given by:

$$v_0 \approx \frac{a_0}{2\pi f}$$

$$d_0 \approx \frac{a_0}{4\pi^2 f^2}$$

A.2.4 High-stress low-cycle fatigue

See A.1.4.

Bibliography

IEC 60068-2-59:1990, *Environmental testing – Part 2-59: Test methods – Test Fe: Vibration – Sine-beat method*¹

IEC 60068-2-81, *Environmental testing – Part 2-81: Tests – Test Ei: Shock – Shock response spectrum synthesis*

ISO/IEC 17025, *General requirements for the competence of testing and calibration laboratories*

ISO 2041, *Mechanical vibration, shock and condition monitoring – Vocabulary*

IECNORM.COM : Click to view the full PDF of IEC 60068-2-57:2013

¹ Withdrawn and replaced by this current third edition of IEC 60068-2-57.

SOMMAIRE

AVANT-PROPOS	44
INTRODUCTION	46
1 Domaine d'application	48
2 Références normatives	48
3 Termes et définitions	48
4 Exigences d'essai et paramètres associés	55
4.1 Généralités	55
4.2 Exigences relatives à l'essai	55
4.3 Recherche et étude des fréquences critiques	56
4.3.1 Généralités	56
4.3.2 Mouvement fondamental	56
4.3.3 Mouvement transversal	56
4.3.4 Mouvement de rotation	56
4.3.5 Points de mesure	56
4.3.6 Tolérances sur l'amplitude de la vibration	57
4.3.7 Tolérances sur les fréquences	57
4.3.8 Balayage	58
4.3.9 Taux d'amortissement	58
4.4 Essai par accélérogrammes	58
4.4.1 Mouvement fondamental	58
4.4.2 Mouvement transversal	58
4.4.3 Mouvement de rotation	58
4.4.4 Zone de tolérance sur le spectre de réponse spécifié	59
4.4.5 Gamme de fréquences	59
4.5 Essai par sinusoïdes modulées	59
4.5.1 Description générale	59
4.5.2 Tolérances sur l'amplitude de la vibration	59
4.5.3 Tolérances sur les fréquences d'essai	60
4.5.4 Mouvement transversal	60
4.6 Fixation	60
5 Sévérités	61
5.1 Généralités	61
5.2 Accélérogramme	61
5.3 Gammes de fréquences d'essai	61
5.4 Spectre de réponse spécifié	62
5.5 Nombre et durée des accélérogrammes	62
5.5.1 Nombre d'accélérogrammes	62
5.5.2 Durée de l'accélérogramme	62
5.5.3 Durée de la partie forte de l'accélérogramme	62
5.5.4 Nombre de cycles de réponse de niveau élevé	62
5.6 Amplitude d'essai en sinusoïdes modulées	63
5.6.1 Généralités	63
5.6.2 Détermination des fréquences d'essai	69
5.6.3 Essai par sinusoïdes modulées	69
5.6.4 Nombre de cycles dans la sinusoïde modulée	69
5.6.5 Fréquence de modulation	70

5.6.6	Nombre de sinusoïdes modulées	71
5.6.7	Fatigue de type oligocyclique.....	71
6	Préconditionnement.....	71
7	Mesures initiales	71
8	Essais	71
8.1	Généralités.....	71
8.2	Recherche et étude des fréquences critiques	71
8.3	Essai par accélérogrammes	72
8.4	Essai par sinusoïdes modulées	72
8.5	Essai multiaxe	72
8.5.1	Généralités.....	72
8.5.2	Essai de type monoaxial	72
8.5.3	Essai de type biaxial.....	72
8.5.4	Essai de type triaxial	73
9	Mesures intermédiaires	73
10	Reprise.....	73
11	Mesures finales	73
12	Renseignements à inclure dans la spécification particulière.....	73
13	Renseignements à fournir dans le rapport d'essai.....	74
Annexe A (informative) Guide relatif aux méthodes par accélérogramme et par sinusoïdes modulées		76
Bibliographie.....		82
Figure 1 – Séquence de cinq sinusoïdes modulées de cinq cycles		47
Figure 2 – Nombre de cycles par sinusoïde modulée		53
Figure 3 – Accélérogramme caractéristique		54
Figure 4 – Représentation logarithmique caractéristique d'un spectre de réponse spécifié, d'un spectre de réponse d'essai et de zone de tolérance		54
Figure 5 – Réponse type d'un oscillateur excité selon un accélérogramme spécifique lors d'un essai		63
Figure 6 – Amplitude d'essai recommandée pour une fréquence de transfert de 0,8 Hz		64
Figure 7 – Amplitude d'essai recommandée pour une fréquence de transfert de 1,6 Hz		66
Figure 8 – Amplitude d'essai recommandée pour une fréquence de transfert de 8 Hz		68
Figure 9 – Facteur d'amplification de différentes sinusoïdes modulées, d'une sinusoïde continue et d'un accélérogramme naturel type		70
Figure A.1 – Forme globale recommandée du spectre de réponse spécifié		78
Figure A.2 – Présentation normalisée de sinusoïdes modulées exprimées en accélération, vitesse et déplacement (avec sinusoïde modulée de l'accélération de cinq cycles).....		81
Tableau 1 – Comparaison des tolérances		55
Tableau 2 – Gammes de fréquences d'essai recommandées		61
Tableau 3 – Amplitudes d'essai recommandées pour une fréquence de transfert de 0,8 Hz (voir la Figure 6)		63
Tableau 4 – Amplitudes d'essai recommandées pour une fréquence de transfert de 1,6 Hz (voir la Figure 7)		65
Tableau 5 – Amplitudes d'essai recommandées pour une fréquence de transfert de 8 Hz (voir la Figure 8)		67

COMMISSION ÉLECTROTECHNIQUE INTERNATIONALE

ESSAIS D'ENVIRONNEMENT –

Partie 2-57: Essais – Essai Ff: Vibrations – Méthode par accélérogrammes et sinusoïdes modulées

AVANT-PROPOS

- 1) La Commission Electrotechnique Internationale (CEI) est une organisation mondiale de normalisation composée de l'ensemble des comités électrotechniques nationaux (Comités nationaux de la CEI). La CEI a pour objet de favoriser la coopération internationale pour toutes les questions de normalisation dans les domaines de l'électricité et de l'électronique. A cet effet, la CEI – entre autres activités – publie des Normes internationales, des Spécifications techniques, des Rapports techniques, des Spécifications accessibles au public (PAS) et des Guides (ci-après dénommés "Publication(s) de la CEI"). Leur élaboration est confiée à des comités d'études, aux travaux desquels tout Comité national intéressé par le sujet traité peut participer. Les organisations internationales, gouvernementales et non gouvernementales, en liaison avec la CEI, participent également aux travaux. La CEI collabore étroitement avec l'Organisation Internationale de Normalisation (ISO), selon des conditions fixées par accord entre les deux organisations.
- 2) Les décisions ou accords officiels de la CEI concernant les questions techniques représentent, dans la mesure du possible, un accord international sur les sujets étudiés, étant donné que les Comités nationaux de la CEI intéressés sont représentés dans chaque comité d'études.
- 3) Les Publications de la CEI se présentent sous la forme de recommandations internationales et sont agréées comme telles par les Comités nationaux de la CEI. Tous les efforts raisonnables sont entrepris afin que la CEI s'assure de l'exactitude du contenu technique de ses publications; la CEI ne peut pas être tenue responsable de l'éventuelle mauvaise utilisation ou interprétation qui en est faite par un quelconque utilisateur final.
- 4) Dans le but d'encourager l'uniformité internationale, les Comités nationaux de la CEI s'engagent, dans toute la mesure possible, à appliquer de façon transparente les Publications de la CEI dans leurs publications nationales et régionales. Toutes divergences entre toutes Publications de la CEI et toutes publications nationales ou régionales correspondantes doivent être indiquées en termes clairs dans ces dernières.
- 5) La CEI elle-même ne fournit aucune attestation de conformité. Des organismes de certification indépendants fournissent des services d'évaluation de conformité et, dans certains secteurs, accèdent aux marques de conformité de la CEI. La CEI n'est responsable d'aucun des services effectués par les organismes de certification indépendants.
- 6) Tous les utilisateurs doivent s'assurer qu'ils sont en possession de la dernière édition de cette publication.
- 7) Aucune responsabilité ne doit être imputée à la CEI, à ses administrateurs, employés, auxiliaires ou mandataires, y compris ses experts particuliers et les membres de ses comités d'études et des Comités nationaux de la CEI, pour tout préjudice causé en cas de dommages corporels et matériels, ou de tout autre dommage de quelque nature que ce soit, directe ou indirecte, ou pour supporter les coûts (y compris les frais de justice) et les dépenses découlant de la publication ou de l'utilisation de cette Publication de la CEI ou de toute autre Publication de la CEI, ou au crédit qui lui est accordé.
- 8) L'attention est attirée sur les références normatives citées dans cette publication. L'utilisation de publications référencées est obligatoire pour une application correcte de la présente publication.
- 9) L'attention est attirée sur le fait que certains des éléments de la présente Publication de la CEI peuvent faire l'objet de droits de brevet. La CEI ne saurait être tenue pour responsable de ne pas avoir identifié de tels droits de brevets et de ne pas avoir signalé leur existence.

La Norme internationale CEI 60068-2-57 a été établie par le comité d'études 104 de la CEI: Conditions, classification et essais d'environnement.

Cette troisième édition annule et remplace la deuxième édition, publiée en 1999. Elle remplace également la CEI 60068-2-59:1990, qui sera retirée.

Cette édition inclut seulement des modifications techniques mineures suivantes par rapport à l'édition précédente:

- combinaison éditoriale de la CEI 60068-2-57 et de la CEI 60068-2-59;
- le titre a été modifié afin d'inclure la méthode d'essai sinusoïde modulé.

Le texte de cette norme est issu des documents suivants:

FDIS	Rapport de vote
104/595/FDIS	104/612/RVD

Le rapport de vote indiqué dans le tableau ci-dessus donne toute information sur le vote ayant abouti à l'approbation de cette norme.

Cette publication a été rédigée selon les Directives ISO/CEI, Partie 2.

Une liste de toutes les parties de la série CEI 60068, publiées sous le titre général *Essais d'environnement*, peut être consultée sur le site web de la CEI.

La présente norme est à lire conjointement avec la CEI 60068-1.

Le comité a décidé que le contenu de cette publication ne sera pas modifié avant la date de stabilité indiquée sur le site web de la CEI sous "<http://webstore.iec.ch>" dans les données relatives à la publication recherchée. A cette date, la publication sera

- reconduite,
- supprimée,
- remplacée par une édition révisée, ou
- amendée.

IECNORM.COM : Click to view the full PDF of IEC 60068-2-57:2013

INTRODUCTION

La présente partie de la CEI 60068 décrit des méthodes d'essai applicables aux composants, matériels et autres produits électrotechniques (dénommés ci-après "spécimens"), pouvant, pendant leur utilisation, être soumis à des sollicitations dynamiques de caractère aléatoire et oscillatoire de durée brève, comme celles qui résultent de séismes, d'explosions et de certaines phases de transport ou bien encore de vibrations transitoires de courte durée produites par des machines.

La nature de ces sollicitations et l'amortissement du spécimen peuvent être tels que la réponse vibratoire de ce dernier n'atteint pas le régime permanent.

Après l'essai préliminaire d'étude des fréquences critiques effectué en vibrations sinusoïdales ou aléatoires, l'essai par accélérogrammes consiste à soumettre le spécimen à un accélérogramme de vibrations (accélération, vitesse ou déplacement), défini par son spectre de réponse et dont les caractéristiques simulent l'effet des sollicitations dynamiques.

Les accélérogrammes peuvent provenir ou être obtenus à partir

- d'un phénomène naturel (accélérogramme naturel),
 - d'un échantillon de mouvement aléatoire
 - d'un signal synthétisé
- } accélérogramme artificiel.


En général, il est nécessaire de modifier ces signaux pour les adapter aux sévérités d'essai demandées.

L'intérêt de l'utilisation des accélérogrammes réside dans la possibilité de couvrir un spectre de réponse à large bande de fréquences par l'application d'une seule onde d'essai.

Tous les modes de la structure situés dans l'axe ou les axes d'excitation peuvent être sollicités en même temps et, de ce fait, les contraintes résultant des effets combinés des modes couplés sont généralement prises en compte.

Dans l'essai en sinusoïdes modulées, le spécimen est excité à des fréquences discrètes, avec un nombre prédéterminé de sinusoïdes modulées (voir la Figure 1). Ces fréquences discrètes d'essai sont, soit des fréquences d'essai prédéterminées, soit des fréquences critiques identifiées au moyen d'un essai en vibrations sinusoïdales (CEI 60068-2-6) ou les deux. Des pauses sont respectées entre chaque sinusoïde modulée, afin de permettre l'atténuation de la réponse propre du spécimen.

Les rédacteurs de spécifications trouveront à l'Article 12 une liste de points particuliers à prendre en considération en vue de leur inclusion dans les spécifications, et à l'Annexe A, un guide donnant les compléments d'information nécessaires.



IEC 907/13

Figure 1 – Séquence de cinq sinusoïdes modulées de cinq cycles

ESSAIS D'ENVIRONNEMENT –

Partie 2-57: Essais – Essai Ff: Vibrations – Méthode par accélérogrammes et sinusoïdes modulées

1 Domaine d'application

La présente partie de la CEI 60068 a pour objet de donner des règles d'exécution normalisées pour déterminer l'aptitude d'un spécimen à supporter des sévérités données de vibrations de courte durée, au moyen des méthodes par accélérogrammes et sinusoïdes modulées.

2 Références normatives

Les documents suivants sont cités en référence de manière normative, en intégralité ou en partie, dans le présent document et sont indispensables pour son application. Pour les références datées, seule l'édition citée s'applique. Pour les références non datées, la dernière édition du document de référence s'applique (y compris les éventuels amendements).

CEI 60068 (toutes les parties), *Essais d'environnement*

CEI 60068-1, *Essais d'environnement – Partie 1: Généralités et guide*

CEI 60068-2-6:2007, *Essais d'environnement – Partie 2-6: Essais – Essai Fc: Vibrations (sinusoïdales)*

CEI 60068-2-47:2005, *Essais d'environnement – Partie 2-47: Essais – Fixation de spécimens pour essais de vibrations, d'impacts et autres essais dynamiques*

IEC 60068-2-64:2008, *Essais d'environnement – Partie 2-64: Essai Fh: Vibrations aléatoires à large bande et guide*

CEI 60068-3-3:1991, *Essais d'environnement – Partie 3-3: Guide – Méthodes d'essais sismiques applicables aux matériels*

CEI 60068-3-8, *Essais d'environnement – Partie 3-8: Documentation d'accompagnement et lignes directrices – Sélection d'essais de vibrations*

3 Termes et définitions

Pour les besoins du présent document, les termes et définitions suivants s'appliquent.

NOTE Certains des termes suivants peuvent se trouver dans les normes ISO 2041, la CEI 60068-1 ou dans la CEI 60068-2-6. Si, pour être agréable au lecteur, une définition issue de l'une de ces sources est mentionnée ci-dessous, l'origine est indiquée

3.1

fréquence critique

fréquence pour laquelle

- il apparaît un mauvais fonctionnement et/ou une altération des propriétés du spécimen, dus aux vibrations, et/ou

- se produisent des résonances mécaniques et/ou d'autres manifestations d'une réponse, par exemple des martèlements

[SOURCE: CEI 60068-2-6:2007, définition 3.9]

3.2

fréquence de transfert

fréquence à laquelle la caractéristique d'une vibration passe d'une relation à une autre

Note 1 à l'article: Par exemple, une fréquence de transfert peut être la fréquence à laquelle la valeur de l'amplitude des vibrations d'essai passe, par rapport à la fréquence, d'une valeur de déplacement constante, à une valeur à accélération constante.

[SOURCE: ISO 2041:2007, définition 2.118]

3.3

amortissement

réduction progressive de l'amplitude avec le temps, due à la dissipation de l'énergie dans un système.

Note 1 à l'article: En pratique, l'amortissement dépend de plusieurs facteurs, tels que le type de structure, le mode de vibration, la déformation, la force appliquée, la vitesse, les matériaux, le glissement des joints, etc.

[SOURCE: CEI 60068-2-6:2007, définition 3.8, modifiée – texte original lit "terme générique lié à de nombreux mécanismes de dissipation d'énergie dans un système"; la Note reste identique]

3.4

amortissement visqueux

amortissement de l'énergie se produisant quand un élément ou une partie d'un système de vibrations est soumis à une force résistante ayant une valeur proportionnelle au module de la vitesse de l'élément et une direction opposée à la direction de la vitesse

3.5

amortissement critique

C_c

valeur minimale de l'amortissement visqueux pour lequel un système avec déplacement initial revient à sa position de repos sans oscillation

3.6

taux d'amortissement

rapport entre la valeur de l'amortissement visqueux réel et la valeur de l'amortissement critique d'un système à amortissement visqueux

Note 1 à l'article: Le taux d'amortissement (DR : *Damping ratio*) peut être calculé par la formule $DR = C/C_c$, où C est la valeur de l'amortissement visqueux réel et C_c est celle de l'amortissement critique.

Note 2 à l'article: Ce paramètre est habituellement exprimé en pourcentage.

3.7

tolérance sur le signal

tolérance sur le signal $T = \left(\frac{NF}{F} - 1 \right) \times 100$ (pourcent)

où

NF est la valeur efficace du signal non filtré;

F est la valeur efficace du signal filtré.

Note 1 à l'article: Ce paramètre s'applique quelque soit le signal, c.-à-d. accélération, vitesse ou déplacement, utilisé pour contrôler l'essai (voir A.2.2 de la CEI 60068-2-6:2007).

3.8

point de fixation

partie du spécimen en contact avec le bâti de fixation ou la table vibrante en un point où le spécimen est normalement fixé en utilisation

Note 1 à l'article: Si une partie de la structure normale de montage est utilisée comme bâti, les points de fixation sont pris comme étant ceux de la structure de montage et non ceux du spécimen.

[SOURCE: CEI 60068-2-6:2007, définition 3.1, modifiée – suppression de la deuxième NOTE]

3.9

accélération normalisée

g_n

accélération normalisée de la pesanteur, variable en fonction de l'altitude et de la latitude

Note 1 à l'article: Dans le cadre de la présente norme, la valeur de g_n est arrondie au nombre entier le plus proche, c'est-à-dire 10 m/s².

3.10

cycles de réponse de niveau élevé

cycles de réponse atteignant des niveaux de contraintes pouvant entraîner la dégradation, la déformation ou une fatigue oligocyclique du spécimen

Note 1 à l'article: Les contraintes dans le spécimen ne sont habituellement ni mesurées ni contrôlées. Une forte contrainte est ici utilisée comme une circonscription des efforts de sollicitation élevés, voir A.1.4.

3.11

points de mesure

points particuliers où des informations sont recueillies pour la conduite de l'essai

Note 1 à l'article: Ils sont de deux types principaux, définis ci-après.

Note 2 à l'article: On peut faire des mesures en certains points du spécimen afin de connaître son comportement; ces points ne sont pas considérés comme des points de mesure au sens de la présente norme.

[SOURCE: CEI 60068-2-6:2007, définition 3.2]

3.11.1

point de vérification

point situé sur le bâti de fixation, la structure normale de montage, sur la table vibrante ou sur le spécimen, aussi près que possible de l'un des points de fixation du spécimen et, dans tous les cas, rigidement lié à ce dernier

Note 1 à l'article: On peut être conduit à utiliser plusieurs points de vérification pour s'assurer que les exigences de l'essai sont satisfaites.

Note 2 à l'article: S'il n'y a pas plus de quatre points de fixation, chacun d'eux sera pris comme point de vérification. S'il y a plus de quatre points de fixation, la spécification particulière désignera les quatre points de fixation représentatifs à utiliser comme points de vérification.

Note 3 à l'article: Dans les cas particuliers, par exemple pour des spécimens complexes ou volumineux, la spécification particulière indiquera les points de vérification, s'ils ne sont pas à proximité des points de fixation.

Note 4 à l'article: Dans le cas d'un grand nombre de petits spécimens fixés sur un seul bâti, ou dans celui d'un petit spécimen ayant plusieurs points de fixation, on peut sélectionner, pour obtenir le signal de pilotage, un seul point de vérification (c'est-à-dire le point de référence). Ce signal est lié au support plutôt qu'aux points de fixation du ou des spécimens. Cela n'est valable que lorsque la plus basse fréquence de résonance du support chargé est située nettement au-dessus de la limite supérieure de la fréquence de l'essai.

3.11.2

point de référence

point, choisi parmi les points de vérification, dont on utilise le signal pour piloter l'essai, afin de satisfaire aux exigences d'essai spécifiées

[SOURCE: CEI 60068-2-6:2007, définition 3.2.2]

3.12

fréquence de modulation

fréquence utilisée pour moduler la fréquence d'essai

Note 1 à l'article: Voir A.2.2 et la Figure 1.

3.13

accélérogramme naturel

enregistrement, en fonction du temps, de l'accélération, de la vitesse ou du déplacement, etc., résultant d'un phénomène donné

3.14

oscillateur

système à un degré de liberté destiné à produire ou à entretenir des oscillations mécaniques

3.15

pause

intervalle entre deux accélérogrammes consécutifs ou sinusoïdes modulées

Note 1 à l'article: Il convient que la pause soit d'une durée suffisante pour qu'il n'en résulte pas de superposition significative dans le mouvement de réponse du spécimen.

Pour les sinusoïdes modulées, elle est:

$$T > \frac{1}{f} \frac{100}{C_c}$$

où

T est la durée (s);

f est la fréquence d'essai en sinusoïdes modulées;

C_c est l'amortissement critique à la fréquence d'essai (en pourcentage).

3.16

axes préférentiels d'essai

trois axes orthogonaux correspondant aux axes les plus vulnérables du spécimen

3.17

spectre de réponse spécifié

spectre de réponse spécifié par l'utilisateur (client)

3.18

spectre de réponse

représentation de la réponse maximale d'une famille d'oscillateurs à un degré de liberté soumis à un déplacement donné, en fonction de leurs fréquences naturelles et pour une valeur spécifiée du taux d'amortissement

3.19

sinusoïde modulée

onde sinusoïdale à fréquence fixe, module en amplitude par une onde sinusoïdale de fréquence inférieure

Note 1 à l'article: La durée d'une sinusoïde modulée est égale à une demi-période de la fréquence de modulation (voir la Figure 2).

Note 2 à l'article: Voir A.2.2.1 pour l'expression mathématique d'une sinusoïde modulée.

3.20

partie forte d'un accélérogramme

partie d'un accélérogramme comprise entre l'instant où il dépasse pour la première fois 25 % de sa valeur maximale et celui où il descend au-dessous de 25 % pour la dernière fois (voir la Figure 3)

3.21

cycle de balayage

parcours, une fois dans chaque sens, de la gamme de fréquences spécifiée, par exemple de 1 Hz à 35 Hz à 1 Hz

[SOURCE: CEI 60068-2-6:2007, définition 3.4, modifiée – les valeurs ont été modifiées, ils étaient, "10 Hz à 350 Hz à 10 Hz"]

3.22

accélérogramme synthétique

accélérogramme qui est produit artificiellement pour que le spectre de réponse lui correspondant enveloppe le spectre de réponse spécifié

3.23

fréquence d'essai

fréquence à laquelle le spécimen est excité avec la sinusoïde modulée, lors d'un essai

Note 1 à l'article: Une fréquence d'essai est de l'un des deux types définis ci-dessous.

3.23.1

fréquence d'essai prédéterminée

fréquence spécifiée par la spécification particulière

3.23.2

fréquence d'essai d'investigation

fréquence relevée lors de l'essai de recherche et d'étude des fréquences critiques

3.24

amplitude d'essai

valeur maximale des valeurs de crête de l'onde d'essai

Note 1 à l'article: Cette définition n'est pas applicable à l'essai par accélérogrammes.

Note 2 à l'article: Pour la méthode de la sinusoïde modulée, celle-ci est égale à la valeur de crête de la demi-onde de modulation des sinusoïdes modulées ou est de valeur légèrement inférieure.

3.25

spectre de réponse d'essai

spectre de réponse obtenu à partir du mouvement réel de la table vibrante, soit analytiquement, soit en utilisant des moyens d'analyse spectrale

3.26

accélérogramme

enregistrement de l'accélération, de la vitesse ou du déplacement en fonction du temps


Note 1 à l'article: La définition mathématique du terme "accélérogramme" est donnée dans l'ISO 2041 et se réfère à l'amplitude d'une grandeur exprimée en fonction du temps.

3.27

accélération à période nulle

valeur asymptotique du spectre de réponse d'accélération aux fréquences élevées

Note 1 à l'article: L'accélération à période nulle a une signification particulière, par exemple, dans le cas d'un accélérogramme; elle est sensiblement égale à la valeur maximale de l'accélération. Il convient de ne pas la confondre avec la valeur maximale du spectre de réponse. Voir, par exemple, la Figure 4.



IEC 908/13

Figure 2 – Nombre de cycles par sinusoïde modulée




Figure 3 – Accélérogramme caractéristique




Figure 4 – Représentation logarithmique caractéristique d'un spectre de réponse spécifié, d'un spectre de réponse d'essai et de zone de tolérance

4 Exigences d'essai et paramètres associés

4.1 Généralités

Le but de cet essai est de déterminer les faiblesses mécaniques et/ou les dégradations des performances spécifiées et d'utiliser ces informations conjointement avec la spécification particulière pour décider si le spécimen est acceptable ou non. On peut aussi l'utiliser dans certains cas pour démontrer la robustesse mécanique des spécimens et/ou pour étudier leur comportement dynamique.

La spécification particulière doit indiquer s'il est nécessaire que le spécimen fonctionne en présence de vibrations ou s'il suffit qu'il soit encore en état de fonctionner après y avoir été soumis.

Les modalités de l'essai sont décrites pour son exécution et pour les mesures des vibrations en des points donnés. Les exigences relatives au mouvement vibratoire, au choix des sévérités (comprenant les gammes de fréquences, les spectres de réponse spécifiés, le nombre de cycles de niveau élevé et le nombre d'accélérogrammes, le nombre de cycles et le nombre des sinusoïdes modulées) sont aussi spécifiées.

On insiste sur le fait que les essais de vibrations requièrent toujours un certain degré d'appréciation technique et il convient que le fournisseur et le client en aient tous deux pleinement conscience. On attend du rédacteur de la spécification particulière qu'il choisisse les modalités d'essai et les valeurs de sévérités adaptées au spécimen et à son utilisation.

Dans le cadre de cet essai, le spécimen est toujours fixé à la table vibrante, directement à l'aide de son support normal de montage, ou par un bâti de fixation.

Afin de faciliter l'utilisation de la présente norme, la partie principale comporte des références renvoyant à l'Annexe A, auxquelles le lecteur est prié de se référer; réciproquement, les numéros d'articles et de paragraphes de la partie principale sont rappelés dans l'Annexe A; ils donnent également des informations spécifiques sur la corrélation entre les sinusoïdes modulées, exprimées en déplacement, vitesse et accélération.

4.2 Exigences relatives à l'essai

Les exigences pour une recherche et l'étude des fréquences critiques sont données en 4.3, celles pour l'essai par accélérogrammes en 4.4, celles pour l'essai par sinusoïdes modulées en 4.5, tandis que 4.6 traite de la fixation pour la réalisation de l'essai. Les tolérances applicables à la recherche et à l'étude des fréquences critiques, et à l'essai par sinusoïdes modulées et par accélérogrammes sont comparées dans le Tableau 1.

Tableau 1 – Comparaison des tolérances

Paramètre	Tolérance	
	Recherche et étude des fréquences critiques	Essai par sinusoïdes modulées et par accélérogrammes
Tolérance sur le signal	5 % du mouvement fondamental (voir 4.3.5.3)	Non applicable
Vibration au point de référence	±15 % du mouvement fondamental (voir 4.3.6 a))	
Vibration aux points de vérification	±25 % de l'accélération, jusqu'à 500 Hz, (voir 4.3.6 b)) ±50 % de l'accélération, au-delà de 500 Hz, (voir 4.3.6 b))	
Mouvement transversal	50 % ou 25 % (pour des cas spéciaux, voir 4.3.3)	25 % (voir 4.4.2)

Paramètre	Tolérance	
	Recherche et étude des fréquences critiques	Essai par sinusoïdes modulées et par accélérogrammes
Fréquence d'essai	(pour des alternatives, voir 4.3.7) $\pm 0,05$ Hz jusqu'à 0,5 Hz ± 10 % de 0,5 Hz à 5 Hz $\pm 0,5$ Hz de 5 Hz à 100 Hz $\pm 0,5$ % au-delà de 100 Hz	a) Prédéterminées (voir 4.5.3.2) $\pm 0,05$ Hz jusqu'à 0,5 Hz ± 10 % de 0,5 Hz à 5 Hz $\pm 0,5$ Hz de 5 Hz à 100 Hz $\pm 0,5$ % au-delà de 100 Hz b) D'investigation (voir 4.5.3.3): ± 2 %

4.3 Recherche et étude des fréquences critiques

4.3.1 Généralités

Lorsque la spécification particulière le spécifie, la recherche et l'étude des fréquences critiques (voir 8.2) doivent être réalisées avec une excitation suivant un seul axe, en se basant sur la CEI 60068-2-6, tout en respectant particulièrement les points traités du 4.3.2 au 4.3.9 ci-dessous, afin de déterminer les fréquences critiques et, lorsqu'on le demande, le taux d'amortissement. Si l'on considère que c'est approprié, ou si cela est spécifié par la spécification particulière, la recherche et l'étude des fréquences critiques peut être effectuée en utilisant des vibrations aléatoires, en se basant sur la CEI 60068-2-64.

4.3.2 Mouvement fondamental

Le mouvement fondamental doit être une fonction sinusoïdale du temps et doit être tel que les points de fixation du spécimen sur la table vibrante, devant être spécifiés par la spécification particulière, se déplacent sensiblement en phase et suivant des directions rectilignes et parallèles, compte tenu des limitations imposées par 4.3.3, 4.3.4 et 4.3.6.

4.3.3 Mouvement transversal

L'amplitude maximale de vibration aux points de vérification, et suivant tout axe perpendiculaire à l'axe spécifié, ne doit pas dépasser 50 % du mouvement fondamental de l'amplitude. Dans des cas particuliers, par exemple, pour les petits spécimens, la valeur de crête du mouvement transversal admissible peut être limitée à 25 % si la spécification particulière l'indique.

A certaines fréquences, ou pour les spécimens volumineux ou lourds, il peut être difficile de respecter ces valeurs (voir aussi A.1.1). Dans de tels cas, la spécification particulière doit préciser quelle exigence suivante s'applique:

- a) tout mouvement transversal dépassant les limites ci-dessus doit être consigné dans le rapport d'essai;
- b) le mouvement transversal ne nécessite pas d'être contrôlé.

4.3.4 Mouvement de rotation

Lorsque les mouvements de rotation parasites de la table vibrante peuvent s'avérer importants, la spécification particulière peut définir un niveau toléré qui doit alors être consigné dans le rapport d'essai.

4.3.5 Points de mesure

4.3.5.1 Point de référence

La spécification particulière doit indiquer si l'on doit faire le pilotage à partir d'un point ou de plusieurs points. S'il est spécifié un pilotage à partir de plusieurs points, la spécification particulière doit indiquer si l'on doit maintenir au niveau de vibration spécifié la valeur moyenne des signaux aux points de vérification, ou la valeur du signal en un point particulier.

4.3.5.2 Point de vérification

A certaines fréquences, ou pour les spécimens volumineux ou lourds, il peut être difficile de respecter les tolérances requises données en 4.3.6 b) (voir aussi A.1.1). Dans ces cas, il faut s'attendre à ce qu'une tolérance plus large ou que l'utilisation d'une autre méthode de détermination soit spécifiée dans les spécifications particulières et qu'elle soit indiquée dans le rapport d'essai.

4.3.5.3 Tolérance sur le signal

La mesure de la tolérance sur le signal doit être effectuée au point de référence et couvrir les fréquences jusqu'à cinq fois la fréquence d'essai.

La tolérance sur le signal, telle que définie au 3.7, ne doit pas dépasser 5 % du mouvement fondamental.

NOTE Parfois, ceci peut être impossible à réaliser; dans ce cas une valeur de tolérance sur le signal supérieure à 5 % est acceptable, si l'amplitude d'essai du signal de pilotage, à la fréquence fondamentale, est rétablie à la valeur spécifiée, par exemple, par l'utilisation d'un filtre de poursuite.

Dans le cas de spécimens complexes ou de grande taille pour lesquels les valeurs de tolérance sur le signal spécifiées ne peuvent pas être respectées en certains points de la gamme de fréquences, et où il n'est guère possible d'utiliser un filtre de poursuite, il n'est pas nécessaire de rétablir l'accélération de l'amplitude; en revanche, la tolérance sur le signal doit être consignée dans le rapport d'essai (voir A.1.1).

La spécification particulière peut exiger que la tolérance sur le signal, soit indiquée dans le rapport d'essai (voir l'Article 13), ainsi que la gamme de fréquences concernée, et qu'un filtre de poursuite ait été ou non utilisé.

4.3.6 Tolérances sur l'amplitude de la vibration

Le mouvement fondamental suivant l'axe requis, aux points de vérification et de référence, doit être égal à la valeur spécifiée avec les tolérances ci-après. Celles-ci comprennent les erreurs dues à l'instrumentation:

a) Point de référence

La tolérance sur le signal de pilotage au point de référence doit être de ± 15 % du mouvement fondamental.

b) Point de vérification

La tolérance en chaque point de vérification: jusqu'à 500 Hz doit être de ± 25 % de l'accélération; au-delà de 500 Hz: ± 50 % de l'accélération, (voir également 4.3.5.2).

4.3.7 Tolérances sur les fréquences

Les tolérances sur les fréquences critiques doivent être les suivantes:

- jusqu'à 0,25 Hz: $\pm 0,05$ Hz;
- de 0,25 Hz à 5 Hz: ± 20 %;
- de 5 Hz à 50 Hz: ± 1 Hz;
- au-delà de 50 Hz: ± 2 %.

Lorsque les fréquences critiques (voir 8.2) sont à comparer avant et après l'essai, il convient que les spécifications concernées précisent les critères de comparaison. Pour déterminer les fréquences critiques, les tolérances de fréquence suivantes s'appliquent:

- jusqu'à 0,5 Hz: $\pm 0,05$ Hz;

- de 0,5 Hz à 5 Hz: ± 10 %;
- de 5 Hz à 100 Hz: $\pm 0,5$ Hz;
- au-delà de 100 Hz: $\pm 0,5$ %.

4.3.8 Balayage

Le balayage doit être continu avec la fréquence variant de façon exponentielle en fonction du temps, à une vitesse ne dépassant pas une octave par minute (voir 3.20).

NOTE Avec les moyens de pilotage numérique, il n'est pas tout à fait correct de définir le balayage comme étant "continu", au sens strict du terme, mais en pratique la différence n'est pas significative.

4.3.9 Taux d'amortissement

Le taux d'amortissement du spécimen est normalement déterminé à partir de la recherche et de l'étude des fréquences critiques. Cette détermination dépend des moyens d'essai utilisés et demande une certaine appréciation technique. Une autre méthode peut être employée, si elle est justifiée dans le rapport d'essai.

4.4 Essai par accélérogrammes

4.4.1 Mouvement fondamental

L'accélérogramme peut être obtenu à partir:

- a) d'un accélérogramme naturel;
- b) d'un accélérogramme synthétique par composition de fréquences comprises dans la gamme spécifiée. Dans ce cas, l'accélérogramme synthétique doit être obtenu avec une finesse d'analyse appropriée, comme indiqué ci-dessous:
 - en bandes de 1/12 d'octave au plus, lorsque l'amortissement du spécimen (= taux d'amortissement) est inférieur ou égal à 2 %;
 - en bandes de 1/6 d'octave au plus, lorsque l'amortissement du spécimen est compris entre 2 % et 10 % (cas général);
 - en bandes de 1/3 d'octave au plus, lorsque l'amortissement du spécimen est supérieur ou égal à 10 %.

La valeur du taux d'amortissement (voir 3.6) peut être définie par la spécification particulière ou obtenue d'une autre manière (voir 4.3.9). Une valeur de 5 % est normalement retenue.

4.4.2 Mouvement transversal

La valeur maximale de crête de l'accélération ou du déplacement aux points de vérification, suivant tout axe perpendiculaire à l'axe spécifié (mouvement fondamental), ne doit pas dépasser 25 % de la valeur de crête spécifiée pour l'accélérogramme ou pour la sinusoïde modulée, sauf indication contraire de la spécification particulière. Il est suffisant que la mesure couvre la gamme de fréquences spécifiée.

A certaines fréquences, ou pour les spécimens volumineux ou lourds, il peut être difficile de respecter ces valeurs (voir aussi A.1.1). Dans de tels cas, la spécification particulière doit préciser laquelle des exigences suivantes s'appliquent:

- a) tout mouvement transversal dépassant les limites ci-dessus doit être consigné dans le rapport d'essai;
- b) le mouvement transversal ne nécessite pas d'être contrôlé.

4.4.3 Mouvement de rotation

Voir 4.3.4 ci-dessus.

4.4.4 Zone de tolérance sur le spectre de réponse spécifié

La zone de tolérance sur le spectre de réponse spécifié doit être comprise entre 0 % et +50 %, comme le montre la Figure 4.

L'essai peut être encore acceptable même si un nombre limité de points du spectre de réponse d'essai est situé en dehors de cette zone de tolérance. Il convient alors de consigner les valeurs de ces points dans le rapport d'essai (voir également les Articles 13 et A.1).

Dans la plage au delà de $1/3 f_2$ (Figure A.1), une zone de tolérance $\square 50$ % est admise.

Le spectre de réponse d'essai doit être contrôlé au moins:

- en bandes de $1/12$ d'octave si l'amortissement du spécimen est inférieur ou égal à 2 %;
- en bandes de $1/6$ d'octave si l'amortissement du spécimen est compris entre 2 % et 10 % (cas général);
- en bandes de $1/3$ d'octave si l'amortissement du spécimen est supérieur ou égal à 10 %.

Dans certains cas, le spectre de réponse spécifié peut avoir été mis en forme ou élargi de façon tellement artificielle que le spectre de réponse d'essai ne peut respecter ces tolérances. Dans ce cas, il peut être nécessaire de réviser les tolérances de la spécification d'essai.

4.4.5 Gamme de fréquences

Le signal issu du point de référence ne doit pas contenir de fréquence supérieure à celles de la gamme de fréquences d'essai, sauf celles qu'induisent les moyens d'essai et le spécimen. La valeur maximale du signal située en dehors de la gamme de fréquences d'essai, induite par les moyens d'essai sans la présence du spécimen, ne doit pas dépasser 20 % de la valeur maximale du signal spécifié issu du point de référence. Si les valeurs ci-dessus ne peuvent être respectées, les valeurs de dépassement obtenues doivent être consignées dans le rapport d'essai.

Les fréquences situées en dehors de la gamme de fréquences ne doivent pas être prises en compte pour la détermination du spectre de réponse d'essai.

4.5 Essai par sinusoïdes modulées

4.5.1 Description générale

Le mouvement fondamental doit être une fonction du temps en sinusoïde modulée et doit être tel que les points de fixation du spécimen sur la table vibrante, devant être spécifiés par la spécification particulière, se déplacent sensiblement en phase et suivant des directions rectilignes et parallèles, compte tenu des limitations imposées par 4.3.1, 4.3.2, 4.3.3 et 4.3.5. L'essai par sinusoïde modulée ne s'applique qu'à une excitation suivant un seul axe (voir le Tableau 1 de la CEI 60068-3-3:1991).

4.5.2 Tolérances sur l'amplitude de la vibration

4.5.2.1 Mouvement fondamental

Le mouvement fondamental suivant l'axe requis, aux points de vérification et de référence, doit être égal à la valeur spécifiée avec les tolérances ci-après. Celles-ci comprennent les erreurs dues à l'instrumentation.

4.5.2.2 Point de référence

Voir 4.3.6 a).

4.5.2.3 Points de vérification

Voir 4.3.6 b).

4.5.3 Tolérances sur les fréquences d'essai

4.5.3.1 Généralités

Les tolérances sur les fréquences d'essai sont les suivantes, pour les deux types:

4.5.3.2 Fréquence d'essai prédéterminée

- jusqu'à 0,5 Hz: $\pm 0,05$ Hz;
- de 0,5 Hz à 5 Hz: ± 10 %;
- de 5 Hz à 100 Hz: $\pm 0,5$ Hz;
- au-delà de 100 Hz: $\pm 0,5$ %.

4.5.3.3 Fréquence d'essai d'investigation

L'écart de la fréquence d'essai par rapport à la fréquence critique, obtenue par la recherche et l'étude des fréquences critiques, ne doit pas dépasser ± 2 %.

4.5.4 Mouvement transversal

Voir 4.4.2 ci-dessus.

4.6 Fixation

Le spécimen doit être monté conformément à la CEI 60068-2-6, où que cette norme fasse référence à la CEI 60068-2-47.

Si un spécimen est normalement monté sur des amortisseurs et qu'il est nécessaire de le soumettre à l'essai sans ceux-ci, le niveau d'excitation spécifié doit être modifié afin d'en tenir compte.

Si un spécimen est soumis à l'essai équipé de son support normal de montage, mais l'excitation spécifié correspond à un essai sans son support normal de montage, le niveau d'excitation spécifié doit être modifié afin d'en tenir compte, voir l'Article A.2 de la CEI 60068-2-47:2005.

L'effet des connexions, câbles, tuyauteries, etc., doit être pris en compte pour la fixation du spécimen.

Il est recommandé d'inclure dans l'essai le dispositif de fixation du spécimen prévu pour les conditions normales de service.

Il convient que le spectre de réponse et que l'accélérogramme utilisés pour l'excitation du support normal de montage soient différents de ceux utilisés pour l'excitation du bâti de fixation ou du spécimen.

L'orientation et la fixation du spécimen pendant l'essai doivent être spécifiées par la spécification particulière et représente le seul cas de figure pour lequel le spécimen est considéré comme satisfaisant aux exigences de la norme, à moins qu'une justification convenable puisse être donnée pour en permettre l'extension à une autre condition non soumise à l'essai (par exemple, s'il est démontré que la pesanteur n'a pas d'effet sur le comportement du spécimen).

5 Sévérités

5.1 Généralités

La sévérité d'essai applicable à l'essai par accélérogrammes est déterminée par la combinaison des paramètres suivants:

- la gamme de fréquences d'essai;
- le spectre de réponse spécifié;
- le nombre et durée des accélérogrammes
- le nombre de cycles de niveau élevé (si applicable).

Pour chaque paramètre, la spécification particulière doit indiquer la valeur appropriée en se basant sur les informations données en 5.2 à 5.5.

La sévérité d'essai applicable à l'essai par sinusoïdes modulées est déterminée par la combinaison des paramètres suivants:

- la gamme de fréquences d'essai;
- l'amplitude d'essai;
- le nombre de cycles dans la sinusoïde modulée;
- le nombre de sinusoïdes modulées.

Pour chaque paramètre, la spécification particulière doit indiquer la valeur appropriée en se basant sur les informations données en 5.6.

5.2 Accélérogramme

Les fréquences d'essai et la gamme de fréquences d'essai sont obtenues de la manière montré au 5.3.

5.3 Gammes de fréquences d'essai

La spécification particulière doit indiquer la gamme de fréquences d'essai en choisissant la fréquence inférieure parmi les fréquences 0,1 Hz, 1 Hz, 5 Hz, 10 Hz, 55 Hz, 100 Hz et la fréquence supérieure parmi les fréquences 10 Hz, 20 Hz, 35 Hz, 55 Hz, 100 Hz, 150 Hz, 300 Hz, 500 Hz, 2 000 Hz. Les gammes recommandées sont données par le Tableau 2.

Tableau 2 – Gammes de fréquences d'essai recommandées

Gammes de fréquences d'essai recommandées de f_1 à f_2 Hz
0,1 to 10 ^a
1 to 35
1 to 100
5 to 35 ^a
10 to 100 ^a
10 to 500
10 to 2 000
55 to 2 000
^a Ces gammes de fréquences ne correspondent pas à celles recommandées par la CEI 60068-2-6.

5.4 Spectre de réponse spécifié

La spécification particulière doit indiquer l'amplitude et la forme des spectres de réponse spécifiés utilisés pour l'essai, y compris la valeur de l'accélération à période nulle. Elle doit également indiquer les axes du spécimen auxquels ces spectres s'appliquent lorsqu'ils ne sont pas identiques pour chacun d'eux.

Lorsque les conditions d'environnement ne sont pas bien connues, on peut s'aider de l'A.1.3 pour définir le spectre de réponse spécifié.

5.5 Nombre et durée des accélérogrammes

5.5.1 Nombre d'accélérogrammes

La spécification particulière doit indiquer le nombre d'accélérogrammes à appliquer au spécimen selon les axes concernés.

Sauf spécification contraire, le nombre d'accélérogrammes à appliquer par axe d'essai et pour chaque niveau doit être choisi dans la série suivante: ... 1, 2, 5, 10, 20, 50.

Lorsque plusieurs niveaux d'accélérogrammes sont définis, on doit toujours commencer l'essai par le niveau le plus faible et on continue avec les niveaux croissants. Chaque accélérogramme doit être suivi d'une pause.

5.5.2 Durée de l'accélérogramme

La spécification particulière doit indiquer la durée de chaque accélérogramme; les valeurs recommandées, en secondes, sont choisies dans la série suivante: ... 1, 2, 5, 10, 20, 50.

Si la période du spécimen d'essai est connue ou peut être calculée, la durée de chaque accélérogramme ne doit pas être inférieure à 3 ou 5 fois cette période.

On peut utiliser une période de 3 s, si cela est spécifié par la spécification particulière.

NOTE 2 La durée typique d'un séisme est de 30 s.

5.5.3 Durée de la partie forte de l'accélérogramme

Dans certains cas, la spécification particulière peut exiger que la partie forte de l'accélérogramme soit un pourcentage donné de la durée totale. Dans les autres cas, la durée relative à cette partie forte doit être choisie parmi les valeurs suivantes, sauf lorsque les exigences du 5.6 s'appliquent:

25 %, 50 %, 75 %.

La valeur choisie doit être consignée dans le rapport d'essai.

5.5.4 Nombre de cycles de réponse de niveau élevé


La spécification particulière peut indiquer une valeur spécifiée et le nombre de cycles de réponse de niveau élevé conduisant à des réponses supérieures à une valeur spécifiée (voir A.1.4).

Sauf avis contraire de la spécification particulière, le nombre de cycles de réponse de niveau élevé doit être choisi parmi la série suivante: ... 4, 8, 16, 32. Les cycles positifs et négatifs en alternance doivent être à peu près régulièrement répartis comme indiqué à la Figure 5.

Il convient que la valeur de l'accélération de ces cycles de réponse de niveau élevé soit exprimée en pourcentage de la valeur crête de la valeur du spectre de réponse spécifié aux

fréquences critiques particulières, situées dans la partie forte du spectre de réponse spécifié (SRS). La valeur spécifiée de l'accélération doit être choisie parmi les valeurs suivantes:

Valeur spécifiée (en % du SRS) 50 %, 70 % (préférentiel), 90 %



IEC 911/13

Figure 5 – Réponse type d'un oscillateur excité selon un accélérogramme spécifique lors d'un essai

5.6 Amplitude d'essai en sinusoïdes modulées

5.6.1 Généralités

Pour chaque axe, la spécification particulière doit indiquer la valeur de l'amplitude d'essai (en déplacement, en vitesse ou en accélération ou les trois) (voir également A.2.1).

Au-dessous de la fréquence de transfert, toutes les valeurs de crête sont spécifiées à déplacement constant et, au-dessus de cette fréquence, elles sont spécifiées à accélération constante. Les valeurs recommandées sont données dans les Tableaux 3, 4 et 5 et par les Figures 6, 7 et 8 pour les différentes fréquences de transfert choisies.

Tableau 3 – Amplitudes d'essai recommandées pour une fréquence de transfert de 0,8 Hz (voir la Figure 6)

Amplitude du déplacement au-dessous de la fréquence de transfert mm	Amplitude de l'accélération au-dessus de la fréquence de transfert m/s ²
40	1
80	2
120	3
200	5

NOTE 1 Toutes les valeurs indiquées représentent des valeurs de crête de la sinusoïde modulée.

NOTE 2 Dans le cadre de la présente norme, à l'attention de ceux souhaitant continuer à exprimer les valeurs d'accélération en "g_n", la valeur conventionnelle de 10 m/s² lui est attribuée (voir 3.9).




Figure 6 – Amplitude d'essai recommandée pour une fréquence de transfert de 0,8 Hz

Tableau 4 – Amplitudes d'essai recommandées pour une fréquence de transfert de 1,6 Hz (voir la Figure 7)

Amplitude du déplacement au-dessous de la fréquence de transfert mm	Amplitude de l'accélération au-dessus de la fréquence de transfert m/s ²
10	1
20	2
30	3
50	5
100	10
200	20

NOTE 1 Toutes les valeurs indiquées représentent des valeurs de crête de la sinusoïde modulée.

NOTE 2 Dans le cadre de la présente norme, à l'attention de ceux souhaitant continuer à exprimer les valeurs d'accélération en " g_n ", la valeur conventionnelle de 10 m/s² lui est attribuée (voir 3.9).

IECNORM.COM : Click to view the full PDF of IEC 60068-2-57:2013




Figure 7 – Amplitude d'essai recommandée pour une fréquence de transfert de 1,6 Hz