

# INTERNATIONAL STANDARD

## NORME INTERNATIONALE

**Surge arresters –**

**Part 6: Surge arresters containing both series and parallel gapped structures –  
System voltage of 52 kV and less**

**Parafoudres –**

**Partie 6: Parafoudres contenant des structures à éclateurs en série et en  
parallèle – Tension de réseau inférieure ou égale à 52 kV**



## THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2019 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'IEC ou du Comité national de l'IEC du pays du demandeur. Si vous avez des questions sur le copyright de l'IEC ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de l'IEC de votre pays de résidence.

IEC Central Office  
3, rue de Varembe  
CH-1211 Geneva 20  
Switzerland

Tel.: +41 22 919 02 11  
[info@iec.ch](mailto:info@iec.ch)  
[www.iec.ch](http://www.iec.ch)

### About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

### About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

#### IEC publications search - [webstore.iec.ch/advsearchform](http://webstore.iec.ch/advsearchform)

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, replaced and withdrawn publications.

#### IEC Just Published - [webstore.iec.ch/justpublished](http://webstore.iec.ch/justpublished)

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

#### IEC Customer Service Centre - [webstore.iec.ch/csc](http://webstore.iec.ch/csc)

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: [sales@iec.ch](mailto:sales@iec.ch).

#### Electropedia - [www.electropedia.org](http://www.electropedia.org)

The world's leading online dictionary on electrotechnology, containing more than 22 000 terminological entries in English and French, with equivalent terms in 16 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

#### IEC Glossary - [std.iec.ch/glossary](http://std.iec.ch/glossary)

67 000 electrotechnical terminology entries in English and French extracted from the Terms and Definitions clause of IEC publications issued since 2002. Some entries have been collected from earlier publications of IEC TC 37, 77, 86 and CISPR.

### A propos de l'IEC

La Commission Electrotechnique Internationale (IEC) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

### A propos des publications IEC

Le contenu technique des publications IEC est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

#### Recherche de publications IEC -

[webstore.iec.ch/advsearchform](http://webstore.iec.ch/advsearchform)

La recherche avancée permet de trouver des publications IEC en utilisant différents critères (numéro de référence, texte, comité d'études,...). Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

#### IEC Just Published - [webstore.iec.ch/justpublished](http://webstore.iec.ch/justpublished)

Restez informé sur les nouvelles publications IEC. Just Published détaille les nouvelles publications parues. Disponible en ligne et une fois par mois par email.

#### Service Clients - [webstore.iec.ch/csc](http://webstore.iec.ch/csc)

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: [sales@iec.ch](mailto:sales@iec.ch).

**Electropedia** - [www.electropedia.org](http://www.electropedia.org)

Le premier dictionnaire d'électrotechnologie en ligne au monde, avec plus de 22 000 articles terminologiques en anglais et en français, ainsi que les termes équivalents dans 16 langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (IEV) en ligne.

#### Glossaire IEC - [std.iec.ch/glossary](http://std.iec.ch/glossary)

67 000 entrées terminologiques électrotechniques, en anglais et en français, extraites des articles Termes et Définitions des publications IEC parues depuis 2002. Plus certaines entrées antérieures extraites des publications des CE 37, 77, 86 et CISPR de l'IEC.

# INTERNATIONAL STANDARD

## NORME INTERNATIONALE

---

### Surge arresters –

**Part 6: Surge arresters containing both series and parallel gapped structures –  
System voltage of 52 kV and less**

### Parafoudres –

**Partie 6: Parafoudres contenant des structures à éclateurs en série et en  
parallèle – Tension de réseau inférieure ou égale à 52 kV**

INTERNATIONAL  
ELECTROTECHNICAL  
COMMISSION

COMMISSION  
ELECTROTECHNIQUE  
INTERNATIONALE

ICS 29.240.10

ISBN 978-2-8322-6919-0

**Warning! Make sure that you obtained this publication from an authorized distributor.  
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

## CONTENTS

|                                                                                            |    |
|--------------------------------------------------------------------------------------------|----|
| FOREWORD.....                                                                              | 7  |
| INTRODUCTION.....                                                                          | 9  |
| 1 Scope.....                                                                               | 10 |
| 2 Normative references .....                                                               | 10 |
| 3 Terms and definitions .....                                                              | 11 |
| 4 Identification and classification .....                                                  | 18 |
| 4.1 Arrester identification.....                                                           | 18 |
| 4.2 Arrester classification .....                                                          | 18 |
| 5 Standard ratings and service conditions .....                                            | 19 |
| 5.1 Standard rated voltages.....                                                           | 19 |
| 5.2 Standard rated frequencies.....                                                        | 19 |
| 5.3 Standard nominal discharge currents .....                                              | 19 |
| 5.4 Service conditions.....                                                                | 19 |
| 5.4.1 Normal service conditions.....                                                       | 19 |
| 5.4.2 Special environmental conditions.....                                                | 20 |
| 6 Requirements .....                                                                       | 20 |
| 6.1 Insulation withstand .....                                                             | 20 |
| 6.2 Residual voltages .....                                                                | 20 |
| 6.3 Impulse protective levels.....                                                         | 20 |
| 6.4 Internal partial discharges.....                                                       | 20 |
| 6.5 Seal leak rate .....                                                                   | 21 |
| 6.6 Thermal stability .....                                                                | 21 |
| 6.7 Heat dissipation behaviour of test sample .....                                        | 21 |
| 6.8 Repetitive charge transfer withstand .....                                             | 21 |
| 6.9 Operating duty .....                                                                   | 21 |
| 6.10 Power-frequency voltage versus time characteristics of an arrester .....              | 21 |
| 6.11 Short-circuit performance.....                                                        | 22 |
| 6.12 Disconnectors.....                                                                    | 22 |
| 6.12.1 Disconnector withstand.....                                                         | 22 |
| 6.12.2 Disconnector operation.....                                                         | 22 |
| 6.13 Requirements on internal grading components.....                                      | 22 |
| 6.14 Power-frequency sparkover .....                                                       | 22 |
| 6.15 Mechanical loads .....                                                                | 22 |
| 6.15.1 General .....                                                                       | 22 |
| 6.15.2 Bending moment.....                                                                 | 22 |
| 6.15.3 Resistance against environmental stresses .....                                     | 23 |
| 6.15.4 Insulating base and mounting bracket.....                                           | 23 |
| 6.15.5 Mean value of breaking load (MBL) .....                                             | 23 |
| 6.16 Electromagnetic compatibility.....                                                    | 23 |
| 6.17 End of life .....                                                                     | 23 |
| 7 General testing procedures.....                                                          | 23 |
| 7.1 Measuring equipment and accuracy .....                                                 | 23 |
| 7.2 Test samples .....                                                                     | 23 |
| 7.2.1 General .....                                                                        | 23 |
| 7.2.2 Samples for residual voltage tests .....                                             | 24 |
| 7.2.3 Samples for the test to verify the repetitive charge transfer rating, $Q_{RS}$ ..... | 24 |

|        |                                                                |    |
|--------|----------------------------------------------------------------|----|
| 8      | Type tests (design tests)                                      | 24 |
| 8.1    | General                                                        | 24 |
| 8.2    | Insulation withstand tests                                     | 25 |
| 8.2.1  | General                                                        | 25 |
| 8.2.2  | Tests on individual unit housing                               | 26 |
| 8.2.3  | Ambient air conditions during tests                            | 26 |
| 8.2.4  | Wet test procedure                                             | 26 |
| 8.2.5  | Lightning impulse voltage test                                 | 26 |
| 8.2.6  | Power- frequency voltage test                                  | 26 |
| 8.3    | Impulse protective level tests                                 | 27 |
| 8.3.1  | General                                                        | 27 |
| 8.3.2  | Residual voltage tests                                         | 27 |
| 8.3.3  | Sparkover tests                                                | 28 |
| 8.4    | Test to verify the repetitive charge transfer rating, $Q_{rs}$ | 30 |
| 8.4.1  | General                                                        | 30 |
| 8.4.2  | MO resistors                                                   | 30 |
| 8.4.3  | Series gaps                                                    | 31 |
| 8.5    | Operating duty tests                                           | 32 |
| 8.5.1  | General                                                        | 32 |
| 8.5.2  | Test procedure                                                 | 33 |
| 8.5.3  | Rated thermal charge values, $Q_{th}$                          | 35 |
| 8.6    | Power-frequency voltage-versus-time test                       | 35 |
| 8.6.1  | General                                                        | 35 |
| 8.6.2  | Test samples                                                   | 36 |
| 8.6.3  | Initial measurements                                           | 36 |
| 8.6.4  | Test procedure                                                 | 36 |
| 8.6.5  | Test evaluation                                                | 37 |
| 8.7    | Tests of arrester disconnectors                                | 38 |
| 8.7.1  | General                                                        | 38 |
| 8.7.2  | Operating withstand test                                       | 38 |
| 8.7.3  | Disconnector operation                                         | 39 |
| 8.7.4  | Mechanical tests                                               | 40 |
| 8.7.5  | Temperature cycling and seal pumping test                      | 40 |
| 8.8    | Power-frequency voltage sparkover tests                        | 40 |
| 8.9    | Short-circuit tests                                            | 41 |
| 8.9.1  | General                                                        | 41 |
| 8.9.2  | Preparation of the test samples                                | 41 |
| 8.9.3  | Mounting of the test sample                                    | 45 |
| 8.9.4  | High-current short-circuit tests                               | 46 |
| 8.9.5  | Low-current short-circuit test                                 | 48 |
| 8.9.6  | Evaluation of test results                                     | 48 |
| 8.10   | Test of the bending moment                                     | 49 |
| 8.10.1 | General                                                        | 49 |
| 8.10.2 | Overview                                                       | 49 |
| 8.10.3 | Sample preparation                                             | 49 |
| 8.10.4 | Test procedure                                                 | 49 |
| 8.10.5 | Test evaluation                                                | 50 |
| 8.10.6 | Test on insulating base and mounting bracket                   | 50 |

|         |                                                                             |    |
|---------|-----------------------------------------------------------------------------|----|
| 8.11    | Environmental tests .....                                                   | 50 |
| 8.11.1  | General .....                                                               | 50 |
| 8.11.2  | Sample preparation .....                                                    | 51 |
| 8.11.3  | Test procedure .....                                                        | 51 |
| 8.11.4  | Test evaluation .....                                                       | 51 |
| 8.12    | Seal leak rate test .....                                                   | 51 |
| 8.12.1  | General .....                                                               | 51 |
| 8.12.2  | Sample preparation .....                                                    | 51 |
| 8.12.3  | Test procedure .....                                                        | 51 |
| 8.12.4  | Test evaluation .....                                                       | 52 |
| 8.13    | Test to verify the dielectric withstand of internal components .....        | 52 |
| 8.13.1  | General .....                                                               | 52 |
| 8.13.2  | Test procedure .....                                                        | 52 |
| 8.13.3  | Test evaluation .....                                                       | 52 |
| 8.14    | Test of internal grading components .....                                   | 52 |
| 8.14.1  | Test to verify long term stability under continuous operating voltage ..... | 52 |
| 8.14.2  | Thermal cyclic test .....                                                   | 53 |
| 9       | Routine tests and acceptance tests .....                                    | 54 |
| 9.1     | Routine tests .....                                                         | 54 |
| 9.2     | Acceptance tests .....                                                      | 55 |
| 9.2.1   | Standard acceptance tests .....                                             | 55 |
| 9.2.2   | Special thermal stability test .....                                        | 55 |
| 10      | Test requirements on polymer-housed surge arresters .....                   | 55 |
| 10.1    | Scope .....                                                                 | 55 |
| 10.2    | Normative references .....                                                  | 56 |
| 10.3    | Terms and definitions .....                                                 | 56 |
| 10.4    | Identification and classification .....                                     | 56 |
| 10.5    | Standard ratings and service conditions .....                               | 56 |
| 10.6    | Requirements .....                                                          | 56 |
| 10.7    | General testing procedure .....                                             | 56 |
| 10.8    | Type tests (design tests) .....                                             | 57 |
| 10.8.1  | General .....                                                               | 57 |
| 10.8.2  | Insulation withstand tests .....                                            | 57 |
| 10.8.3  | Impulse protective level tests .....                                        | 57 |
| 10.8.4  | Test to verify the repetitive charge transfer rating, $Q_{rs}$ .....        | 57 |
| 10.8.5  | Operating Duty tests .....                                                  | 57 |
| 10.8.6  | Power frequency voltage-versus-time test .....                              | 57 |
| 10.8.7  | Tests of arrester disconnectors .....                                       | 58 |
| 10.8.8  | Power frequency voltage sparkover tests .....                               | 58 |
| 10.8.9  | Short-circuit tests .....                                                   | 58 |
| 10.8.10 | Test of the bending moment .....                                            | 63 |
| 10.8.11 | Environmental tests .....                                                   | 69 |
| 10.8.12 | Seal leak rate test .....                                                   | 69 |
| 10.8.13 | Test to verify the dielectric withstand of internal components .....        | 69 |
| 10.8.14 | Test of internal grading components .....                                   | 69 |
| 10.8.15 | Weather ageing test .....                                                   | 69 |
| 10.9    | Routine tests .....                                                         | 71 |

|                                                                                                                                            |    |
|--------------------------------------------------------------------------------------------------------------------------------------------|----|
| Annex A (normative) Special Environmental Conditions .....                                                                                 | 72 |
| Annex B (normative) Typical information given with enquiries and tenders .....                                                             | 73 |
| B.1 Information given with enquiry .....                                                                                                   | 73 |
| B.1.1 System data .....                                                                                                                    | 73 |
| B.1.2 Service conditions .....                                                                                                             | 73 |
| B.1.3 Arrester duty .....                                                                                                                  | 73 |
| B.1.4 Characteristics of arrester .....                                                                                                    | 74 |
| B.1.5 Additional equipment and fittings .....                                                                                              | 74 |
| B.1.6 Any special abnormal conditions .....                                                                                                | 74 |
| B.2 Information given with tender .....                                                                                                    | 74 |
| Annex C (normative) Mechanical considerations .....                                                                                        | 76 |
| C.1 Test of bending moment .....                                                                                                           | 76 |
| C.2 Definition of mechanical loads .....                                                                                                   | 77 |
| C.3 Definition of seal leak rate .....                                                                                                     | 77 |
| C.4 Calculation of wind-bending-moment .....                                                                                               | 78 |
| C.5 Procedures of tests of bending moment for porcelain/cast resin and polymer-housed arresters .....                                      | 79 |
| Figure 1 – procedure to verify the repetitive charge transfer rating, $Q_{rs}$ , for MO resistors .....                                    | 30 |
| Figure 2 – Procedure to verify the repetitive charge transfer rating, $Q_{rs}$ , for series gaps .....                                     | 32 |
| Figure 3 – Test procedure to verify the thermal charge transfer rating, $Q_{th}$ .....                                                     | 33 |
| Figure 4 – Test procedure to verify the power frequency versus time characteristic (TOV test) .....                                        | 36 |
| Figure 5 – Examples of arrester units .....                                                                                                | 44 |
| Figure 6 – Examples of fuse wire locations for “Design A” arresters .....                                                                  | 45 |
| Figure 7 – Examples of fuse wire locations for “Design B” arresters .....                                                                  | 45 |
| Figure 8 – Short-circuit test setup for porcelain-housed arresters .....                                                                   | 46 |
| Figure 9 – Short-circuit test setup for polymer-housed arresters .....                                                                     | 61 |
| Figure 10 – Example of a test circuit for re-applying pre-failing circuit immediately before applying the short-circuit test current ..... | 63 |
| Figure 11 – Thermomechanical test .....                                                                                                    | 66 |
| Figure 12 – Example of the test arrangement for the thermomechanical test and direction of the cantilever load .....                       | 67 |
| Figure 13 – Water immersion .....                                                                                                          | 68 |
| Figure C.1 – Bending moment – multi-unit surge arrester .....                                                                              | 76 |
| Figure C.2 – Definition of mechanical loads .....                                                                                          | 77 |
| Figure C.3 – Surge arrester unit .....                                                                                                     | 78 |
| Figure C.4 – Surge-arrester dimensions .....                                                                                               | 79 |
| Figure C.5 – Flow chart of bending moment test procedures .....                                                                            | 80 |

|                                                                          |    |
|--------------------------------------------------------------------------|----|
| Table 1 – Arrester classification .....                                  | 19 |
| Table 2 – Steps of rated voltages.....                                   | 19 |
| Table 3 – Arrester type tests .....                                      | 25 |
| Table 4 – Requirements for high current impulses .....                   | 34 |
| Table 5 – Rated values of thermal charge transfer rating, $Q_{th}$ ..... | 35 |
| Table 6 – Test requirements for porcelain housed arresters.....          | 43 |
| Table 7 – Required currents for short-circuit tests .....                | 47 |
| Table 8 – Test requirements for polymer-housed arresters .....           | 60 |

IECNORM.COM : Click to view the full PDF of IEC 60099-6:2019



## INTERNATIONAL ELECTROTECHNICAL COMMISSION

## SURGE ARRESTERS –

**Part 6: Surge arresters containing both series and parallel gapped structures – System voltage of 52 kV and less**

## FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 60099-6 has been prepared by IEC technical committee 37: Surge arresters.

This second edition cancels and replaces the first edition published in 2002. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) A new concept of arrester classification and energy withstand testing was introduced: the line discharge classification was replaced by a classification based on repetitive charge transfer rating ( $Q_{rs}$ ) and thermal charge transfer rating ( $Q_{th}$ ). The new concept clearly differentiates between impulse and thermal energy handling capability, which is reflected in the requirements as well as in the related test procedures.

- b) Power-frequency voltage versus time tests – with and without prior duty – were introduced as type tests.
- c) Requirements and tests on disconnectors were added.
- d) Definitions for new terms have been added.
- e) Clause 10 contains particular requirements for polymer-housed surge arresters. These are indicated in the form of replacements, additions or amendments to the original clauses or subclauses concerned.

The text of this International Standard is based on the following documents:

| FDIS        | Report on voting |
|-------------|------------------|
| 37/450/FDIS | 37/451/RVD       |

Full information on the voting for the approval of this International Standard can be found in the report on voting indicated in the above table.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts in the IEC 60099 series, published under the general title *Surge arresters*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IECNORM.COM : Click to view the full PDF of IEC 60099-6:2019

## INTRODUCTION

This part of IEC 60099 presents the minimum criteria for the requirements and testing of metal-oxide surge arresters containing gapped structures that are applied to AC power systems with  $U_s$  above 1 kV up to and including 52kV.

Arresters covered by this document can be applied to overhead installations in place of the non-linear type arresters covered in IEC 60099-4.

An accelerated ageing procedure is incorporated in this document to simulate the long-term effects of voltage and temperature on the arrester. This is necessary since during the arrester's service life the gaps and resistor elements will have portions of the system power frequency voltage continuously applied across them.

IECNORM.COM : Click to view the full PDF of IEC 60099-6:2019

## **SURGE ARRESTERS –**

### **Part 6: Surge arresters containing both series and parallel gapped structures – System voltage of 52 kV and less**

#### **1 Scope**

This part of IEC 60099 applies to non-linear metal-oxide resistor type surge arresters with spark gaps designed to limit voltage surges on AC power circuits with system voltages  $U_s$  above 1 kV up to and including 52 kV. This document basically applies to all metal-oxide distribution class surge arresters with internal series and/or parallel gaps and housed in either porcelain or polymeric housings.

#### **2 Normative references**

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60060-1, *High-voltage test techniques – Part 1: General definitions and test requirements*

IEC 60060-2, *High-voltage test techniques – Part 2: Measuring systems*

IEC 60068-2-11:1981, *Basic environmental testing procedures – Part 2-11: Tests – Test Ka: Salt mist*

IEC 60068-2-14, *Environmental testing – Part 2-14: Tests – Test N: Change of temperature*

IEC 60071-2:2018, *Insulation co-ordination – Part 2: Application guidelines*

IEC 60270, *High-voltage test techniques – Partial discharge measurements*

IEC TS 60815-2, *Selection and dimensioning of high-voltage insulators intended for use in polluted conditions – Part 2: Ceramic and glass insulators for a.c. systems*

IEC 62217, *Polymeric HV insulators for indoor and outdoor use – General definitions, test methods and acceptance criteria*

ISO 4287, *Geometrical Product Specifications (GPS) – Surface texture: Profile method – Terms, definitions and surface texture parameters*

ISO 4892-1, *Plastics – Methods of exposure to laboratory light sources – Part 1: General guidance*

ISO 4892-2, *Plastics – Methods of exposure to laboratory light sources – Part 2: Xenon-arc lamps*

ISO 4892-3, *Plastics – Methods of exposure to laboratory light sources – Part 3: Fluorescent UV lamps*

### 3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <http://www.electropedia.org/>
- ISO Online browsing platform: available at <http://www.iso.org/obp>

#### 3.1

##### **acceptance test**

test made on arresters or representative samples after agreement between manufacturer and user

#### 3.2

##### **arrester disconnecter**

device for disconnecting an arrester from the system in the event of arrester failure, to prevent a persistent fault on the system and to give visible indication of the failed arrester

Note 1 to entry: Clearing of the fault current through the arrester during disconnection generally is not a function of the device.

#### 3.3

##### **bending moment**

force perpendicular to the longitudinal axis of an arrester multiplied by the vertical distance between the mounting base (lower level of the flange) of the arrester and the point of application of the force

#### 3.4

##### **breaking load**

force perpendicular to the longitudinal axis of a porcelain-housed or cast resin arrester leading to mechanical failure of the arrester housing

#### 3.5

##### **cast resin housed arrester**

arrester using a housing made from only one organic based material (e.g. cycloaliphatic epoxy) that fractures similarly to a porcelain housing under mechanical overstress

#### 3.6

##### **continuous current of an arrester**

current flowing through the arrester when energized at the continuous operating voltage

#### 3.7

##### **continuous operating voltage of an arrester**

$U_c$

designated permissible RMS value of power-frequency voltage that may be applied continuously between the arrester terminals in accordance with 8.5

#### 3.8

##### **damage limit**

<mechanical>

lowest value of a force perpendicular to the longitudinal axis of a polymer-housed arrester leading to mechanical failure of the arrester housing

### 3.9

#### **designation of an impulse shape**

combination of two numbers, the first representing the virtual front time ( $T_1$ ) and the second the virtual time to half-value on the tail ( $T_2$ )

Note 1 to entry: This is written as  $T_1/T_2$ , both in microseconds, the sign "/" having no mathematical meaning.

### 3.10

#### **discharge current of an arrester**

impulse current which flows through the arrester

### 3.11

#### **disruptive discharge**

phenomenon associated with the failure of insulation under electric stress, which includes a collapse of voltage and the passage of current

Note 1 to entry: The term applies to electrical breakdowns in solid, liquid and gaseous dielectric, and combinations of these.

Note 2 to entry: A disruptive discharge in a solid dielectric produces permanent loss of electric strength. In a liquid or gaseous dielectric the loss may be only temporary.

### 3.12

#### **distribution class arrester**

arrester intended for use on distribution systems, typically of  $U_s \leq 52$  kV, to protect components primarily from the effects of lightning

Note 1 to entry: Distribution class arresters may have nominal discharge currents,  $I_n$ , of 2,5 kA; 5 kA or 10 kA.

Note 2 to entry: Distribution arresters are classified as "Distribution DH", "Distribution DM" and "Distribution DL" (see Table 1).

### 3.13

#### **electrical unit**

portion of an arrester in which each end of the unit is terminated with an electrode which is exposed to the external environment

### 3.14

#### **fault indicator**

device intended to provide an indication that the arrester is faulty and which does not disconnect the arrester from the system

### 3.15

#### **flashover**

disruptive discharge over a solid surface

### 3.16

#### **follow current**

current from the connected power source that flows through an arrester during and following the passage of discharge current

### 3.17

#### **front of an impulse**

part of an impulse which occurs prior to the peak

### 3.18

#### **high current impulse**

<of an arrester> peak value of discharge current having a 4/10 impulse shape which is used to test the stability of the arrester on direct lightning strokes

**3.19****housing**

external insulating part of an arrester, which provides the necessary creepage distance and protects the internal parts from the environment

Note 1 to entry: A housing may consist of several parts providing mechanical strength and protection against the environment.

**3.20****impulse**

unidirectional wave of voltage or current which, without appreciable oscillations, rises rapidly to a maximum value and falls, usually less rapidly, to zero with small, if any, excursions of opposite polarity, with defining parameters being polarity, peak value, front time and time to half-value

**3.21****insulating base**

a short insulator (or set of insulators) on which the arrester is mounted to provide a means of connecting a current monitoring device between the base of the arrester and earth

**3.22****internal grading components of an internally gapped arrester**

grading impedances, connected in parallel with the internal gap(s), to control the voltage across the gap section

**3.23****internal parts**

MO resistor with supporting structure and internal grading system, if equipped

**3.24****lightning current impulse**

8/20 current impulse with limits on the adjustment of equipment such that the measured values are from 7  $\mu$ s to 9  $\mu$ s for the virtual front time and from 18  $\mu$ s to 22  $\mu$ s for the time to half-value

Note 1 to entry: The time to half-value is not critical and may have any tolerance during the residual voltage type tests (see 8.3.2.3).

**3.25****lightning impulse discharge**

an approximately sine half-wave current impulse having a time duration within 200  $\mu$ s to 230  $\mu$ s during which the instantaneous value of the impulse current is greater than 5 % of its peak value

**3.26****lightning impulse protection level**

**LIPL or  $U_{pl}$**

the maximum residual voltage of the arrester for the nominal discharge current

**3.27****long-duration current impulse**

rectangular current impulse which rises rapidly to maximum value, remains substantially constant for a specified period and then falls rapidly to zero, with defining parameters being polarity, peak value, virtual duration of the peak and virtual total duration.

**3.28****mean breaking load**

**MBL**

the average breaking load for porcelain or cast resin-housed arresters determined from tests

### 3.29

#### **mechanical unit**

portion of an arrester in which the MO resistors within the unit are mechanically restrained from moving in an axial direction

Note 1 to entry: An arrester may contain more than one mechanical units within an electrical unit (see Figure 5).

Note 2 to entry: A mechanical unit may have more than one electrical unit (see Figure 5).

### 3.30

#### **mounting bracket**

means by which a distribution class arrester is physically attached to a pole or other structure

Note 1 to entry: For polymer housed distribution class arresters, the mounting bracket is typically of an insulating material and is typically attached to the bottom (ground) end of the arrester; for porcelain-housed distribution class arresters, the bracket is typically metal (often steel) and is connected by a "belly band" around the porcelain housing at some distance from the ground end of the arrester.

### 3.31

$I_n$

#### **nominal discharge current of an arrester**

peak value of lightning current impulse, which is used to classify an arrester

### 3.32

#### **MO resistor**

part of the surge arrester which, by its non-linear voltage versus current characteristics, acts as a low resistance to overvoltages, thus limiting the voltage across the arrester terminals, and as a high resistance at normal power-frequency voltage

### 3.33

#### **peak value of an impulse**

#### **crest value of an impulse**

maximum value of a voltage or current impulse

Note 1 to entry: Superimposed oscillations may be disregarded.

### 3.34

#### **peak value of opposite polarity of an impulse**

#### **crest value of opposite polarity of an impulse**

maximum amplitude of opposite polarity reached by a voltage or current impulse when it oscillates about zero before attaining a permanent zero value

### 3.35

#### **polymer-housed surge arrester**

arrester using polymeric and composite materials for housing

Note 1 to entry: Designs with an enclosed gas volume are possible. Sealing may be accomplished by use of the polymeric material itself or by a separate sealing system.

### 3.36

#### **porcelain-housed surge arrester**

arrester using porcelain as housing material, with fittings and sealing systems

### 3.37

#### **power-frequency voltage versus time characteristic**

<of an arrester> maximum time durations for which corresponding power-frequency voltages may be applied to arresters without causing damage or thermal instability, under specified conditions in accordance with 6.10



**3.38****pressure-relief device**

<of an arrester> means for relieving internal pressure in an arrester and preventing violent shattering of the housing following prolonged passage of fault current or internal flashover of the arrester

**3.39****prospective current**

<of a circuit> current that would flow at a given location in a circuit if it were short-circuited at that location by a link of negligible impedance

**3.40****protective characteristics**

<of an arrester> combination of lightning impulse protection level (LIPL), switching impulse protection level (SIPL) and steep current impulse protection level (STIPL)

**3.41****puncture**

breakdown

disruptive discharge through a solid

**3.42****rated frequency of an arrester**

frequency of the power system on which the arrester is designed to be used

**3.43**

$I_s$

**rated short-circuit current**

highest tested power-frequency current that may develop in a failed arrester as a short-circuit current without causing violent shattering of the housing or any open flames for more than two minutes under the specified test conditions

**3.44**

$U_r$

**rated voltage of an arrester**

maximum permissible 10 s power frequency RMS overvoltage that can be applied between the arrester, as verified in the TOV test and the operating duty test

Note 1 to entry: The rated voltage is used as a reference parameter for the specification of operating characteristics.

**3.45****repetitive charge transfer rating**

$Q_{rs}$

maximum specified charge transfer capability of an arrester, in the form of a single event or group of surges that may be transferred through an arrester without causing mechanical failure or unacceptable electrical degradation to the MO resistors

Note 1 to entry: The charge is calculated as the absolute value of current integrated over time. For the purpose of this document this is the charge that is accumulated in a single event or group of surges lasting for not more than 2 s and which may be followed by a subsequent event at a time interval not shorter than 60 s.

**3.46**

$U_{res}$

**residual voltage of an arrester**

peak value of voltage that appears between the terminals of an arrester during the passage of discharge current

Note 1 to entry: The term "discharge voltage" is used in some countries.

### 3.47

#### **routine tests**

tests made on each arrester, or on parts and materials, as required, to ensure that the product meets the design specifications

### 3.48

#### **seal**

<gas/water tightness>

ability of an arrester to avoid ingress of matter affecting the electrical and/or mechanical behaviour

### 3.49

#### **series gap**

intentional gap(s) between spaced electrodes, in series with the valve element of the arrester, substantially isolating the element from line or ground, or both, under normal line-voltage conditions

### 3.50

#### **section of an arrester**

<prorated section>

complete, suitably assembled part of an arrester necessary to represent the behaviour of a complete arrester with respect to a particular test

Note 1 to entry: A section of an arrester is not necessarily a unit of an arrester. For certain tests, a MO resistor alone constitutes a section.

### 3.51

#### **shed**

insulating part projecting from the housing, intended to increase the creepage distance

### 3.52

#### **specified long-term load**

##### **SLL**

force perpendicular to the longitudinal axis of an arrester, allowed to be continuously applied during service without causing any mechanical damage to the arrester

### 3.53

#### **specified short-term load**

##### **SSL**

greatest force perpendicular to the longitudinal axis of an arrester, allowed to be applied during service for short periods and for relatively rare events (for example, short-circuit current loads and extreme wind gusts) without causing any mechanical damage to the arrester

Note 1 to entry: SSL does not relate to mechanical strength requirements for seismic loads. See C.2.

### 3.54

#### **steep current impulse**

current impulse with a virtual front time of 1  $\mu\text{s}$  with limits in the adjustment of equipment such that the measured values are from 0,9  $\mu\text{s}$  to 1,1  $\mu\text{s}$  and the virtual time to half-value on the tail is not longer than 20  $\mu\text{s}$

Note 1 to entry: The time to half-value on the tail is not critical and may have any tolerance during the residual voltage type tests (see 8.3.2.2).

### 3.55

#### **steep current impulse protection level**

##### **STIPL**

maximum residual voltage of the arrester for a steep current impulse of magnitude equal to the magnitude of the nominal discharge current

**3.56****tail of an impulse**

part of an impulse which occurs after the peak

**3.57****terminal line force**

force perpendicular to the longitudinal axis of the arrester measured at the centre line of the arrester

**3.58****thermal charge transfer rating** **$Q_{th}$** 

maximum specified charge that may be transferred through an arrester or arrester section within 3 minutes in a thermal recovery test without causing a thermal runaway

Note 1 to entry: This rating is verified by the operating duty type test.

**3.59****thermal runaway**

<of an arrester> situation when the sustained power loss of an arrester exceeds the thermal dissipation capability of the housing and connections, leading to a cumulative increase in the temperature of the MO resistor elements culminating in failure

**3.60****thermal stability**

<of an arrester> state of an arrester if, after an operating duty causing temperature rise, the temperature of the MO resistors decreases with time when the arrester is energized at specified continuous operating voltage and at specified ambient conditions

**3.61****torsional loading**

each horizontal force at the top of a vertical mounted arrester housing which is not applied to the longitudinal axis of the arrester

**3.62****type tests****design tests**

tests which are made upon the completion of the development of a new arrester design to establish representative performance and to demonstrate compliance with the relevant standard

Note 1 to entry: Once made, these tests need not be repeated unless the design is changed so as to modify its performance. In such a case, only the relevant tests need be repeated.

**3.63****unipolar sine half-wave current impulse**

unipolar current impulse consisting of one half-cycle of an approximately sinusoidal current

**3.64****unit of an arrester****arrester unit**

completely housed part of an arrester which may be connected in series and/or in parallel with other units to construct an arrester of higher voltage and/or current rating

**3.65** **$T_1$** **virtual front time of a current impulse**

time in microseconds equal to 1,25 multiplied by the time in microseconds for the current to increase from 10 % to 90 % of its peak value

Note 1 to entry: If oscillations are present on the front, the reference points at 10 % and 90 % should be taken on the mean curve drawn through the oscillations.

### 3.66

#### **virtual origin**

<of an impulse> point on a graph of voltage versus time or current versus time determined by the intersection between the time axis at zero voltage or zero current and the straight line drawn through two reference points on the front of the impulse

Note 1 to entry: For current impulses the reference points shall be 10 % and 90 % of the peak value.

Note 2 to entry: This definition applies only when scales of both ordinate and abscissa are linear.

Note 3 to entry: If oscillations are present on the front, the reference points at 10 % and 90 % should be taken on the mean curve drawn through the oscillations.

### 3.67

#### **virtual steepness of the front of an impulse**

quotient of the peak value and the virtual front time of an impulse

### 3.68

#### **virtual time to half-value on the tail of an impulse**

$T_2$

time interval between the virtual origin and the instant when the voltage or current has decreased to half its peak value, expressed in microseconds

## **4 Identification and classification**

### **4.1 Arrester identification**

Metal-oxide surge arresters containing gapped structures shall be identified by the following minimum information which shall appear on a nameplate permanently attached to the arrester:

- designation of arrester (see Table 1)
- continuous operating voltage;
- rated voltage;
- rated frequency, only if other than one of the standard frequencies, see 5.2;
- nominal discharge current;
- rated short-circuit current in kiloamperes (kA). For arresters for which no short-circuit rating is claimed, the value "0" shall be indicated;
- manufacturer's name or trade mark, type and identification of the complete arrester;
- year of manufacture;
- if sufficient space is available the nameplate should also contain:
- repetitive charge transfer rating,  $Q_{rs}$ .

### **4.2 Arrester classification**

Distribution class arresters are classified as indicated in Table 1, and they shall meet at least the test requirements and performance characteristics specified in Table 3.

**Table 1 – Arrester classification**

| Arrester class                                                                                                                                                                                                  | Distribution |            |             |
|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------|------------|-------------|
| Designation                                                                                                                                                                                                     | DH           | DM         | DL          |
| Nominal discharge current <sup>a</sup>                                                                                                                                                                          | 10 kA        | 5 kA       | 2,5 kA      |
| $Q_{rs}$ (C)                                                                                                                                                                                                    | $\geq 0,4$   | $\geq 0,2$ | $\geq 0,1$  |
| $Q_{th}$ (C)                                                                                                                                                                                                    | $\geq 1,1$   | $\geq 0,7$ | $\geq 0,45$ |
| <sup>a</sup> Other currents may be specified upon agreement between manufacturer and user.<br><br>NOTE The letters "H", "M" and "L" in the designation stand for "high", "medium" and "low" duty, respectively. |              |            |             |

## 5 Standard ratings and service conditions

### 5.1 Standard rated voltages

Standard values of rated voltages for arresters (in kV RMS) are specified in Table 2 in equal voltage steps within specified voltage ranges:

**Table 2 – Steps of rated voltages**

| Range of rated voltage<br>kV | Steps of rated voltage<br>kV RMS |
|------------------------------|----------------------------------|
| 3 to 30                      | 1 kV                             |
| 30 to 52                     | 3 kV                             |

Other values of rated voltages may be accepted.

### 5.2 Standard rated frequencies

The standard rated frequencies are 50 Hz and 60 Hz.

### 5.3 Standard nominal discharge currents

The standard nominal 8/20 discharge currents are: 10 kA, 5 kA, and 2,5 kA.

### 5.4 Service conditions

#### 5.4.1 Normal service conditions

Surge arresters that conform to this document shall be suitable for normal operation under the following normal service conditions:

- ambient air temperature within the range of  $-40\text{ }^{\circ}\text{C}$  to  $+40\text{ }^{\circ}\text{C}$ ;
- solar radiation;

NOTE The effects of maximum solar radiation ( $1,1\text{ kW/m}^2$ ) have been taken into account by preheating the test specimen in the type tests. Other heat sources that may affect the application of the arrester are not considered under normal service condition

- altitude not exceeding 1 000 m;
- frequency of the AC power supply shall not be less than 48 Hz and not exceeding 62 Hz;
- power frequency voltage applied continuously between the terminals of the arrester not exceeding its continuous operating voltage;

- f) wind speeds  $\leq 34$  m/s;
- g) vertical erection, not suspended.

#### 5.4.2 Special environmental conditions

Surge arresters subject to other than normal application or service conditions may require special consideration in design, manufacture or application. The use of this document in case of special environmental conditions is subject to agreement between the manufacturer and the purchaser. A list of possible abnormal service conditions is given in Annex A.

## 6 Requirements

### 6.1 Insulation withstand

The arrester shall be designed such that the housings are able to adequately withstand voltages during conduction of lightning currents and during anticipated maximum power frequency overvoltages. The external insulation withstand capability of the housings shall be demonstrated by tests according to 8.2, while the internal insulation withstand capability shall be demonstrated by tests according to 8.13.

### 6.2 Residual voltages

The purpose of the measurement of residual voltages is to obtain the maximum residual voltages for a given design for all specified currents and wave shapes. These are derived from the type test data and from the maximum residual voltage at a lightning current impulse used for routine tests as specified and published by the manufacturer.

The maximum residual voltage of a given arrester design for any current and wave shape is calculated from the residual voltage of sections tested during type tests multiplied by a specific scale factor. This scale factor is equal to the ratio of the declared maximum residual voltage, as checked during the routine tests, to the measured residual voltage of the sections at the same current and wave shape.

Manufacturers' literature shall contain, for each arrester listed, the following residual voltage information:

- Maximum lightning impulse residual voltage for impulse currents of at least 0,5; 1 and 2 times the nominal discharge current of the arrester (see 8.3.2.3)
- Maximum steep current impulse residual voltage, excluding inductive voltage contribution, for an impulse current having peak value equal to the nominal discharge current of the arrester (see 8.3.2.2)
- Maximum steep current impulse residual voltage, including inductive voltage contribution for an impulse current having peak value equal to the nominal discharge current of the arrester. This residual voltage shall be equal to

NOTE Typical maximum residual voltages for different types of arrester are given in Annex F of IEC 60099-5:2018.

### 6.3 Impulse protective levels

The arrester shall be tested to determine whether the protective level for a specified waveshape is a function of the maximum impulse sparkover value (8.3.3) or residual voltage (8.3.2) whichever is greatest.

### 6.4 Internal partial discharges

Under normal and dry operating conditions, internal partial discharges shall be below a level that might cause damage to internal parts. This shall be demonstrated by routine test according to item c) of 9.1.

### 6.5 Seal leak rate

For arresters having an enclosed gas volume and a separate sealing system, seal leak rates shall be specified as defined in 8.12 and item d) of 9.1.

### 6.6 Thermal stability

When agreed between manufacturer and purchaser, a special thermal stability test may be performed according to 9.2.2

### 6.7 Heat dissipation behaviour of test sample

In the operating duty test (8.5) and the power frequency voltage-versus-time test (8.6), the behaviour of the test sample is to a great extent dependent on the ability of the sample to dissipate heat, i.e. to cool down after being stressed by a discharge.

Consequently, the test samples shall have a transient and a steady-state heat dissipation capability and heat capacity equivalent to the complete arrester if correct information is to be obtained from the test. For the same ambient conditions the MO resistors in the sample and in the complete arrester should in principle reach the same temperature when subjected to the same voltage stress.

### 6.8 Repetitive charge transfer withstand

Complete arresters shall withstand repetitive charge transfers as checked during type tests (see 8.4).

The repetitive charge transfer withstand is demonstrated on complete arresters with voltage ratings between 3 and 12kV in the test to verify the repetitive charge transfer rating (see 8.4.2.2).

NOTE There may be special applications where single event charge transfers cause energy dissipations higher than the rated thermal charge transfer rating.

### 6.9 Operating duty

Arresters shall be able to absorb energy from switching events or transfer charge from lightning events and subsequently thermally recover under applied temporary overvoltage and following continuous operating voltage conditions. This capability is demonstrated by the operating duty test (see 8.5).

### 6.10 Power-frequency voltage versus time characteristics of an arrester

The manufacturer shall supply data on the allowable time duration of power-frequency voltage and the corresponding voltage value which may be applied to the arrester after the arrester has been preheated to the start temperature as per 8.5.2.3 without damage or thermal runaway. The data shall be given without prior energy or charge duty and – in case of  $I_n = 10 \text{ kA}$  – the thermal charge transfer rating  $Q_{th}$ .

This information shall be presented as power-frequency voltage versus time curves (TOV curves) with the energy or charge duty prior to this power-frequency voltage application stated on the above-mentioned curve. The TOV characteristic is demonstrated on complete arrester that represents the worst case heat transfer in the test to verify the power frequency voltage versus time characteristic (TOV test) (see 8.6).

### 6.11 Short-circuit performance

The manufacturer shall declare a short-circuit current rating for each family of arresters. Only for applications with expected short-circuit currents below 1 kA may the rated value “zero” be claimed. In this case “0” shall be indicated on the name plate. In any case, the arrester shall be subjected to a short-circuit test according to 8.9 to show that it will not fail in a manner that causes violent shattering of the housing and that self-extinguishing of open flames (if any) occurs within a defined period of time.

### 6.12 Disconnectors

#### 6.12.1 Disconnector withstand

When an arrester is fitted or associated with a disconnector, this device shall withstand, without operating, each of the following tests:

- test to verify the repetitive charge transfer rating,  $Q_{rs}$  (see 8.4.2.2);
- operating duty test with rated values of thermal charge rating,  $Q_{th}$  (see 8.5.2);
- mechanical tests on agreement between manufacturer and user (see NOTE to 8.7.4.1)
- temperature cycling and seal pumping test (see 8.7.5)

#### 6.12.2 Disconnector operation

The time delay for the operation of the disconnector is determined for three values of current according to 8.7.3. There shall be clear evidence of effective and permanent disconnection by the device.

### 6.13 Requirements on internal grading components

Internal grading components, if used in the arrester, shall be able to withstand the combination of stresses arising in service, and the impedance of the grading components shall also show sufficient stability during the service life. This shall be demonstrated by operating duty test (see 8.5) and the TOV test (see 8.6) being performed with internal grading components included in the test sections.

Furthermore, the components shall withstand the accelerated ageing and cyclic tests as specified in 8.13.

### 6.14 Power-frequency sparkover

A power-frequency sparkover test shall be performed on gapped arresters. The minimum power-frequency sparkover voltage of the arrester shall be stated by the manufacturer.

### 6.15 Mechanical loads

#### 6.15.1 General

The manufacturer shall specify the maximum permissible terminal loads relevant for installation and service, such as cantilever, torque and tensile loads.

#### 6.15.2 Bending moment

The arrester shall be able to withstand the manufacturer's declared values for bending loads (see 8.10).

When determining the mechanical load applied to a surge arrester, the user should consider, for example, wind, ice and electromagnetic forces likely to affect the installation.



Surge arresters enclosed within their package should withstand the transportation loads specified by the user in accordance with IEC 60721-3-2, but not less than Class 2M1.

NOTE Unlike porcelain-housed arresters, polymer-housed arresters might show mechanical deflections in service.

### **6.15.3 Resistance against environmental stresses**

The arrester shall be able to withstand environmental stresses as defined in 8.11.

### **6.15.4 Insulating base and mounting bracket**

When an insulating base and/or a mounting bracket is provided with the arrester, the base and/or bracket shall be subjected to mechanical tests separately from the arrester (see 8.10.6).

### **6.15.5 Mean value of breaking load (MBL)**

For porcelain and cast-resin housed arresters the MBL shall be  $\geq 1,2$  times the specified short-term load (SSL). This shall be demonstrated in the bending moment test of 8.10.

## **6.16 Electromagnetic compatibility**

Arresters are not sensitive to electromagnetic disturbances and therefore no immunity test is necessary.

In normal dry operating conditions, surge arresters shall not emit significant disturbances. On request from users, each manufacturer shall give enough information so that all the arrester components may be scrapped and/or recycled in accordance with international and national regulations.

## **6.17 End of life**

On request from users, each manufacturer shall give enough information so that all the arrester components may be scrapped and/or recycled in accordance with international and national regulations.

## **7 General testing procedures**

### **7.1 Measuring equipment and accuracy**

The measuring equipment shall meet the requirements of IEC 60060-2. The values obtained shall be accepted as accurate for the purpose of compliance with the relevant test clauses.

Unless elsewhere stated, all tests with power-frequency voltages shall be made with an alternating voltage having a frequency between the limits of 48 Hz and 62 Hz and an approximately sinusoidal waveshape.

### **7.2 Test samples**

#### **7.2.1 General**

Unless otherwise specified, all tests shall be made on complete arrester units. They shall be new, clean, completely assembled (for example, with grading rings if applicable) and arranged to simulate as closely as possible the conditions in service.

In general, the samples shall cover the highest residual voltage and the lowest reference voltage of the type of MO resistors used in the arrester. If thermal charge transfer rating is specified in the operating duty test and for the TOV test (see 8.5 and 8.6) the samples shall have the highest lightning impulse protection level  $U_{pl}$  per unit length of the design. If thermal

energy rating is specified in the operating duty test the test samples shall have a reference voltage value at the lower end of the variation range declared by the manufacturer. In order to comply with these demands the following shall be fulfilled:

- a) The ratio between the rated voltage of the complete arrester to the rated voltage of the section is defined as  $n$ . The volume of the MO resistor elements used as test samples shall not be greater than the minimum volume of all MO resistor elements used in the complete arrester divided by  $n$ .
- b) The continuous operating voltage applied in tests involving thermal recovery shall fulfil the following requirement: The ratio of the continuous operating voltage to the rated voltage of the section shall be not less than the maximum ratio claimed for the arrester type.

## 7.2.2 Samples for residual voltage tests

Samples for the residual voltage tests shall be complete arresters, stacks of series connected MO resistors or individual MO resistors in still air. For multi-column arresters the samples may be made of the actual number of MO resistors or resistor columns in parallel or of only one MO resistor or resistor column, respectively.

## 7.2.3 Samples for the test to verify the repetitive charge transfer rating, $Q_{rs}$

### 7.2.3.1 General

Both MO resistors and series gaps shall be tested.

### 7.2.3.2 MO resistors

Samples shall be either complete arresters, MO resistors either in still air or in the actual surrounding medium of the design. The choice is at the discretion of the manufacturer.

The samples shall be of the longest length of the type of MO resistors used in the design, and shall have a 10-kA residual voltage stress of not less than  $0,97 \times (U_{10 \text{ kA}} \text{ per mm of MO resistor length})_{\text{max}}$ , where  $(U_{10 \text{ kA}} \text{ per mm of MO resistor length})_{\text{max}}$  is the highest 10-kA residual voltage stress specified by the manufacturer for any length of the type of MO resistors used in the arrester. If only samples of lower 10-kA residual voltage stress are available, the required transferred charge shall be increased for the test by the factor

$$(U_{10 \text{ kA}} \text{ per mm of MO resistor length})_{\text{max}} / (U_{10 \text{ kA}} \text{ per mm of MO resistor length})_{\text{actual}}$$

### 7.2.3.3 Gaps

Samples shall be gaps having the shortest gap spacing of gaps used in the arrester design.

## 8 Type tests (design tests)

### 8.1 General

Type tests defined in this clause apply to porcelain-housed arresters. The tests also apply to polymer-housed arresters unless otherwise noted in 10.8.

Type tests shall be made as indicated in Table 3.

**Table 3 – Arrester type tests**

| Arrester class                                                                       | Distribution            |
|--------------------------------------------------------------------------------------|-------------------------|
| Nominal discharge current                                                            | 10 kA<br>5 kA<br>2,5 kA |
| Typical $U_s$ (kV), rms value                                                        | ≤ 52                    |
| 1 Insulation withstand tests on the arrester housing                                 |                         |
| a) Lightning impulse                                                                 | 8.2.5                   |
| c) Power-frequency                                                                   | 8.2.6                   |
| 2 Impulse protective level test                                                      | 8.3                     |
| 3 Repetitive charge transfer withstand                                               | 8.4                     |
| 4 Operating duty test                                                                | 8.5                     |
| 5 Power-frequency voltage versus time                                                | 8.6                     |
| 6 Arrester disconnect/fault indicator (when fitted)                                  | 8.7                     |
| 7 Power frequency sparkover voltage test                                             | 8.8                     |
| 8 Short-circuit tests                                                                | 8.9                     |
| 9 Bending moment                                                                     | 8.10                    |
| 10 Environmental tests                                                               | 8.11                    |
| 11 Seal leak rate                                                                    | 8.12                    |
| 12 Test to verify the dielectric withstand of the internal components of an arrester | 8.13                    |
| 13 Test of internal grading components                                               | 8.14                    |
| Numbers in rows 1 to 13 refer to clauses and subclauses in this document.            |                         |
| NOTE Type tests for polymer-housed arresters are specified in 10.8.                  |                         |

The required numbers of samples and their conditions are specified in the individual clauses. Arresters that differ only in methods of mounting or arrangement of the supporting structure, and which are otherwise based on the same components and similar construction resulting in the same performance characteristics including their heat dissipation conditions and internal atmosphere, are considered to be of the same design.

## 8.2 Insulation withstand tests

### 8.2.1 General

The voltage withstand tests demonstrate the voltage withstand capability of the external insulation of the arrester housing. For other designs the test has to be agreed upon between the manufacturer and the user.

The tests shall be performed in the conditions and with the test voltages specified in 6.1 and repeated below. The outside surface of insulating parts shall be carefully cleaned and the internal parts removed or rendered inoperative to permit these tests.

If any of the conditions relating dry arc distance to test voltage, as described in 8.2.5 or 8.2.6, is fulfilled then the relevant test specified in 8.2.5 or 8.2.6 need not be performed, since, under these conditions, the insulation withstand voltage of the arrester will inherently meet the minimum requirement.

### 8.2.2 Tests on individual unit housing

The applicable tests shall be run on the longest arrester housing. If this does not represent the highest specific voltage stress per unit length, additional tests shall be performed on the unit housing having the highest specific voltage stress.

For the test, the MO resistors shall be removed from the housing or replaced by insulators.

### 8.2.3 Ambient air conditions during tests

The voltage to be applied during a withstand test is determined by multiplying the specified withstand voltage by the correction factor, taking into account density and humidity. See IEC 60060-1.

Humidity correction shall not be applied for wet tests.

### 8.2.4 Wet test procedure

The external insulation of outdoor arresters shall be subjected to wet withstand tests under the test procedure given in IEC 60060-1.

### 8.2.5 Lightning impulse voltage test

The arrester shall be subjected to a standard lightning impulse voltage dry test according to IEC 60060-1. The test voltage shall be at least 1,3 times the maximum residual voltage of the arrester at nominal discharge current.

NOTE The 1,3 factor is obtained from  $1,15 \cdot e^{1000/8150}$ , which reflects a 15 % coordination factor to take into account discharge currents higher than nominal and the statistical nature of the withstand voltage of the insulation, and a 13 % margin to account for variation in air pressure from sea level up to normal service altitudes not exceeding 1 000 m.

Fifteen consecutive impulses at the test voltage value shall be applied for each polarity. The arrester shall be considered to have passed the test if no internal disruptive discharges occur and if the number of the external disruptive discharges does not exceed two in each series of 15 impulses. The test voltage shall be equal to the standard lightning impulse protection level of the arrester multiplied by 1,3.

If the dry arcing distance or the sum of the partial dry arcing distances is larger than the test voltage divided by 500 kV/m, this test is not required.

### 8.2.6 Power-frequency voltage test

The housings of arresters intended for outdoor use shall be tested in wet conditions, and housings of arresters intended for indoor use shall be tested in dry conditions.

Housings of distribution class arresters according to Table 1 shall withstand a power-frequency voltage with a peak value equal to the lightning impulse protection level multiplied by 0,88 for a duration of 1 min.

NOTE 1 The factor of 0,88 takes into account a safety margin of 1,15 for lightning impulse currents higher than nominal discharge current, an altitude correction factor of 1,13 for 1 000 m installation altitude, a factor 0,8 as a typical ratio between switching and lightning impulse protection level and a test conversion factor of  $0,6 \times \sqrt{2}$  for conversion from switching impulse voltage to peak value of power-frequency voltage according to Table 2 of IEC 60071-2:2018.

NOTE 2 If the dry arcing distance or the sum of the partial dry arcing distances is larger than given by the equation  $d = [1,82 \times (e^{(U/859)} - 1)]^{0,833}$ , where  $d$  is the distance in m and  $U$  is the peak value of the power-frequency test voltage in kV, this test is not required.

NOTE 3 The equation is derived from formula G.1 of IEC 60071-2:2018, where the peak value of  $U_{50}$  is given as  $750 \times \sqrt{2} \times \ln(1 + 0,55 \times d^{1,2})$ ,  $d$  being the distance. Following the recommendations given in IEC 60071-2, for the

purpose of this document the gap factor  $k$  is assumed to be equal to 1, the withstand voltage is assumed to be 90 % of  $U_{50}$ , and a 10 % reduction in  $U_{50}$  is assumed for wet conditions compared to dry.

### 8.3 Impulse protective level tests

#### 8.3.1 General

The purpose of the impulse protective level measurement is to obtain the maximum protective level for a given design for all specified currents and voltage waveshapes.

The general test procedure shall be as follows:

- a) Apply prospective impulse voltage waves, measure the resulting peak arrester voltages and compare these voltages with the appropriate residual voltage level.
- b) Where the maximum arrester voltage resulting from application of these prospective voltage impulses is less than the arrester residual voltage level, then the protective level for that waveshape is the arrester residual voltage level.
- c) Otherwise, sparkover tests shall be made and the protective level for that waveshape is the maximum sparkover value. Impulse protective levels shall be established by the front-of-wave sparkover and 1,2/50 impulse sparkover.

#### 8.3.2 Residual voltage tests

##### 8.3.2.1 General

The purpose of the residual voltage type test is to obtain the data necessary to derive the maximum residual voltage. It includes the calculation of the ratio between voltages at specified impulse currents and the voltage level checked in routine tests. The latter residual voltage can be either at the nominal discharge current or the residual voltage at a suitable lightning impulse current in the range 0,01 to 2 times the nominal discharge current, depending on the manufacturer's choice of routine test procedure.

The maximum residual voltage at a lightning impulse current used for routine tests shall be specified and published in the manufacturer's data. Maximum residual voltages of the design for all specified currents and waveshapes are obtained by multiplying the measured residual voltages of the test sections by the ratio of the declared maximum residual voltage at the routine test current to the measured residual voltage for the section at the same current.

All residual voltage tests shall be made on the same three samples of complete arresters or arrester sections. The time between discharges shall be sufficient to permit the samples to return to within 5 °C of ambient temperature.

##### 8.3.2.2 Steep current impulse residual voltage test

One steep current impulse with a peak value equal to the nominal discharge current of the arrester  $\pm 5$  % shall be applied to each of the three samples. The peak value and the impulse shape of the voltage appearing across the three samples shall be recorded and, if necessary, corrected for inductive effects of the voltage measuring circuit as well as the geometry of the test sample and the test circuit.

The following procedure shall be used to determine if an inductive correction is required:

- A steep current impulse as described above shall be applied to a non-ferrous metal block having the same dimensions as the MO resistor samples being tested. The peak value and the shape of the voltage appearing across the metal block shall be recorded.
- If the peak voltage on the metal block is less than 2 % of the peak voltage of the MO resistor samples, no inductive correction to the MO resistor measurements is required.
- If the peak voltage on the metal block is between 2 % and 20 % of the peak voltage on the MO resistor sample, then the impulse shape of the metal block voltage shall be subtracted

from the impulse shape of each of the MO resistor voltages and the peak values of the resulting impulse shapes shall be recorded as the corrected MO resistor voltages.

- If the peak voltage on the metal block is greater than 20 % of the peak voltage on the MO resistor samples, then the test circuit and the voltage measuring circuit shall be improved and the test shall be repeated.

NOTE 1 A possible way to achieve identical current wave shapes during all measurements is to perform them with both the test sample and the metal block in series in the test circuit. Only their positions relative to each other need to be interchanged for measuring the voltage drop on the metal block or on the test sample.

The highest of the three measured residual voltages, corrected if necessary as indicated above, and multiplied by the scale factor (see 7.2) is defined as the steep current protection level of the arrester excluding the inductive voltage contribution of the arrester.

NOTE 2 Connecting leads to connect the arrester to the power system will introduce additional inductive voltage drop for steep current impulse currents.

### 8.3.2.3 Lightning impulse residual voltage test

One lightning current impulse shall be applied to each of the three samples for each of the following three peak values of approximately 0,5, 1 and 2 times the nominal discharge current of the arrester. Virtual front time shall be within 7  $\mu$ s to 9  $\mu$ s while the time to half-value (which is not critical) may have any tolerance. The residual voltages are determined in accordance with 6.2. The maximum values of the determined residual voltages shall be drawn in a residual voltage versus discharge current curve. The residual voltage read on such a curve corresponding to the nominal discharge current is defined as the lightning impulse protection level of the arrester.

If a complete arrester routine test cannot be carried out at one of the above currents, then additional type tests shall be carried out at a current in the range of 0,01 to 0,25 times nominal discharge current for comparison to the complete arrester.

## 8.3.3 Sparkover tests

### 8.3.3.1 General

Sparkover tests shall be made on three samples of complete arresters of each voltage rating tested. The performance for other voltage ratings of the same design within  $\pm 20$  % (or 3 kV, whichever is greater) of a test sample rating can be determined by adjusting the voltage level in proportion to the voltage ratings. In view of the dependency of gap sparkover on temperature, the tests should be carried out at 20 °C to 25 °C, and an additional test carried out at an elevated temperature (preferably between 40 °C and 50 °C). If there is a difference between the results, then the higher of the two results shall be used for subsequent tests and comparisons.

### 8.3.3.2 Fast front protective level

#### 8.3.3.2.1 General

This test determines whether the arrester sparkover for a front-of-wave lightning impulse can exceed its steep current residual voltage.

#### 8.3.3.2.2 Front-of-wave impulse sparkover determination test

This test is performed using both positive and negative polarity impulses. The prospective magnitude of the test wave shall be a minimum of 1,2 times the arrester's steep current residual voltage. At least five discharges shall be measured for each polarity. The nominal rate of rise of the test wave front shall be 8,33 kV/ $\mu$ s for each kilovolt of arrester voltage rating.

The maximum arrester voltage recorded during five positive and five negative polarity impulses shall be compared to the steep current residual voltage. If the steep current residual voltage exceeds the voltage values measured during the impulse test described above, the steep current residual voltage is the fast front protective level and no further testing is required on this waveshape. If the voltage measured during the impulse test exceeds the steep current residual voltage, proceed to 8.3.3.2.3 to determine the fast front protective level.

### 8.3.3.2.3 Front-of-wave impulse sparkover tests

This test shall be made using both positive and negative polarity impulses. The prospective crest value of the test wave shall be high enough that the sparkover of the arrester occurs before 90 % of the crest value of the test wave is reached. At least five sparkovers shall be recorded for each polarity and the highest crest value so recorded shall be reported as the maximum front-of-wave sparkover value of the test arrester and taken as the fast front protective level. The nominal rate of rise of the test wave front shall be the same as described in 8.3.3.2.2.

### 8.3.3.3 Standard lightning impulse protective level test

#### 8.3.3.3.1 General

This test series determines whether the arrester sparkover voltage for a standard lightning impulse can exceed the residual voltage obtained from an 8/20 impulse at nominal current as shown in 8.3.3.3.2.

#### 8.3.3.3.2 Standard lightning impulse sparkover determination test

The test is performed using at least five positive and five negative waves. A minimum prospective magnitude of 1,2 times the arrester's residual voltage at the nominal discharge current as indicated in 8.3.2.3 shall be used. The maximum arrester voltage recorded during the five positive and five negative polarity standard lightning impulses shall be compared to the residual voltage obtained with the nominal discharge currents in 8.3.2.3. If the nominal discharge current residual voltage exceeds the voltage values measured during the standard lightning impulse sparkover voltage test described earlier, the nominal discharge current residual voltage is the standard lightning protective level and no further testing is required on this waveshape. If the voltage measured during the standard lightning impulse test exceeds the nominal discharge current residual voltage, proceed to 8.3.3.3.3, the standard lightning impulse sparkover voltage test, to determine the standard lightning impulse protective level.

#### 8.3.3.3.3 The standard lightning impulse sparkover test

The purpose of this test is to determine the highest standard lightning impulse voltage greater than 3  $\mu$ s duration that the arrester will withstand without sparkover.

For each polarity, the test procedure shall be:

- a) Determine the base generator charge voltage,  $U_G$ , according to the method described in the following note and record crest voltage and time to sparkover (where sparkover occurs) for each of the 20 impulses used for establishing  $U_G$ .

NOTE The procedure for establishing  $U_G$  is as follows: Start by applying an impulse having a prospective crest voltage somewhat lower than the expected sparkover voltage of the arrester, raising the generator charge voltage in approximately 5 % steps for subsequent impulses until sparkover occurs. Then apply a series of 20 impulses, decreasing the prospective crest voltage by about 5 % after every sparkover and increasing the prospective crest voltage by about 5 % after every withstand.  $U_G$  is the average generator charge voltage used during the series of 20 impulses.

- b) Apply five impulses using a generator charge voltage not more than 1,05  $U_G$  and record crest voltage and time to sparkover. If sparkover does not occur within 3,0  $\mu$ s after the virtual zero point on each of the five impulses, raise generator charge voltage in additional increments not greater than 0,05  $U_G$  until a level is reached that results in sparkover within 3,0  $\mu$ s after the virtual zero point on each of the five applications. The higher



prospective crest voltage of either polarity required to obtain five sparkovers on five successive applications of test impulses with constant generator charge voltage shall be reported as the standard lightning impulse protective level of the arrester.

## 8.4 Test to verify the repetitive charge transfer rating, $Q_{rs}$

### 8.4.1 General

The purpose of this test is to verify the repetitive charge transfer rating,  $Q_{rs}$ , of an arrester. An arrester shall be assigned a  $Q_{rs}$  value from the values in Table 1.

Repetitive charge transfer capability is specified as an impulse current stress that can be withstood by the MO resistors and gaps of an arrester twenty times without mechanical or unacceptable electrical damage. One impulse current stress is considered to represent a charge transfer event that may occur under real system conditions.

The repetitive charge transfer rating is related to a certain very low failure probability and is thus not a deterministic but a statistical value. The test is performed on individual MO resistors and gaps at a charge value of at least 1,1 times the  $Q_{rs}$  rated value selected from Table 1 according to the class of arrester being tested.

Charge has been chosen as a test basis for the purpose of better comparison between different makes of MO resistors.

Lightning impulse currents 8/20  $\mu$ s shall be used.

### 8.4.2 MO resistors

#### 8.4.2.1 General

Tests shall be performed on 10 MO resistor samples selected according to 7.2.3.2. At the manufacturer's discretion, the samples may be individual MO resistors or may be combined in stacks of two or more resistors provided that 10 resistors in total are tested.

#### 8.4.2.2 Test procedure

Figure 1 gives an overview of the test procedure for MO resistors.

|                                                                                                                                                                                                                                                                                                                                                                                                      |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Initial measurements                                                                                                                                                                                                                                                                                                                                                                                 |
| <ul style="list-style-type: none"> <li>Residual voltage test at nominal discharge current</li> </ul>                                                                                                                                                                                                                                                                                                 |
| Application of 1,1 times $Q_{rs}$                                                                                                                                                                                                                                                                                                                                                                    |
| <ul style="list-style-type: none"> <li>1<sup>st</sup> sequence: 20 impulses per sample</li> <li>if not more than one MO resistor sample failure during 1<sup>st</sup> sequence: MO resistor test passed</li> <li>if not more than two sample MO resistor failures during 1<sup>st</sup> sequence: conduct 2<sup>nd</sup> sequence with 10 new MO resistor samples, 20 impulses per sample</li> </ul> |
| if more than two MO resistor sample failures in 1 <sup>st</sup> sequence or any MO resistor sample failure in 2 <sup>nd</sup> sequence: MO resistor test failed                                                                                                                                                                                                                                      |
| Final measurements                                                                                                                                                                                                                                                                                                                                                                                   |
| <ul style="list-style-type: none"> <li>withstand capability to one 8/20 current impulse of at least 0,5 kA/cm<sup>2</sup> peak current density or 2 times <math>I_n</math>, whichever is lower</li> </ul>                                                                                                                                                                                            |
| Residual voltage test at nominal discharge current                                                                                                                                                                                                                                                                                                                                                   |

IEC

Figure 1 – procedure to verify the repetitive charge transfer rating,  $Q_{rs}$ , for MO resistors



The following procedure shall be followed:

- Each sample shall be subjected to a residual voltage test at nominal discharge current. For samples of multi-column arresters the nominal discharge current applied in the test is the highest nominal discharge current used for the type of sample in any design.
- In a first test sequence, each sample shall be subjected to twenty 8/20 lightning current impulses administered in ten groups of two impulses, with time between impulses within a group of 50 s to 60 s and time between groups sufficient for cooling to ambient temperature.

The charge content of each impulse shall be at least equal to the claimed repetitive charge transfer rating multiplied by 1,1;

NOTE The requirement of testing at least 1,1 times the rated charge values is considered to give sufficient confidence that the performance of the individual MO resistors can also be assigned to complete arresters built from this type of MO resistors.

- If one sample fails, a second sequence identical to the first shall be performed on an additional 10 samples (if more than one sample fails, the entire test is failed).
- Surviving samples shall be subjected to one 8/20 current impulse of at least 0,5 kA/cm<sup>2</sup> peak current density or 2 times  $I_n$ , whichever is lower.
- Surviving samples shall again be subjected to a residual voltage test at nominal discharge current.

#### 8.4.2.3 Test evaluation

The test shall be considered passed for MO resistors if all the following requirements are met:

- not more than one sample failed during the first sequence, or not more than two samples failed during two sequences.

NOTE If only one failure occurs during the first sequence and this happens, in the worst case, at the very first impulse application, 180 impulses without failure will have been applied at the end, giving a failure probability of max.  $1/181 = 0,0056$  or 0,56 % for the complete test. If two failures occur during the first sequence and this happens, again as a worst case, at the very first applications on two of the samples, 360 impulses without failure will have been applied at the end of both sequences, giving again a failure probability of max.  $2/362 = 0,0056$  or 0,56 % for the complete test.

- there is no mechanical damage of surviving resistors at visual inspection
- each surviving sample demonstrates a withstand capability to one 8/20 current impulse of at least 0,5 kA/cm<sup>2</sup> peak current density or 2 times  $I_n$ , whichever is lower
- the change of residual voltage of surviving samples at nominal discharge current is within  $\pm 5$  %

#### 8.4.3 Series gaps

##### 8.4.3.1 General

Tests shall be performed on three series gaps having the shortest gap spacing of all series gaps used in the arrester design. At the manufacturer's discretion, the gaps may be tested separately from the MO resistors or may be tested in series with three of the MO resistor samples (see 8.4.2).

##### 8.4.3.2 Test procedure

Figure 2 gives an overview of the test procedure for series gaps.

|                                                                                                                                                                     |
|---------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Initial measurements <ul style="list-style-type: none"> <li>• Power-frequency sparkover voltage test</li> <li>• Lightning impulse sparkover voltage test</li> </ul> |
| Application of 1,1 times $Q_{rs}$                                                                                                                                   |
| Final measurements <ul style="list-style-type: none"> <li>• Power-frequency sparkover voltage test</li> <li>• Lightning impulse sparkover voltage test</li> </ul>   |

IEC

**Figure 2 – Procedure to verify the repetitive charge transfer rating,  $Q_{rs}$ , for series gaps**

The following procedure shall be followed:

- Each sample shall be subjected to a power frequency sparkover test and a lightning impulse sparkover voltage test.
- Each sample shall be subjected to twenty current impulses administered in ten groups of two impulses, with time between impulses within a group of 50 s to 60 s and time between groups sufficient for cooling to ambient temperature.  
The wave shape and duration of the current impulses is not important, except that the charge content of each impulse shall be at least equal to the claimed repetitive charge transfer rating multiplied by 1,1.
- Each sample shall be again subjected to a power frequency sparkover test and a lightning impulse sparkover voltage test.

#### 8.4.3.3 Evaluation

The test shall be considered passed if both of the following requirements are met:

- power-frequency sparkover voltage of all three series gap samples is not below claimed sparkover value
- lightning impulse sparkover voltage of all three series gap samples is not above the claimed protection level.

### 8.5 Operating duty tests

#### 8.5.1 General

The purpose of this test is to verify the arrester's ability to thermally recover after injection of the rated thermal energy,  $Q_{th}$ , respectively, under applied temporary overvoltage and following continuous operating voltage conditions. The test shall be performed on three samples.

NOTE Though thermal stability has basically no statistical character, three test samples are specified. This compensates for statistical factors such as incorrect voltage adjustment, variability in the power loss characteristic, tolerance during energy injection etc.

The samples shall fulfil the requirements of 7.2.

Each design of arrester shall be assigned a thermal energy rating,  $Q_{th}$ , from Table 5.

The characterization and conditioning part of the test (8.5.2.2) may be performed at an ambient temperature of  $20\text{ °C} \pm 15\text{ K}$  on the MO resistors in still air or on an arrester.

The thermal recovery part of this test (8.5.2.3) shall be performed on complete arresters (see 6.7). It shall be demonstrated by adequate methods that the start temperature requirement is fulfilled at the beginning of the thermal recovery part of the test.

The relative uncertainty between measurements of the applied voltage shall not be more than  $\pm 1$  %. This may be achieved by any suitable means, e.g. by using identical measuring setups or by calibration of all used measuring setups to  $\pm 1$  %. The peak value of the voltage shall not vary by more than 1 % from no-load to full-load condition. The ratio of peak voltage to RMS value shall not deviate from  $\sqrt{2}$  by more than 2 %. During the tests, the power frequency voltage shall not deviate from the specified values by more than  $\pm 1$  %.

## 8.5.2 Test procedure

### 8.5.2.1 General

Figure 3 gives an overview of the test procedure.

|                                                                                                                                                                                                                                                                                                                                                                                     |
|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <p>Pre-tests</p> <ul style="list-style-type: none"> <li>• Verification of thermal equivalence of the complete arrester</li> </ul>                                                                                                                                                                                                                                                   |
| <p>Initial tests for sample characterization</p> <ul style="list-style-type: none"> <li>• Residual voltage test at nominal discharge current</li> </ul>                                                                                                                                                                                                                             |
| <p>Determination of sample's continuous operating voltage and rated voltage (see, 7.2)</p>                                                                                                                                                                                                                                                                                          |
| <p>Conditioning</p> <p>Conditioning test; 4 groups of 5 impulses superimposed on a continuous power frequency voltage of <math>U_r</math></p> <p>One high current impulse (as per Table 4)</p>                                                                                                                                                                                      |
| <p>Hold for future use</p>                                                                                                                                                                                                                                                                                                                                                          |
| <p>Preheating to start temperature as per 8.5.2.3.</p>                                                                                                                                                                                                                                                                                                                              |
| <p>Distribution class arresters:</p> <ul style="list-style-type: none"> <li>• Rated thermal charge transfer, <math>Q_{th}</math>, within one minute by two lightning current impulses 8/20 <math>\mu</math>s according to 8.5.3</li> </ul>                                                                                                                                          |
| <p>Application of sample's rated voltage for 10 s (within 100 ms after energy or charge injection)</p>                                                                                                                                                                                                                                                                              |
| <p>Application of sample's continuous operating voltage for at least 30 min (until pass or fail is evident)</p>                                                                                                                                                                                                                                                                     |
| <p>Test evaluation</p> <ul style="list-style-type: none"> <li>• Thermal recovery</li> <li>• No physical damage</li> <li>• Change of residual voltage at nominal discharge current within <math>\pm 5\%</math></li> <li>• Final interruption of the follow current shall occur not later than at the end of the half cycle following that in which the impulse is applied</li> </ul> |

IEC

**Figure 3 – Test procedure to verify the thermal charge transfer rating,  $Q_{th}$**

Requirements for start temperature are given in 8.5.2.3.

### 8.5.2.2 Characterization and conditioning

The following procedure shall be applied for characterization and conditioning:

- Each sample shall be subjected to a residual voltage test at the nominal discharge current before and after the test.
- Each sample shall be subjected to 4 groups of 5 impulses superimposed on a continuous power frequency voltage of  $U_r$ . The interval between the impulses shall be 50 s to 60 s and the interval between groups shall be 25 min to 30 min. It is not required that the test sample be energized between groups of impulses.
- For the purpose of conditioning, the samples shall be subjected to one high current impulse as specified in Table 4.
- The impulse shall be of the same polarity as that of the current impulses for the charge transfer, in the thermal recovery part of the test.
- After application of the high current impulse the samples shall be stored at room temperature.

Heating the samples for longer time at very high temperatures, application of alternating voltage or application of impulse currents of opposite polarity might lead to recovery from possible electrical ageing effects and is therefore not permitted.

**Table 4 – Requirements for high current impulses**

| Arrester classification | Peak current 4/10<br>kA |
|-------------------------|-------------------------|
| 10 kA                   | 100                     |
| 5 kA                    | 65                      |
| 2,5 kA                  | 25                      |

The tolerances on the adjustment of the equipment shall be such that the measured values of the current impulses are within the following limits:

- from 90 % to 110 % of the specified peak value;
- from 3,5  $\mu$ s to 4,5  $\mu$ s for virtual front time;
- from 9  $\mu$ s to 11  $\mu$ s for virtual time to half-value;
- the peak value of any opposite polarity current wave shall be less than 20 % of the peak value of the current;
- small oscillations on the impulse are permissible provided their amplitude near the peak of the impulse is less than 5 % of the peak value. Under these conditions, for the purpose of measurement, a mean curve shall be accepted for determination of the peak value.

### 8.5.2.3 Thermal recovery test

The following procedure shall be applied for the thermal recovery part of the test:

- The complete test samples shall be preheated to a start temperature of at least 60 °C.
- The preheating shall take not more than twenty hours.
- The temperature of the MO resistors shall be immediately prior to the transfer of charge.
- Each sample shall be subjected to transfer of charge. Within 100 ms from the charge transfer, a voltage equal to the sample's rated voltage (see 7.2), shall be applied for 10 s and thereafter a voltage equal to the sample's continuous operating voltage (see 7.2) shall be applied for a minimum of 30 minutes to demonstrate thermal stability. Resistive component of current or power dissipation or temperature or any combination of them

shall be monitored until the measured value is appreciably reduced (success), but for at least 30 minutes, or thermal runaway condition (failure) is evident.

#### 8.5.2.4 Test evaluation

The test shall be considered passed if all the following criteria are met:

- thermal recovery has been demonstrated;
- no physical damage is evident;
- any change of the residual voltage at nominal discharge current before and after the test is within  $\pm 5\%$ .

Final interruption of the follow current shall occur not later than at the end of the half cycle following that in which the impulse is applied

#### 8.5.3 Rated thermal charge values, $Q_{th}$

The values of thermal charge rating,  $Q_{th}$ , given in C, shall be taken from Table 5.

**Table 5 – Rated values of thermal charge transfer rating,  $Q_{th}$**

| Nominal discharge current (kA) | $Q_{th}$ rating (C) | $Q_{th}$ per impulse (C) | Corresponding 8/20 $\mu$ s current amplitude (kA) (approximately) (informative) |
|--------------------------------|---------------------|--------------------------|---------------------------------------------------------------------------------|
| 2,5                            | 0,45                | 0,23 ( $\pm 10\%$ )      | 14                                                                              |
| 5                              | 0,7                 | 0,35 ( $\pm 10\%$ )      | 22                                                                              |
| 10                             | 1,1                 | 0,55 ( $\pm 10\%$ )      | 34                                                                              |

### 8.6 Power-frequency voltage-versus-time test

#### 8.6.1 General

The purpose of this test is to demonstrate the TOV (temporary overvoltage) withstand capability of the arrester. In this test, the TOV is strictly a power-frequency overvoltage for time periods from 0,1 s to 3 600 s.

Manufacturers' published data shall include curves with abscissa scaled in time and ordinate in per unit of  $U_r$ . In addition, the manufacturer shall publish a table of TOV values listed in per unit of  $U_r$  to three significant digits, for times 0,1 s, 1 s, 10 s, 100 s, and 1 000 s. The table values shall be taken from the curves and shall include data "without prior duty" and "with prior duty". The published curve and table shall state the range of arrester ratings for which they apply.

The TOV value "with prior duty" and 10 s time duration shall be at least equal to  $U_r$ .

Figure 4 gives an overview of the test procedure.

|                                                                                                                                                                                                                                                                                                                                                                                                                                                               |
|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Initial tests <ul style="list-style-type: none"> <li>Residual voltage test at nominal discharge current</li> </ul>                                                                                                                                                                                                                                                                                                                                            |
| Determination of continuous operating voltage and rated voltage.                                                                                                                                                                                                                                                                                                                                                                                              |
| Preheating to start temperature as per 8.5.2.3                                                                                                                                                                                                                                                                                                                                                                                                                |
| With prior duty (4 new samples) (only for DH arresters) <ul style="list-style-type: none"> <li>Rated thermal charge transfer, <math>Q_{th}</math>, within one minute by two lightning current impulses 8/20 <math>\mu</math>s according to 8.5.3</li> <li>Application of test voltage and duration according to TOV curve (within 100 ms)</li> <li>Application of continuous operating voltage for at least 30 min (until pass or fail is evident)</li> </ul> |
| Without prior duty (2 new samples) <ul style="list-style-type: none"> <li>Application of test voltage and duration according to TOV curve</li> <li>Application of continuous operating voltage for at least 30 min (until pass or fail is evident)</li> </ul>                                                                                                                                                                                                 |
| Test evaluation <ul style="list-style-type: none"> <li>Thermal recovery</li> <li>No physical damage</li> <li>Change of residual voltage at nominal discharge current within <math>\pm 5\%</math></li> <li>Power-frequency sparkover voltage test shall not be below claimed sparkover value</li> </ul>                                                                                                                                                        |

IEC

**Figure 4 – Test procedure to verify the power frequency versus time characteristic (TOV test)**

## 8.6.2 Test samples

The test samples shall fulfil the requirements in 7.2.

The test samples shall be complete arresters with rated voltages of 3 kV to 12 kV may be used provided the arrester's cooling rate represents the slowest cooling rate for all ratings of the design.

A total of six samples shall be tested as follows:

- “with prior duty” – one sample in each of the four ranges listed in 8.6.4.2.
- “without prior duty” – one sample in each of two ranges selected from the list in 8.6.4.2.

For a given type and design arrester, when various size MO resistors are used, the MO resistors selected for the TOV test section shall have the minimum material volume per  $U_c$ .

## 8.6.3 Initial measurements

An initial measurement of residual voltage test shall be made at nominal discharge current.

## 8.6.4 Test procedure

### 8.6.4.1 General

The test sample shall be connected to a power supply having a frequency within the range of 48 Hz to 62 Hz. Nominal test frequency (50 Hz or 60 Hz) shall be stated with published data. The peak values of power-frequency voltage shall be measured at the arrester terminals during the overvoltage. The minimum measured peak value divided by  $\sqrt{2}$  is the per-unit value that shall be used for data display referenced to rated voltage.

Care shall be taken in the case of a weak voltage source. Distortion of the voltage (flat peak) under severe non-linear current loading may lead to much higher energy injection at a given peak voltage level compared to the situation for an ideally sinusoidal voltage shape. It is therefore recommended to use a voltage source of a short-circuit current of at least 3 kA in order to avoid unrealistically high energy injection to the sample at a given peak voltage level.

The tests shall be performed in still air at  $20\text{ °C} \pm 15\text{ K}$  on thermally prorated sections. The samples shall be heated for a time sufficient to obtain thermal equilibrium, and the MO resistors shall be at a temperature of at least  $60\text{ °C}$ . It shall be demonstrated by adequate methods that the start temperature requirement is fulfilled at the beginning of the thermal recovery parts of the test.

#### 8.6.4.2 “With prior duty” test

This test is applicable to arresters of  $I_n = 10\text{ kA}$  only. Four new test samples shall be tested “with prior duty”. One sample each shall be tested in the ranges (in seconds) given below:

- 1) 0,1 to 1
- 2) 1,1 to 10
- 3) 10,1 to 100
- 4) 101 to 3 600

The manufacturer shall publish TOV data for conditions “with prior duty” for each of the four listed time periods. The prior duty consists of injection of the thermal charge rating  $Q_{th}$ . The test procedure shall be the procedure given in 8.5.2.3, where the rated voltage is replaced by the specified TOV. The charge (in C), respectively, shall be measured and shall be stated with the relevant published prior duty TOV data.

#### 8.6.4.3 “Without prior duty” test

This test is applicable to arresters of all nominal discharge currents. Two new test samples shall be tested “without prior duty”. The manufacturer shall publish TOV data for conditions “without prior duty” for two of the four time periods listed in 8.6.4.2. One new sample in each of two non-adjacent time ranges selected from this list shall be tested. Immediately after the sample's overvoltage, the continuous operating voltage (see 7.2) shall be applied for a minimum of 30 min. MO resistor temperature, resistive component of current or power dissipation shall be monitored until the measured value is appreciably reduced (success) or a thermal runaway condition is evident (failure).

#### 8.6.5 Test evaluation

A sample shall be considered passed if all the following criteria are met:

- thermal recovery has been demonstrated;
- no physical damage is evident;
- any change of the residual voltage at nominal discharge current before and after the test is within  $\pm 5\%$ ;
- power frequency sparkover voltage test shall not be below claimed sparkover value.

The manufacturer's published curve has been verified when all six samples have been tested at TOV voltages and corresponding durations that are equal to or greater than the values indicated on the curve, and all samples have passed the evaluation criteria. All test points shall be displayed on the curve.

## 8.7 Tests of arrester disconnectors

### 8.7.1 General

The purpose of the disconnector test is to verify that the disconnector of an arrester can withstand all stresses related to their application in arresters without operating. The test also demonstrates that the disconnector will perform according to the time-current characteristic published by the manufacturer. Furthermore the water tightness and the mechanical strength of the disconnector have to be verified (see 6.12).

These tests shall be made on arresters which are fitted with arrester disconnectors or on the disconnector assembly alone if its design is such as to be unaffected by the heating of adjacent parts of the arrester in its normally installed position. The test sample shall be mounted in accordance with the manufacturer's published recommendations using the maximum recommended size and stiffness and the shortest recommended length of connecting lead. In the absence of published recommendations, the conductor shall be hard-drawn bare copper approximately 5 mm in diameter and 30 cm long, arranged to allow freedom of movement of the disconnector/fault indicator when it operates.

### 8.7.2 Operating withstand test

#### 8.7.2.1 General

For disconnectors designed for attachment to an arrester or for insertion into the line or ground lead as an accessory, a charge transfer test and an operating duty test shall be made either separately or in conjunction with tests on arrester samples. For arresters with built-in disconnectors, the tests shall be made at the same time as the tests on the arresters. The disconnectors shall withstand the tests without operating.

#### 8.7.2.2 Test to verify the repetitive charge transfer rating $Q_{rs}$

This test shall be made in accordance with 8.4, with charge transfer values corresponding to the highest classification of arresters with which the disconnector is designed to be used. The test shall be made with lightning impulse currents 8/20  $\mu$ s. The test shall be made on three samples with the same charge as specified for the arrester (see 8.4.4).

#### 8.7.2.3 Operating duty test

This test shall be made in accordance with 8.5 with the sample disconnector in series with a test sample of the arrester design. The test shall be made on three samples with the same thermal charge rating as specified for the arrester.

#### 8.7.2.4 Test evaluation

The tests shall be considered passed if

- there is no operation of any sample during the testing of 8.7.2.2 and 8.7.2.3

and

- either
  - the resistance or capacitance of the grading elements have not changed by more than 20 %
- or
- if each of the samples used for the tests of 8.7.2.2 and 8.7.2.3 successfully operates in a subsequent test of operation when conducting a current of 20 A rms symmetrical



### 8.7.3 Disconnecter operation

#### 8.7.3.1 Time-versus-current test

An operation test shall be made on arrester disconnectors to determine a time-current characteristic; that is, the relation between the time in seconds and the current in rms symmetrical amperes required to cause the disconnector to operate. It is permissible for the actual operation of the disconnector to occur after the current has ceased.

Data for a time-versus-current curve shall be obtained at three different symmetrically initiated current levels with five samples each – 20 A, 200 A and 800 A RMS  $\pm 10\%$  – flowing through test sample disconnectors with or without arresters as required by 8.7.1. If lower currents are claimed they shall be tested (e.g. 5 A). For tests on disconnectors affected by internal heating of the associated arresters, the MO resistors in the arrester shall be bypassed with a bare copper wire 0,08 mm to 0,13 mm in diameter in order to start the internal arcing.

The test voltage may be any convenient value so long as it is sufficient to maintain full current flow in the arc over the arrester elements and sufficient to cause and maintain arcing of any gaps upon which operation of the disconnector may depend. The test voltage shall not exceed the rated voltage of the lowest rated arrester with which the disconnector is designed to be used.

Because the disconnector is not a fault-clearing device, the test circuits shall include devices with interrupting capabilities. An opening device such as a fuse or switch may be used with provision for adjusting the duration of current through the test sample.

NOTE One method of preparing the test circuit is to first adjust the parameters of the test circuit with the test sample temporarily shunted by a link of negligible impedance to produce the required value of current. A closing switch can be timed to close the circuit within a time corresponding to a few degrees of voltage crest to produce approximately symmetrical current.

The RMS value of current through the specimen and the duration to the first movement of the disconnector shall be plotted for all the samples tested. The time-versus-current characteristic curve of the disconnector shall be drawn as a smooth curve through the points representing maximum duration.

Depending on the test setup and the amplitude of the test current the arc will not distinguish after disconnector operation. In this case the time-versus-current curve test shall be made by subjecting the test samples to controlled durations of current flow to determine the minimum duration for each of the three current levels which will consistently result in successful operation of the disconnector. For the points to be used for the time-versus-current curve, successful operation of the disconnector shall occur in five tests out of five trials, or, if one unsuccessful test occurs, five additional tests at the same current level and duration shall result in successful operations.

#### 8.7.3.2 Evaluation of disconnector performance

There shall be clear evidence of effective and permanent disconnection by the device. If there is no clear evidence of effective and permanent disconnection by the device, a power-frequency voltage equal to 1,2 times the rated voltage of the highest rated arrester with which the disconnector is designed to be used, shall be applied for 1 min without current flow in excess of 1mA RMS. At each value of current, the established characteristic curve shall have a time value that is equal to or lower than that shown in manufacturer's published data.

#### **8.7.4 Mechanical tests**

##### **8.7.4.1 General**

Bending moment, tensile load and torsional load tests shall be performed on disconnectors used with NGLA. For arresters other than NGLA these tests may be performed on agreement between user and manufacturer.

NOTE Typically, disconnectors used on these distribution class arresters would be subjected to very small loading due to weight of connecting leads, and would therefore not be subject to this test. However, disconnectors might be exposed to torque or other loads during installation even though mechanical stress in service is negligible.

##### **8.7.4.2 Bending moment test**

The test shall be made on five new samples. On each sample, the bending load shall be increased smoothly until breaking occurs within 30 s to 90 s. The test is passed if the values of breaking load exceed the value specified by the manufacturer. If one sample fails to reach the specified breaking value, five additional samples shall be tested successfully.

##### **8.7.4.3 Tensile load test**

The test shall be made on five new samples. On each sample, the tensile load shall be increased smoothly until breaking occurs within 30 s to 90 s. The test is passed if the values of breaking load exceed the value specified by the manufacturer. If one sample fails to reach the specified breaking value, five additional samples shall be tested successfully.

##### **8.7.4.4 Torsional load test**

The test shall be made on five new samples. On each sample, the torsional load shall be increased smoothly until breaking occurs within 30 s to 90 s. The test is passed if the values of breaking load exceed the value specified by the manufacturer. If one sample fails to reach the specified breaking value, five additional samples shall be tested successfully.

#### **8.7.5 Temperature cycling and seal pumping test**

A temperature cycling test shall be made on 10 new samples, in accordance with 8.11.3.2, followed by a seal pumping test on each sample.

In the seal pumping test the test samples shall be uniformly heated to  $60\text{ °C} \pm 3\text{ °C}$  and maintained at that temperature for a minimum of 1 h. The samples shall then be placed in a cold water bath having a temperature of  $4\text{ °C} \pm 3\text{ °C}$  for a minimum of 2 h. The transfer time between the hot and cold media shall be not more than 5 min. The test cycle shall be performed 10 times. The cold water bath shall have a water weight at a minimum of 10 times the weight of the test samples.

Within 24 h after having reached ambient temperature the resistance or capacitance of the grading element of each sample shall be measured and the samples shall be opened for visual inspection. The disconnectors shall have passed the tests if no moisture is found within the test samples upon visual examination of the internal parts and surfaces and if the resistance or capacitance of the grading element has not changed by more than 20 %.

#### **8.8 Power-frequency voltage sparkover tests**

Dry and wet tests shall be made on three samples of complete arresters of each voltage rating tested. The performance for other voltage ratings of the same design within  $\pm 20\%$  (or 3 kV, whichever is greater) of a test sample rating can be determined by adjusting the voltage level in proportion to the voltage ratings. The voltage applied to the arrester shall be switched on at a value low enough to avoid sparkover of the arrester by the resulting switching surge and raised rapidly at a uniform rate until sparkover of the series gap occurs. The time during which the voltage may exceed the rated voltage of the arrester shall be in the

range of 2 s to 5 s when testing arresters using grading resistors which may be damaged by overheating if the applied voltage exceeds the rated voltage for too long. After sparkover, the test voltage shall be switched off as rapidly as possible, preferably by automatic tripping and in any case within 0,5 s.

The load imposed on the testing circuit by a surge arrester having non-linear grading resistors of high conductivity gives rise to harmonics and the test circuit shall have a sufficiently low impedance to maintain the waveform of the voltage across the specimen within the limits specified in IEC 60060-1 and IEC 60060-2.

The voltage shall be applied not less than five times with an interval of about 10 s between successive applications.

The average sparkover value of the five tests is adopted as the power frequency sparkover voltage for purposes of comparison of tests made before and after other type tests.

## **8.9 Short-circuit tests**

### **8.9.1 General**

All arresters shall be tested to show that arrester failure does not result in a violent shattering of the arrester housing, and that self-extinguishing of open flames (if any) occurs within a defined period of time. Each arrester type is tested with up to four values of short-circuit currents. If the arrester is equipped with some other arrangement as a substitute for a conventional pressure relief device, this arrangement shall be included in the test.

The frequency of the short-circuit test current supply shall be between 48 Hz and 62 Hz.

With respect to the short-circuit current performance, it is important to distinguish between two designs of surge arresters.

- “Design A” arresters have a design in which a gas channel runs along the entire length of the arrester unit and fills  $\geq 50$  % of the internal volume not occupied by the internal active parts.
- “Design B” arresters are of a solid design with no enclosed volume of gas or having an internal gas volume filling  $< 50$  % of the internal volume not occupied by the internal active parts.

NOTE 1 Typically, “Design A” arresters are porcelain-housed arresters, or polymer-housed arresters with a composite hollow insulator which are equipped either with pressure-relief devices, or with prefabricated weak spots in the composite housing which burst or flip open at a specified pressure, thereby decreasing the internal pressure.

Typically, “Design B” arresters do not have any pressure relief device and are of a solid type with no enclosed volume of gas. If the MO resistors fail electrically, an arc is established within the arrester. This arc causes heavy evaporation and possibly burning of the housing and/or internal material. These arresters' short-circuit performance is determined by their ability to control the cracking or tearing-open of the housing due to the arc effects, thereby avoiding violent shattering.

NOTE 2 “Active parts” in this context are the MO resistors and any metal spacers directly in series with them.

NOTE 3 Following agreement between the manufacturer and the user, the test procedure can be modified to include, for example, a number of reclosing operations, with the procedure and acceptance criteria being agreed upon between the manufacturer and the user.

### **8.9.2 Preparation of the test samples**

#### **8.9.2.1 General**

Depending on the type of arrester and test voltage, different requirements apply with regard to the number of test samples, initiation of short-circuit current and amplitude of the first short-circuit current peak. Table 6 shows a summary of these requirements.

For the high-current tests, the test samples shall be the longest arrester unit used for the design with the highest rated voltage of that unit used for each different arrester design.

For the low-current test, the test sample shall be an arrester unit of any length with the highest rated voltage of that unit used for each different arrester design. Figure 5 shows different examples of arrester units.

### 8.9.2.2 “Design A” arresters

The samples shall be prepared with means for conducting the required short-circuit current using a fuse wire. The fuse wire shall be in direct contact with the MO resistors and be located as far away as possible from the gas channel and shall short-circuit the entire internal active part, as illustrated in Figure 6 for different possible constructions of Design B arresters. The actual location of the fuse wire in the test shall be reported in the test report.

Fuse wire along surface of MO resistors; located as far away as possible from the gas channel. The fuse wire material and size shall be selected so that, for the high and reduced short-circuit current tests, the wire will melt within the first 30 electrical degrees after initiation of the test current. For the low short-circuit current test, there is no limitation on time to melt.

In order to have melting of the fuse wire within the specified time limit and create a suitable condition for arc ignition, it is generally recommended that a fuse wire of a low resistance material (for example copper, aluminium or silver) with a diameter of about 0,2 mm to 0,5 mm be used. Higher fuse-wire cross-sections are applicable to surge arrester units prepared for higher short-circuit test currents. When there are problems in initiating the arc, a fuse wire of larger size but with a diameter not exceeding 1,5 mm, may be used since it will help arc establishment. In such cases, a specially prepared fuse wire, having a larger cross-section along most of the arrester height with a short thinner section in the middle, may also help.

“Design A” arresters with polymeric sheds which are applied to a primary housing of porcelain or other hollow insulator that is as brittle as ceramic, shall be considered and tested as porcelain-housed arresters.

The test samples shall be filled with the surrounding medium (gas) used in the arresters.

### 8.9.2.3 “Design B” arresters

The samples shall be prepared with means for conducting the required short-circuit current using a fuse wire. The fuse wire shall be in direct contact with the MO resistors and be located as far away as possible from the gas channel and shall short-circuit the entire internal active part, as illustrated in Figure 7 for different possible constructions of Design B arresters. The actual location of the fuse wire in the test shall be reported in the test report.

The fuse wire material and size shall be selected so that, for the high and reduced short-circuit current tests, the wire will melt within the first 30 electrical degrees after initiation of the test current. For the low short-circuit current test, there is no limitation on time to melt.


In order to have melting of the fuse wire within the specified time limit and create a suitable condition for arc ignition, it is generally recommended that a fuse wire of a low resistance material (for example copper, aluminium or silver) with a diameter of about 0,2 mm to 0,5 mm be used. Higher fuse-wire cross-sections are applicable to surge arrester units prepared for higher short-circuit test currents. When there are problems in initiating the arc, a fuse wire of larger size but with a diameter not exceeding 1,5 mm, may be used since it will help arc establishment. In such cases, a specially prepared fuse wire, having a larger cross-section along most of the arrester height with a short thinner section in the middle, may also help.

In case of an internal gas volume, the test samples shall be filled with the surrounding medium (gas) used in the arresters.

Table 6 – Test requirements for porcelain housed arresters


|            | Required number of test samples | Initiation of short-circuit current                                                           | Ratio of first current peak value to r.m.s. value of required short-circuit current taken from Table 7 |                                                        |                               |                             |
|------------|---------------------------------|-----------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------|--------------------------------------------------------|-------------------------------|-----------------------------|
|            |                                 |                                                                                               | Test voltage: 77 % to 107 % of $U_r$                                                                   |                                                        | Test voltage: < 77 % of $U_r$ |                             |
|            |                                 |                                                                                               | Rated short-circuit current                                                                            | Reduced short-circuit current                          | Low short-circuit current     | Rated short-circuit current |
| "Design A" | 4                               | Fuse wire along surface of MO resistors; within, or as close as possible to, the gas channel  | Prospective: $\geq 2,5$<br>Actual: no requirement                                                      | Prospective: $\geq \sqrt{2}$<br>Actual: no requirement | Actual: $\geq \sqrt{2}$       | Actual: $\geq 2,5$          |
| "Design B" | 4                               | Fuse wire along surface of MO resistors; located as far away as possible from the gas channel | Prospective: $\geq \sqrt{2}$<br>Actual: no requirement                                                 | Prospective: $\geq \sqrt{2}$<br>Actual: no requirement | Actual: $\geq \sqrt{2}$       | Actual: $\geq \sqrt{2}$     |

IECNORM.COM : Click to view the full PDF of IEC 60099-6:2019




IEC

Figure 5 – Examples of arrester units



IEC

**Figure 6 – Examples of fuse wire locations for “Design A” arresters**



IEC


**Figure 7 – Examples of fuse wire locations for “Design B” arresters**

### 8.9.3 Mounting of the test sample

For a base-mounted arrester, the mounting arrangement is shown in Figure 8. The distance to the ground from the insulating platform and the conductors shall be as indicated in this figure.



Dimensions in metres



NOTE All leads and venting systems in the same plane.

**Figure 8 – Short-circuit test setup for porcelain-housed arresters**

For non-base-mounted arresters (for example, pole-mounted arresters), the test sample shall be mounted on a non-metallic pole using mounting brackets and hardware typically used for real service installation. For the purpose of the test, the mounting bracket shall be considered as a part of the arrester base. In cases where the foregoing is at variance with the manufacturer's instructions, the arrester shall be mounted in accordance with the installation recommendations of the manufacturer. The entire lead between the base and the current sensor shall be insulated for at least 1 000 V. The top end of the test sample shall be fitted with the base assembly of the same design of an arrester or with the top cap.

The mounting of the arrester during the short-circuit test and, more specifically, the routing of the conductors shall represent the most unfavourable condition in service.

NOTE The routing shown in Figure 8 is the most unfavourable to use during the initial phase of the test before venting occurs (especially in the case of a surge arrester fitted with a pressure relief device). Positioning the sample as shown in Figure 8, with the venting ports facing in the direction of the test source, may cause the external arc to be swept in closer proximity to the arrester housing than otherwise. As a result, a thermal shock effect may cause excessive chipping and shattering of porcelain weather sheds, as compared to the other possible orientations of the venting ports.

## 8.9.4 High-current short-circuit tests

### 8.9.4.1 General

A total of three samples shall be tested at currents based on selection of a rated short-circuit current selected from Table 7. All three samples shall be prepared according to 8.9.2 and mounted according to 8.9.3.

Tests shall be made in a single-phase test circuit, preferably with an open-circuit test voltage of 77 % to 107 % of the rated voltage of the test sample, as outlined in 8.9.4.2. However, it is expected that tests on high-voltage arresters will have to be made at laboratories which might not have the sufficient short-circuit power capability to carry out these tests at 77 % or more of the test sample rated voltage. Accordingly, an alternative procedure for making the high-



current, short-circuit tests at a reduced voltage is given in 8.9.4.3. The measured total duration of test current flowing through the circuit shall be  $\geq 0,2$  s.

**Table 7 – Required currents for short-circuit tests**

| Arrester class = nominal discharge current                                                                                                                                                                                                                                                                                                                                                                                                         | Rated short-circuit current $I_s$ | Reduced short-circuit currents $\pm 10\%$ |     | Low short-circuit current with a duration of 1 s <sup>a</sup> |
|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------|-------------------------------------------|-----|---------------------------------------------------------------|
| kA                                                                                                                                                                                                                                                                                                                                                                                                                                                 | kA                                | kA                                        |     | A                                                             |
| 10 or 5                                                                                                                                                                                                                                                                                                                                                                                                                                            | 20                                | 12                                        | 6   | $600 \pm 200$                                                 |
| 10 or 5                                                                                                                                                                                                                                                                                                                                                                                                                                            | 16                                | 6                                         | 3   | $600 \pm 200$                                                 |
| 10, 5, or 2,5                                                                                                                                                                                                                                                                                                                                                                                                                                      | 10                                | 6                                         | 3   | $600 \pm 200$                                                 |
| 10, 5, or 2,5                                                                                                                                                                                                                                                                                                                                                                                                                                      | 5                                 | 3                                         | 1,5 | $600 \pm 200$                                                 |
| 10, 5 or 2,5                                                                                                                                                                                                                                                                                                                                                                                                                                       | 2,5 kA                            | –                                         | –   | $600 \pm 200$                                                 |
| 10, 5 or 2,5                                                                                                                                                                                                                                                                                                                                                                                                                                       | 1 kA                              | –                                         | –   | Amplitude and time on agreement between user and manufacturer |
| 10, 5 or 2,5                                                                                                                                                                                                                                                                                                                                                                                                                                       | $< 1$ kA <sup>b</sup>             | –                                         | –   | Amplitude and time on agreement between user and manufacturer |
| <sup>a</sup> For surge arresters to be installed in resonant earthed or unearthed neutral systems, the increase of the test duration to longer than 1 s, up to 30 min, may be permitted after agreement between the manufacturer and the user. In this case the low short-circuit current shall be reduced to $50 \text{ A} \pm 20 \text{ A}$ , and the test sample and acceptance criteria shall be agreed between the manufacturer and the user. |                                   |                                           |     |                                                               |
| <sup>b</sup> High current tests are not required in this case.                                                                                                                                                                                                                                                                                                                                                                                     |                                   |                                           |     |                                                               |
| NOTE If an existing arrester is qualified for one of the rated short-circuit currents in this table, it is deemed to have passed the test for any value of rated current lower than this one.                                                                                                                                                                                                                                                      |                                   |                                           |     |                                                               |

If an existing type of arrester already qualified for one of the rated currents in this table is being qualified for a higher rated-current value available in the table, it should be tested only at the new rated value. Any extrapolation can only be extended by two steps of rated short-circuit current.

If a new arrester type is to be qualified for a higher rated current value than available in this table, it shall be tested at the proposed rated current, at 50 % and at 25 % of this rated current.

#### 8.9.4.2 High-current tests at full voltage (77 % to 107 % of rating)

The prospective current shall first be measured by making a test with the arrester short-circuited or replaced by a solid link of negligible impedance.

The duration of such a test may be limited to the minimum time required to measure the peak and symmetrical component of the current waveform.

For “Design B” arresters tested at rated short-circuit current, the peak value of the first half-cycle of the prospective current shall be at least  $\sqrt{2}$  times the RMS value of the rated short circuit current .

For all the reduced short-circuit currents, the RMS value shall be in accordance with Table 7 and the peak value of the first half-cycle of the prospective current shall be at least  $\sqrt{2}$  times the RMS value of this current.

The solid shorting link shall be removed after checking the prospective current and the arrester sample(s) shall be tested with the same circuit parameters.

NOTE The resistance of the restricted arc inside the arrester might reduce the RMS, symmetrical component and the peak value of the measured current. This does not invalidate the test, since the test is being made with at least normal service voltage and the effect on the test current is the same as would be experienced during a fault in service.

The X/R ratio of the test circuit impedance, without the arrester connected, should preferably be at least 15. In cases where the test circuit impedance X/R ratio is less than 15, the test voltage may be increased or the impedance may be reduced, in such a way that,

- for the rated short-circuit current, the peak value of the first half-cycle of the prospective current is equal to, or greater than, 2,5 times the required test current level;
- for the reduced current level tests, the tolerances in Table 7 are met.

#### 8.9.4.3 High-current test at less than 77 % of rated voltage

When tests are made with a test circuit voltage <77 % of the rated voltage of the test samples, the test circuit parameters shall be adjusted in such a way that the RMS value of the symmetrical component of the actual arrester test current shall equal or exceed the required test current selected from Table 7.

For “Design B” arresters tested at rated short-circuit current, the peak value of the first half-cycle of the actual arrester test current shall be at least  $\sqrt{2}$  times the RMS value of the rated short circuit current.

For all the reduced short-circuit currents the RMS value shall be in accordance with Table 7 and the peak value of the first half-cycle of the actual arrester test current shall be at least  $\sqrt{2}$  times the RMS value of this current.

#### 8.9.5 Low-current short-circuit test

The test shall be made by using any test circuit that will produce a current through the test sample of  $600 \text{ A} \pm 200 \text{ A}$  RMS, measured at approximately 0,1 s after the start of the short circuit current flow. The current shall flow for at least 1 s after the fuse wire melts.

Refer to 8.9.6 with regard to handling an arrester that fails to vent.

#### 8.9.6 Evaluation of test results

The test is considered successful if the following three criteria are met.

- a) No violent shattering. Structural failure of the sample is permitted as long as criteria b) and c) are met.
- b) No parts of the test sample shall be allowed to be found outside the enclosure, except for
  - fragments, less than 60 g each, of ceramic material such as MO resistors or porcelain;
  - pressure relief vent covers and diaphragms;
  - soft parts of polymeric materials.
- c) The arrester shall be able to self-extinguish open flames within 2 min after the end of the test. Any ejected part (in or out of the enclosure) shall also self-extinguish open flames within 2 min. A shorter duration of self-extinguishing open flames for ejected parts may be agreed upon between the manufacturer and the user.

If the arrester has not visibly vented at the end of the test, caution should be exercised, as the housing may remain pressurized after the test. This is applicable to all levels of test current, but is of particular relevance to the low-current, short-circuit tests.

For arresters to be used in applications where mechanical integrity and a strength is required after failure, different test procedures and evaluations may be established between the manufacturer and the user (as an example, it may be required that after the tests the arrester should still be able to be lifted and removed by its top end).

## 8.10 Test of the bending moment

### 8.10.1 General

This test applies to porcelain and cast-resin housed arresters for  $U_s \leq 52$  kV for which the manufacturer claims cantilever strength. The test shall be performed on the arrester without insulating base or mounting bracket.

The complete test procedure is shown by the flow chart in Annex C.

### 8.10.2 Overview

This test demonstrates the ability of the arrester to withstand the manufacturer's declared values for bending loads. Normally, an arrester is not designed for torsional loading. If an arrester is subjected to torsional loads, a specific test may be necessary by agreement between manufacturer and user.

The test shall be performed on complete arrester units without insulating base or mounting bracket and without internal overpressure. For single-unit arrester designs, the test shall be performed on the longest unit of the design. Where an arrester contains more than one unit or where the arrester has different specified bending moments in both ends, the test shall be performed on the longest unit of each different specified bending moment, with loads determined according to C.1.

The test shall be performed in two parts that may be done in any order:

- a bending moment test to determine the mean value of breaking load (MBL);
- a static bending moment test with the test load equal to the specified short-term load (SSL), i.e. the 100 % value of C.2.

### 8.10.3 Sample preparation

One end of the sample shall be firmly fixed to a rigid mounting surface of the test equipment, and a load shall be applied to the other (free) end of the sample to produce the required bending moment at the fixed end. The direction of the load shall pass through and be perpendicular to the longitudinal axis of the arrester. If the arrester is not axi-symmetrical with respect to its bending strength, the manufacturer shall provide information regarding this non-symmetric strength, and the load shall be applied in an angular direction that subjects the weakest part of the arrester to the maximum bending moment.

### 8.10.4 Test procedure

#### 8.10.4.1 Test procedure to determine mean value of breaking load (MBL)

Three samples shall be tested. If the test to verify the SSL (see 8.10.4.2) is performed first, then samples from that test may be used for determination of MBL. The test samples need not contain the internal parts. On each sample, the bending load shall be increased smoothly until breaking occurs within 30 s to 90 s. "Breaking" includes fracture of the housing and damages that may occur to fixing device or end fittings.

The mean breaking load, MBL, is calculated as the mean value of the breaking loads for the test samples.

NOTE The housing of an arrester might splinter while under load and might present a handling hazard.

#### 8.10.4.2 Test procedure to verify the specified short-term load (SSL)

Three samples shall be tested. The test samples shall contain the internal parts. Prior to the tests, each test sample shall be subjected to a leakage check (see item d) of 9.1) and an internal partial discharge test (see item c) of 9.1). If these tests have been performed as routine tests, they need not be repeated at this time.

On each sample, the bending load shall be increased smoothly to SSL, tolerance  $\pm 5\%$ , within 30 s to 90 s. When the test load is reached, it shall be maintained for 60 s to 90 s. During this time the deflection shall be measured. Then the load shall be released smoothly and the residual deflection shall be recorded. The residual deflection shall be measured in the interval 1 min to 10 min after the release of the load.

NOTE The housing of an arrester might splinter while under load and might present a handling hazard.

#### 8.10.5 Test evaluation

The arrester shall have passed the test if

- the mean value of breaking load, MBL, is  $\geq 1,2 \times \text{SSL}$ ;
- for the SSL test
  - there is no visible mechanical damage;
  - the remaining permanent deflection is  $\leq 3 \text{ mm}$  or  $\leq 10 \%$  of maximum deflection during the test, whichever is greater;
  - the test samples pass the leakage test in accordance with item d) of 9.1;
  - the internal partial discharge level of the test samples does not exceed the value specified in 9.1 c).

#### 8.10.6 Test on insulating base and mounting bracket

If the arrester is supplied with an insulating base and/or a mounting bracket, the base and/or bracket shall be subjected to a bending test. Three samples of each shall be tested. On each sample, the bending load shall be increased smoothly to a load equivalent to the arrester SSL within 30 s to 90 s. When the test load is reached, it shall be maintained for 60 s to 90 s. Then the load shall be released smoothly.

The samples shall have passed the test if there is no visible mechanical damage.

### 8.11 Environmental tests

#### 8.11.1 General

These tests apply to porcelain and cast resin-housed arresters. The environmental tests demonstrate by accelerated test procedures that the sealing mechanism and the exposed metal combinations of the arrester are not impaired by environmental conditions.

The test shall be performed on complete arrester units of any length.

For arresters with an enclosed gas volume and a separate sealing system, the internal parts may be omitted.

Arresters whose units differ only in terms of their lengths, and which are otherwise based on the same design and material, and have the same sealing system in each unit, are considered to be the same type of arrester.

### 8.11.2 Sample preparation

Prior to the tests, the test sample shall be subjected to the leakage check of item e) of 9.1.

### 8.11.3 Test procedure

#### 8.11.3.1 General

The tests specified in 8.11.3.2 and 8.11.3.3 shall be performed on one sample in the sequence given.

#### 8.11.3.2 Temperature cycling test

The test shall be performed according to test Nb of IEC 60068-2-14.

The hot period shall be at a temperature of at least +40 °C, but not higher than +70 °C. The cold period shall be at least 85 K below the value actually applied in the hot period; however, the lowest temperature in the cold period shall not be lower than –50 °C.

- temperature change gradient: 1 K/min;
- duration of each temperature level: 3 h;
- number of cycles: 10.

#### 8.11.3.3 Salt mist test

The test shall be performed according to Clause 4 and Subclause 7.6, as applicable, of IEC 60068-2-11:1981:

- salt solution concentration: 5 % ± 1 % by weight;
- test duration: 96 h.

### 8.11.4 Test evaluation

The arrester shall have passed the tests if the sample passes the leakage check in accordance with item e) of 9.1.

## 8.12 Seal leak rate test

### 8.12.1 General

This test applies to arresters having an enclosed gas volume and a separate sealing system. The test demonstrates the gas/water tightness of the complete system.

If a routine test for seal leak rate (see item e) of 9.1) is performed with acceptance criteria at least as stringent as specified in this clause, then a type test is not required. Otherwise, a type test shall be performed on one complete arrester unit. The internal parts may be omitted. If the arrester contains units with differences in their sealing system, the test shall be performed on one unit each, representing each different sealing system.

### 8.12.2 Sample preparation

The test sample shall be new and clean.

### 8.12.3 Test procedure

The manufacturer may use any sensitive method suitable for the measurement of the specified seal leak rate.

NOTE Some test procedures are specified in IEC 60068-2-17.

#### 8.12.4 Test evaluation

The maximum seal leak rate (see C.3) shall be lower than  $1 \times 10^{-6} \text{ Pa} \times \text{m}^3/\text{s}$

#### 8.13 Test to verify the dielectric withstand of internal components

##### 8.13.1 General

The purpose of this test is to verify the internal dielectric withstand capability of an arrester even under impulse currents of amplitudes higher than nominal discharge current.

If it can be demonstrated by calculations that, for a specific arrester, the electrical field at critical locations is less than or equal to the electrical field on an arrester which has been successfully tested at higher or equal voltage, no test is required.

The test shall be performed on one test sample.

No internal temperature sensor shall be installed.

##### 8.13.2 Test procedure

The test sample shall be heated in an oven for a time sufficient to obtain thermal equilibrium to at least 60 °C. The test shall be performed within 10 minutes after removing the sample from the oven. The test consists of one application of a high-current impulse with amplitude according to Table 4.

Oscillograms of current and voltage shall be taken for the impulse application.

##### 8.13.3 Test evaluation

The sample has passed the test if all the following criteria are met:

- there is no evidence of a dielectric breakdown from the oscillograms;
- any change of the residual voltage at nominal discharge current before and after the test is within  $\pm 5 \%$ ;
- the following requirements are met:
  - if the manufacturer declares that the resistors may be removed from the test sample, a visual examination of the resistors shall be made and it shall be verified that the test has not caused puncture, flashover or cracking of the resistors.
  - if the manufacturer declares that the MO resistors cannot be removed from the test sample, the following additional test shall be performed to be sure that no damage occurred during the test:
    - 1) after the check of residual voltage at  $I_n$ , two current impulses 8/20 of an amplitude resulting in a current density of at least 0,5 kA/cm<sup>2</sup> or in 2 times  $I_n$ , whichever is lower, shall be applied to the sample. The first impulse shall be applied after sufficient time to allow the cooling of the sample to ambient temperature. The second impulse shall be applied between 50 s to 60 s after the first one. During the two impulses, the oscillograms of both voltage and current shall not reveal any breakdown.

#### 8.14 Test of internal grading components

##### 8.14.1 Test to verify long term stability under continuous operating voltage

If internal grading components such as capacitors or (non-linear) resistors are used in the arrester they shall be tested in an accelerated test to verify long term stability under continuous operating voltage. The test samples may be individual components or a stack of such components.

All material (solid or liquid) in direct contact with the grading components in the arrester shall be present during the ageing test with the same design as used in the complete arrester.

During the test, the test samples shall be placed in a temperature-controlled oven in the same surrounding medium as used in the arrester. The volume of the oven chamber shall be at least twice the volume of the test sample and the density of the medium in the chamber shall not be less than the density of the medium in the arrester.

NOTE The medium surrounding the grading components within the arrester may be subject to a modification during the normal life of the arrester due to internal partial discharges. Possible change of the medium surrounding the grading components in the field can significantly change their electrical properties.

A suitable test procedure taking into account such modifications is under consideration. During this time an alternative procedure consists in performing the test in  $N_2$  with a low oxygen concentration (less than 0,1 % in volume). This ensures that even in the total absence of oxygen, the grading components will not age.

If the manufacturer can prove that the test carried out in the open air is equivalent to that carried out in the actual medium, the ageing procedure can be carried out in the open air.

Three samples shall be tested for 1 000 h, during which the temperature shall be controlled to keep the surface of the samples at  $115\text{ °C} \pm 4\text{ K}$ . During the 1 000 h test, the samples shall be energized at a voltage corresponding to the maximum continuous operating voltage for the number of MO resistors installed in parallel to the grading components in the arrester. The impedance of the grading components shall be measured at  $20\text{ °C} \pm 15\text{ K}$  before and after the 1 000 h test.

The samples shall have passed this part of the test if

- there is no evidence of a dielectric breakdown;
- examination after the test reveals no evidence of puncture, flashover or cracking of the grading components;
- a partial discharge test at the test voltage reveal partial discharges not exceeding 10 pC;
- the change in impedance of the grading components due to the 1 000 h test is not greater than  $\pm 5\%$ .

If the samples pass the above evaluation criteria, then MO resistors, equal in number to those used in parallel to the grading components in the arrester, shall be connected in parallel to the test sample, and two 8/20 lightning impulses with peak current density of  $0,5\text{ kA/cm}^2$  in the MO resistors or 2 times  $I_n$ , whichever is lower, shall be applied to the sample. The first impulse shall be applied after sufficient time to allow the cooling of the sample to ambient temperature. The second impulse is applied between 50 s to 60 s after the first impulse. The impedance of the grading components shall be measured at  $20\text{ °C} \pm 15\text{ K}$  before and after the two impulses. The samples shall have passed the test if

- oscillograms of voltage and current taken during each impulse reveal no electrical breakdown
- the change in impedance of the grading components due to the two impulses is not greater than  $\pm 5\%$ .

#### 8.14.2 Thermal cyclic test

Three samples shall be subjected to thermal variations without voltage applied. The thermal variations consist of five 48 h cycles of heating and cooling to  $60\text{ °C}$  and  $-40\text{ °C}$  respectively. The hot and cold periods shall be maintained for at least 16 h. The test shall be conducted in air. The impedance of the grading components shall be measured at  $20\text{ °C} \pm 15\text{ K}$  before and after the thermal cycles.

The samples have passed this part of the test if



- examination after the test reveals no evidence of cracking of the grading components;
- a partial discharge test at the test voltage corresponding to the maximum continuous operating voltage for the number of MO resistors installed in parallel to the grading components in the arrester reveal partial discharges not exceeding 10 pC;
- the change in impedance of the grading components due to the thermal cycles is not greater than  $\pm 5\%$ .

If the samples pass the above evaluation criteria, then MO resistors, equal in number to those used in parallel to the grading components in the arrester, shall be connected in parallel to the test sample, and two 8/20 lightning impulses with peak current density of at least  $0,5 \text{ kA/cm}^2$  in the MO resistors shall be applied to the sample. The first impulse shall be applied after sufficient time to allow the cooling of the sample to ambient temperature. The second impulse is applied between 50 s to 60 s after the first impulse. The impedance of the grading components shall be measured at  $20^\circ\text{C} \pm 15 \text{ K}$  before and after the two impulses. The samples shall have passed the test if

- oscillograms of voltage and current taken during each impulse reveal no electrical breakdown;
- the change in impedance of the grading components due to the two impulses is not greater than  $\pm 5\%$ .

## 9 Routine tests and acceptance tests

### 9.1 Routine tests

The minimum requirement for routine tests to be made by the manufacturer shall be

- Measurement of power-frequency spark-over voltage on the arrester. The measured value shall be within a range specified by the manufacturer.
- Residual voltage test. This test is compulsory for arresters with rated voltage above 1 kV. The test may be performed either on complete arresters or assembled arrester units. The manufacturer shall specify a suitable lightning current impulse in the range between 0,01 and 2 times the nominal current at which the residual voltage is measured. If not directly measured, the residual voltage of the complete arrester is taken as the sum of the residual voltages of the MO resistors or the individual arrester units. The residual voltage for the complete arrester shall not be higher than the value specified by the manufacturer.

NOTE When 5 kA and 2,5 kA arresters below 36 kV rating are supplied in volume, the residual voltage test may be omitted in the routine tests if agreed between manufacturer and user.

- Internal partial discharge test. This test shall be performed on each arrester unit. The test sample may be shielded against external partial discharges.

The power-frequency voltage shall be increased to the rated voltage of the sample, held for 2 s to 10 s, and then decreased to 1,05 times the continuous operating voltage of the sample. At that voltage, the partial discharge level shall be measured according to IEC 60270. The measured value for the internal partial discharge shall not exceed 10 pC. Alternatively, the manufacturer may carry out the partial discharge measurement at the rated voltage or at a higher value without reducing the test voltage afterwards.

- In order to reduce test efforts during production, higher values of seal leak rate than required for type testing (see 8.13.4) may be used in this routine test for verification of correct assembly; for arrester units with an enclosed gas volume and separate sealing system, a leakage check shall be made on each unit by any sensitive method adopted by the manufacturer.
- Proper assembly of each disconnector has to be demonstrated by either measurement of resistance / capacitance or partial discharges. The values of resistance or capacitance shall be in a range specified by the manufacturer. The measured value for the partial discharge shall not exceed 10 pC.



## 9.2 Acceptance tests

### 9.2.1 Standard acceptance tests

When the purchaser specifies acceptance tests in the purchase agreement, the following tests shall be made on the nearest lower whole number to the cube root of the number of arresters to be supplied:

- a) Measurement of power-frequency spark-over voltage on the arrester. The measured value shall be within a range specified by the manufacturer.
- b) Lightning impulse residual voltage on the arrester at nominal discharge current if possible or at a current value chosen according to 8.3. In this case, the virtual time to half-value is less important and need not be complied with.

For a multi-unit arrester, measurements may be made on individual units of the arrester. The residual voltage of the complete arrester is taken as the sum of the residual voltages of the individual arrester units.

The residual voltage for the complete arrester shall not be higher than a value specified by the manufacturer.

- c) Internal partial discharge test

The test shall be performed on the complete arrester or, for a multi-unit arrester, on the individual units of the arrester. The test sample may be shielded against external partial discharges.

The power-frequency voltage shall be increased to the rated voltage of the sample, held for 2 s to 10 s, and then decreased to 1,05 times the continuous operating voltage of the sample. At that voltage, the partial discharge level shall be measured according to IEC 60270. The measured value for the internal partial discharge shall not exceed 10 pC.

Any alteration in the number of test samples or type of test shall be negotiated between the manufacturer and the user.

### 9.2.2 Special thermal stability test

The following test requires additional agreement between manufacturer and user prior to the commencement of arrester assembly (see 6.6).

This test shall be performed on three sections using MO resistors taken from current routine production and having the same dimensions and characteristics as those of the arresters under test. The test consists of the thermal recovery portion of the operating duty test (see 8.5.2.3).

MO resistor temperature or resistive component of current or power dissipation shall be monitored during the power frequency voltage application to prove thermal stability. The test is passed if thermal stability occurs in all three samples (see 8.5.2.4). If one sample fails, agreement shall be reached between the manufacturer and the user regarding any further tests.

## 10 Test requirements on polymer-housed surge arresters

Clauses 1 to 5 and Clause 7 apply in their entirety to polymer-housed arresters. Many of the requirements in Clause 6 and many of the tests prescribed in Clause 8 also apply without change to polymer-housed arresters. Where there is a variation, of any degree, from the requirements of Clauses 6 and 8, that variation is provided here for polymer-housed arresters.

### 10.1 Scope

Clause 1 applies without modification.

## 10.2 Normative references

Clause 2 applies without modification.

## 10.3 Terms and definitions

Clause 3 applies without modification.

## 10.4 Identification and classification

Clause 4 applies without modification.

## 10.5 Standard ratings and service conditions

Clause 5 applies without modification.

## 10.6 Requirements

Clause 6 applies except as follows:

### 10.6.11 Short-circuit performance

*Replacement of Subclause 6.11:*

The manufacturer shall declare a short-circuit current rating for each family of arresters. Only for applications with expected short-circuit currents below 1 kA the rated value “zero” may be claimed. In this case “0” shall be indicated on the name plate. In any case, the arrester shall be subjected to a short-circuit test according to 10.8.9 to show that it will not fail in a manner that causes violent shattering of the housing and that self-extinguishing of open flames (if any) occurs within a defined period of time.

#### 10.6.15.2 Bending moment

*Replacement of Subclause 6.15.2:*

The arrester shall be able to withstand the manufacturer's declared values for bending loads (see 10.8.10).

NOTE 1 Forces other than those applied by physical connections might affect the mechanical loading of an arrester; for example: wind, ice and electromagnetic forces.

NOTE 2 Unlike porcelain housed arresters, polymer-housed arresters might show mechanical deflections in service

Surge arresters enclosed within their package should withstand the transportation loads specified by the user in accordance with IEC 60721-3-2, but not less than Class 2M1.

#### 10.6.15.4 Insulating base

*Replacement of Subclause 6.15.4:*

When an arrester is fitted with an insulating base, this device shall withstand the following test without any damage, which could affect its normal function:

- test of the bending moment (see 8.10.6).

## 10.7 General testing procedure

Clause 7 applies without modification.

## 10.8 Type tests (design tests)

### 10.8.1 General

*Amendment of Subclause 10.8.1:*

Type tests shall be performed as defined in Clause 8, except for specific changes indicated below (list numbers refer to numbers in rows of Table 3):

10) Environmental tests do not apply

In addition, the following test is to be made for polymer-housed arresters intended for outdoor use

14) Weather ageing test (see 10.8.15)

### 10.8.2 Insulation withstand tests

Subclause 8.2 applies without modification.

### 10.8.3 Impulse protective level tests

Subclause 8.3 applies without modification.

### 10.8.4 Test to verify the repetitive charge transfer rating, $Q_{rs}$

Subclause 8.4 applies without modification.

### 10.8.5 Operating Duty tests

Subclause 8.5 applies except as follows:

#### 10.8.5.2.4 Test evaluation

*Replacement of Subclause 8.5.2.4:*

The test shall be considered passed if all the following criteria are met:

- thermal recovery has been demonstrated;
- any change of the residual voltage at nominal discharge current before and after the test is within  $\pm 5\%$ ;
- the following requirements are met:
  - if the manufacturer declares that the resistors may be removed from the test sample, a visual examination of the resistors shall be made and it shall be verified that the test has not caused puncture, flashover or cracking of the resistors.
  - if the manufacturer declares that the MO resistors cannot be removed from the test sample for visual examination, the following additional test shall be performed to be sure that no damage occurred during the test:
    - i) after the check of residual voltage at  $I_n$ , two further current impulses 8/20 at  $I_n$  shall be applied to the sample. The first impulse shall be applied after sufficient time to allow the cooling of the sample to ambient temperature. The second impulse shall be applied between 50 s to 60 s after the first one. During the two impulses, the oscillograms of both voltage and current shall not reveal any breakdown. The variation of the residual voltage between the initial measurement and the last impulse shall not be greater than  $\pm 5\%$ .

### 10.8.6 Power frequency voltage-versus-time test

Subclause 8.6 applies, except as follows:

#### 10.8.6.5 Test evaluation

*Replacement of Subclause 8.6.5:*

A sample shall be considered passed if all the following criteria are met:

- thermal recovery has been demonstrated;
- any change of the residual voltage at nominal discharge current before and after the test is within  $\pm 5\%$ .
- the following requirements are met:
  - if the manufacturer declares that the resistors may be removed from the test sample, a visual examination of the resistors shall be made and it shall be verified that the test has not caused puncture, flashover or cracking of the resistors.
  - If the manufacturer declares that the MO resistors cannot be removed from the test sample for visual examination, the following additional test shall be performed to be sure that no damage occurred during the test:
    - i) after the check of residual voltage at  $I_n$ , two current impulses 8/20 of an amplitude resulting in a current density of at least  $0,5 \text{ kA/cm}^2$  or in 2 times  $I_n$ , whichever is lower, shall be applied to the sample. The first impulse shall be applied after sufficient time to allow the cooling of the sample to ambient temperature. The second impulse shall be applied between 50 s to 60 s after the first one. During the two impulses, the oscillograms of both voltage and current shall not reveal any breakdown.

The manufacturer's published curve has been verified when all six samples have been tested at TOV voltages and corresponding durations that are equal to or greater than the values indicated on the curve, and all samples have passed the evaluation criteria. All test points shall be displayed on the curve.

#### 10.8.7 Tests of arrester disconnectors

Subclause 8.7 applies without modification.

#### 10.8.8 Power frequency voltage sparkover tests

Subclause 8.8 applies without modification.

#### 10.8.9 Short-circuit tests

Subclause 8.9 applies, except as follows:

##### 10.8.9.2 Preparation of the test samples

*Replacement of Subclause 8.9.2:*

Depending on the type of arrester and test voltage, different requirements apply with regard to the number of test samples, initiation of short-circuit current and amplitude of the first short-circuit current peak. Table 8 shows a summary of these requirements.

For the high-current tests, the test samples shall be the longest arrester unit used for the design with the highest rated voltage of that unit used for each different arrester design.

For the low-current test, the test sample shall be an arrester unit of any length with the highest rated voltage of that unit used for each different arrester design. Figure 5 shows different examples of arrester units.

### 10.8.9.2.3 “Design B” arresters

#### *Replacement of Subclause 8.9.2.3:*

The samples shall be prepared with means for conducting the required short-circuit current using a fuse wire across the internal gap. The fuse wire shall be in direct contact with the gap structure as illustrated in Figure 7 for different possible constructions of Design B arresters. The actual location of the fuse wire in the test shall be reported in the test report.

The overvoltage shall be run on completely assembled test units. No physical modification shall be made to the units between pre-failing and the actual short-circuit current test.

The overvoltage given by the manufacturer shall be a voltage exceeding 1,15 times  $U_c$ . The voltage shall cause the arrester to fail within  $(5 \pm 3)$  min. The MO resistors are considered to have failed when the voltage across the MO resistors falls below 10 % of the originally applied voltage. The short-circuit current of the pre-failing test circuit shall not exceed 30 A.

The time between pre-failure and the rated short-circuit current test shall not exceed 15 min.

The pre-failure can be achieved by either applying a voltage source or a current source to the samples.

- Voltage source method: the initial current should typically be in the range 5-10 mA/cm<sup>2</sup>. The short-circuit current should typically be between 1 A and 30 A. The voltage source need not be adjusted after the initial setting, although small adjustments might be necessary in order to fail the MO resistors in the given time range.
- Current source method: Typically a current density of around 15 mA/cm<sup>2</sup> with a variation of  $\pm 50$  %, will result in failure of the MO resistors in the given time range. The short-circuit current should typically be between 10 A and 30 A. The current source need not be adjusted after the initial setting, although small adjustments might be necessary in order to fail the MO resistors in the given time range.


**Table 8 – Test requirements for polymer-housed arresters**

|            | Required number of test samples | Initiation of short-circuit current                        | Ratio of first current peak value to r.m.s. value of required short-circuit current taken from Table 7 |                                                        |                           |                               |                               |                           |
|------------|---------------------------------|------------------------------------------------------------|--------------------------------------------------------------------------------------------------------|--------------------------------------------------------|---------------------------|-------------------------------|-------------------------------|---------------------------|
|            |                                 |                                                            | Test voltage: 77 % to 107 % of $U_r$                                                                   |                                                        |                           | Test voltage: < 77 % of $U_r$ |                               |                           |
|            |                                 |                                                            | Rated short-circuit current                                                                            | Reduced short-circuit current                          | Low short-circuit current | Rated short-circuit current   | Reduced short-circuit current | Low short-circuit current |
| "Design B" | 4                               | Pre-failing by constant voltage or constant current source | Prospective: $\geq \sqrt{2}$<br>Actual: no requirement                                                 | Prospective: $\geq \sqrt{2}$<br>Actual: no requirement | Actual: $\geq \sqrt{2}$   | Actual: $\geq \sqrt{2}$       | Actual: $\geq \sqrt{2}$       | Actual: $\geq \sqrt{2}$   |

### 10.8.9.3 Mounting of the test sample

#### *Replacement of Subclause 8.9.3:*

For a base-mounted arrester, the mounting arrangement is shown in Figure 9. The distance to the ground from the insulating platform and the conductors shall be as indicated in this figure.



NOTE All leads and venting systems in the same plane.

**Figure 9 – Short-circuit test setup for polymer-housed arresters**

For non-base-mounted arresters (for example, pole-mounted arresters), the test sample shall be mounted on a non-metallic pole using mounting brackets and hardware typically used for real service installation. For the purpose of the test, the mounting bracket shall be considered as a part of the arrester base. In cases where the foregoing is at variance with the manufacturer's instructions, the arrester shall be mounted in accordance with the installation recommendations of the manufacturer. The entire lead between the base and the current sensor shall be insulated for at least 1 000 V. The top end of the test sample shall be fitted with the base assembly of the same design of an arrester or with the top cap.

For base-mounted arresters, the bottom end fitting of the test sample shall be mounted on a test base that is at the same height as a surrounding circular or square enclosure. The test base shall be of insulating material or may be of conducting material if its surface dimensions are smaller than the surface dimensions of the arrester bottom end fitting. The test base and the enclosure shall be placed on top of an insulating platform, as shown in Figure 9. For non-base-mounted arresters, the same requirements apply to the bottom of the arrester. The arcing distance between the top end cap and any other metallic object (floating or grounded), except for the base of the arrester, shall be at least 1,6 times the height of the sample arrester, but not less than 0,9 m. The enclosure shall be made of non-metallic material and be positioned symmetrically with respect to the axis of the test sample. The height of the enclosure shall be  $40 \text{ cm} \pm 10 \text{ cm}$ , and its diameter (or side, in case of a square enclosure) shall be equal to the greater of 1,8 m or  $D$  in Equation (1) below. The enclosure shall not be permitted to open or move during the test.

$$D = 1,2 \times (2 \times H + D_{\text{arr}}) \quad (1)$$

where

$H$  is the height of tested arrester unit;

$D_{\text{arr}}$  is the diameter of tested arrester unit.

In the event that physical space limitations of the laboratory do not permit an enclosure of the specified size, the manufacturer may choose to use an enclosure of lesser diameter.

Test samples shall be mounted vertically unless agreed upon otherwise between the manufacturer and the user.

The mounting of the arrester during the short-circuit test and, more specifically, the routing of the conductors shall represent the most unfavourable condition in service. For all polymer-housed arresters, the ground conductor shall be directed to the opposite direction as the incoming conductor, as described in Figure 9. In this way, the arc will stay close to the arrester during the entire duration of the short-circuit current, thus creating the most unfavourable conditions with regards to the fire hazard.

#### 10.8.9.4.3 High-current test at less than 77 % of rated voltage

*Replacement of Subclause 8.9.4.3:*

When tests are made with a test circuit voltage  $\leq 77\%$  of the rated voltage of the test samples, the test circuit parameters shall be adjusted in such a way that the RMS value of the symmetrical component of the actual arrester test current shall equal or exceed the required test current level selected from Table 7.

For “Design B” arresters tested at rated short-circuit current, the peak value of the first half-cycle of the actual arrester test current shall be at least  $\sqrt{2}$  times the RMS value of the rated short circuit current.

For all the reduced short-circuit currents the RMS value shall be in accordance with Table 7 and the peak value of the first half-cycle of the actual arrester test current shall be at least  $\sqrt{2}$  times the RMS value of this current.

Especially for tall arresters that are tested at a low percentage of their rated voltage, the first asymmetric peak current of 2,5 is not easily achieved unless special test possibilities are considered. It is thus possible to increase the test RMS voltage or reduce the impedance so that, for the rated short-circuit current, the peak value of the first half-cycle of the test current is equal to, or greater than, 2,5 times the required test current level. In case of testing with a generator, the first peak of 2,5 times the required test current can also be achieved by varying the generator's excitation. The current should then be reduced, not less than 2,5 cycles after initiation, to the required symmetrical value. The actual peak value of the test current, divided by 2,5, should be quoted as the test current, even though the RMS value of the symmetrical component of the actual arrester test current may be higher. Because of the higher test current, the sample arrester may be subjected to more severe duty and, therefore, tests at X/R ratio lower than 15 should only be carried out with the manufacturer's consent.

For “Design B” polymer-housed arresters, even the first current peak of  $\sqrt{2}$  may not be easily achieved unless special test facilities are considered. Pre-failed arresters can build up considerable arc resistance, which limits the symmetrical current through the arrester. It is therefore recommended to perform the short-circuit tests as soon as possible after the pre-failure, preferably before the test samples have cooled down.



For pre-failed arresters, therefore, it is recommended to ensure that the arrester represents a sufficiently low impedance prior to applying the short-circuit current by reapplying the pre-failing, or similar, circuit during a maximum of 2 s immediately before applying the short-circuit test current (see Figure 10). It is acceptable to increase the short-circuit current of the pre-applied circuit up to 300 A (RMS). If so, its maximum duration, which depends on the current magnitude, shall not exceed the following value:


$$t_{\text{rpf}} \leq Q_{\text{rpf}} / I_{\text{rpf}}$$

where

$t_{\text{rpf}}$  is the re-pre-failing time in s;

$Q_{\text{rpf}}$  is the re-pre-failing charge = 60 As;

$I_{\text{rpf}}$  is the re-pre-failing current in A (RMS).



NOTE SW 1 is closed and SW 2 is opened to apply pre-failing level of current (maximum of 30 A, limited by impedance Z). After a maximum of 2 s, SW 2 is closed to cause the specified short-circuit current to flow through the test sample.

**Figure 10 – Example of a test circuit for re-applying pre-failing circuit immediately before applying the short-circuit test current**

#### 10.8.10 Test of the bending moment

*Replacement of Subclause 8.10:*

This test applies to polymer (except cast-resin) housed arresters (with and without enclosed gas volume) for which the manufacturer claims cantilever strength. The test shall be performed on the arrester without insulating base or mounting bracket.

Cast-resin housed arresters shall be tested according to 8.10. Arresters that have no declared cantilever strength shall be submitted to the terminal torque preconditioning according to 10.8.10.3.1, the thermal preconditioning according to 10.8.10.3.2 and the water immersion test according to 10.8.10.3.3.

The complete test procedure is shown by the flow chart in Annex C.

### 10.8.10.1 General

This test demonstrates the ability of the arrester to withstand the manufacturer's declared values for bending loads. Normally, an arrester is not designed for torsional loading. If an arrester is subjected to torsional loads, a specific test may be necessary by agreement between manufacturer and user.

The test shall be performed on complete arrester units with the highest rated voltage of the unit. For single-unit arrester designs, the test shall be performed on the longest unit with the highest rated voltage of that unit of the design. Where an arrester contains more than one unit or where the arrester has different specified bending moments in both ends, the test shall be performed on the longest unit of each different specified bending moment, with loads determined according to C.1. However, if the length of the longest unit is greater than 800 mm, a shorter length unit may be used, provided the following requirements are met:

- the length is at least as long as the greater of
  - 800 mm
  - three times the outside diameter of the housing (excluding the sheds) at the point it enters the end fittings;
- the unit is one of the normal assortment of units used in the design, and is not specially made for the test;
- the unit has the highest rated voltage of that unit of the design.

A two-step test shall be performed one after the other on three samples as follows:

- On two of the samples a static bending moment test with the test load equal to the specified short-term load (SSL), i.e. the 100 % value of C.2 and on the 3<sup>rd</sup> sample a mechanical preconditioning test as per 10.8.10.3;
- on all three samples a water immersion test as per 10.8.10.3.3.

Tolerance on specified loads shall be  $\pm 5\%$ .

### 10.8.10.2 Sample preparation

The test samples shall contain the internal parts.

Prior to the test, each test sample shall be subjected to the following tests:

- electrical tests made in the following sequence:
  - watt losses measured at  $U_c$  and at an ambient temperature of  $20\text{ °C} \pm 15\text{ K}$ ;
  - internal partial discharge test according to item c) of 9.1;
  - residual voltage test at (0,01 to 1) times the nominal discharge current; the current wave shape shall be in the range of  $T_1/T_2 = (4\text{ to }10)/(10\text{ to }25)\text{ }\mu\text{s}$ ;
- leakage tests in accordance with item d) of 9.1 for arresters with enclosed gas volume and separate sealing system.

If the partial discharge test according to item c) of 9.1 and the leakage test according to item d) of 9.1 have been performed as routine tests they need not be repeated at this time.

One end of the sample shall be firmly fixed to a rigid mounting surface of the test equipment, and a load shall be applied to the other (free) end of the sample to produce the required bending moment at the fixed end. The direction of the load shall pass through and be perpendicular to the longitudinal axis of the arrester. If the arrester is not axi-symmetrical with respect to its bending strength, the manufacturer shall provide information regarding this non-symmetric strength, and the load shall be applied in an angular direction that subjects the weakest part of the arrester to the maximum bending moment.

#### 10.8.10.2.1 Test procedure

The test shall be performed on three samples.

Step 1.1:

Subject two samples to a bending moment test. The bending load shall be increased smoothly to specified short-term load (SSL) within 30 s to 90 s. When the test load is reached, it shall be maintained for 60 s to 90 s. During this time the deflection shall be measured. Then the load shall be released smoothly.

The maximum deflection during the test and any residual deflection shall be recorded. The residual deflection shall be measured in the interval 1 min to 10 min after the release of the load.

Step 1.2:

Subject a third sample to mechanical/thermal preconditioning according to 10.8.10.3.

Step 2:

Subject all three samples to the water immersion test according to 10.8.10.3.3.

#### 10.8.10.3 Mechanical/thermal preconditioning

This preconditioning constitutes part of the test procedure of 10.8.10.2.1 and shall be performed on one of the test samples as defined in 10.8.10.2.1.

##### 10.8.10.3.1 Terminal torque preconditioning

The arrester terminal torque specified by the manufacturer shall be applied to the test sample for a duration of 30 s.

##### 10.8.10.3.2 Thermo-mechanical preconditioning

This portion of the test applies only to arresters for which a cantilever strength is declared.

The sample is submitted to the specified long-term load (SLL) in four directions and in thermal variations as described in Figure 11 and Figure 12.


If, in particular applications, other loads are dominant, the relevant loads shall be applied instead. The total test time and temperature cycle shall remain unchanged.

The thermal variations consist of two 48 h cycles of heating and cooling as described in Figure 11. The temperature shall be measured in the air surrounding the arrester in the test chamber. The temperature of the hot and cold periods shall be maintained for at least 16 h. The test shall be conducted in air.


The applied static mechanical load shall be equal to SLL defined by the manufacturer. Its direction changes every 24 h at any temperature in the transition from hot to cold, or from cold to hot, as defined in Figure 11.

The test may be interrupted for maintenance for a total duration of 4 h and restarted after interruption. The cycle then remains valid.

Any residual deflection measured from the initial no-load position shall be reported. The residual deflection shall be measured within 1 min to 10 min after the release of the load.



**Figure 11 – Thermomechanical test**



**Figure 12 – Example of the test arrangement for the thermomechanical test and direction of the cantilever load**

#### 10.8.10.3.2.1 Thermal preconditioning

This portion of the test applies only to arresters for which no cantilever strength is declared.

The sample is submitted to the thermal variations as described in Figure 11 without any load applied.

The thermal variations consist of two 48 h cycles of heating and cooling as described in Figure 11. The temperature of the hot and cold periods shall be maintained for at least 16 h. The test shall be conducted in air.

#### 10.8.10.3.3 Water immersion test

The test samples shall be kept immersed in a vessel, in boiling deionised water with 1 kg/m<sup>3</sup> of NaCl, for 42 h.

NOTE 1 The characteristics of the water described above are those measured at the beginning of the test.

NOTE 2 This temperature (boiling water) can be reduced to 80 °C (with a minimum duration of 52 h) by agreement between the user and the manufacturer, if the manufacturer claims that its sealing material is not able to withstand the boiling temperature for a duration of 42 h. This value of 52 h can be expanded up to 168 h (i.e. one week) after agreement between the manufacturer and the user.

At the end of the boiling, the arrester shall remain in the vessel until the water cools to approximately 50 °C and shall be maintained in the water at this temperature until verification tests can be performed. The arrester shall be removed from the water and cooled to ambient temperature for not longer than three thermal time constants of the sample (as derived from the cooling curves of 10.8.5). The 50 °C holding temperature is necessary only if it is necessary to delay the verification tests after the end of the water immersion test as shown in Figure 13. Evaluation tests shall be made within the time specified in 10.8.10.4. After removing the sample from the water it may be washed with tap water.




Figure 13 – Water immersion

#### 10.8.10.4 Test evaluation

Tests according to 10.8.11.2 shall be repeated on each test sample.

The arrester shall have passed the test if the following is demonstrated:

After step 1:

- there is no visible damage;
- for step 1.1, the slope of the force-deflection curve remains positive up to the SSL value except for dips not exceeding 5 % of SSL magnitude. The sampling rate of digital measuring equipment shall be at least 10 s<sup>-1</sup>. The cut-off frequency of the measuring equipment shall be not less than 5 Hz.

Maximum deflection during step 1 and any remaining permanent deflection after the test shall be reported.

After step 2:

- within 8 h after cooling as defined in Figure 13:
  - the increase in watt losses, measured at  $U_c$  and at an ambient temperature that does not deviate by more than 3 K from the initial measurements, is not more than the greater of 20 mW/kV of  $U_c$  (measured at  $U_c$ ) or 20 %;

- the internal partial discharge measured at 1,05 times  $U_c$  does not exceed 10 pC;
- at any time after the above watt losses and partial discharge measurements:
  - for arresters with enclosed gas volume and separate sealing system, the samples pass the leakage test in accordance with item d) of 9.1;
  - the residual voltage measured at the same current value and wave shape as the initial measurement is not more than 5 % different from the initial measurement;
  - the difference in voltage between two successive impulses at nominal discharge current does not exceed 2 %, and the oscillograms of voltage and current do not reveal any partial or full breakdown of the test sample. The current wave shape shall be in the range of  $T_1/T_2 = (4 \text{ to } 10)/(10 \text{ to } 25) \mu\text{s}$  and the impulses shall be administered 50 to 60 s apart.

NOTE 2 In case of extra-long arresters where the blocks can be dismantled, the residual voltage test can be performed on individual blocks or stacks of blocks. If the blocks cannot be dismantled, a possible procedure would be to drill a hole in the arrester insulation to make contact with the internal stack at a metal spacer and in this way be able to test shorter arrester sections.

#### 10.8.11 Environmental tests

Subclause 8.11 does not apply.

#### 10.8.12 Seal leak rate test

Subclause 8.12 applies, except as follows:

*Replacement of Subclause 8.12.1:*

This test applies to arresters having an enclosed gas volume and a separate sealing system. The test demonstrates the gas/water tightness of the complete system. It applies to arresters with polymer housings having seals and associated components essential for maintaining a controlled atmosphere within the housing (arresters with enclosed gas volume and a separate sealing system).

The test shall be performed on one complete arrester unit. The internal parts may be omitted. If the arrester contains units with differences in their sealing system, the test shall be performed on one unit each, representing each different sealing system.

#### 10.8.13 Test to verify the dielectric withstand of internal components

Subclause 8.13 applies without modification.

#### 10.8.14 Test of internal grading components

Subclause 8.14 applies without modification.

*Addition:*

#### 10.8.15 Weather ageing test

##### 10.8.15.1 General

This test has two parts. One evaluates the effect of exposure of the arrester to salt fog. The other evaluates the effect of exposure of the housing material to ultra-violet (UV) light.

### 10.8.15.2 Salt fog test

#### 10.8.15.2.1 Test specimens

This test shall be performed on the longest electrical unit with the minimum specific creepage distance and the highest rated voltage recommended by the manufacturer for this unit.

#### 10.8.15.2.2 Test procedure

The test is a time-limited continuous test under salt fog at constant power-frequency voltage equal to  $U_c$ . The test is carried out in a moisture-sealed corrosion-proof chamber. An aperture of not more than 80 cm<sup>2</sup> shall be provided for the natural evacuation of exhaust air. A turbo sprayer or room humidifier of constant spraying capacity shall be used as a water atomizer.

The fog shall fill up the chamber and not be directly sprayed onto the test specimen. The salt water prepared with NaCl and deionized water will be supplied to the sprayer. The power-frequency test voltage shall be obtained with a test transformer. The test circuit, when loaded with a resistive current of 250 mA (RMS) during 1 s on the high-voltage side, shall experience a maximum voltage drop of 5 %.

The protection level shall be set at 1 A (RMS). The test specimen shall be cleaned with deionized water before starting the test.

The test specimen shall be tested when mounted vertically. There shall be enough clearance between the roof and walls of the chamber and the test specimen in order to avoid electrical field disturbance. These data shall be found in the manufacturer's installation instructions.

- Duration of the test                    1 000 h
- Water flow rate                        0,4 l/h/m<sup>3</sup> ± 0,1 l/h/m<sup>3</sup>
- Size of droplets                        5 µm to 10 µm
- Temperature                            20 °C ± 5 K
- NaCl content of water                between 1 kg/m<sup>3</sup> to 10 kg/m<sup>3</sup>

The manufacturer shall state the starting value of the salt content of the water. The water flow rate is defined in litres per hour per cubic metre of the test chamber. It is not permitted to recirculate the water. Interruptions due to flashovers are permitted. If more than one flashover occurs, the test voltage is interrupted. However, the salt fog application shall continue until the washing of the arrester with tap water is started. Interruptions of salt fog application shall not exceed 15 min. The test shall then be re-started at a lower value of the salt content of the water. If again more than one flashover occurs, this procedure shall be repeated. Interruption times shall not be counted as part of the test duration.

The NaCl content of the water, the number of flashovers and the duration of the interruptions shall be noted. The number of overcurrent trip-outs shall be noted and taken into account in the evaluation of the duration of the test.

NOTE Within this range of salinity, lower salt content may increase test severity. Higher salt content increases flashover probability, which makes it difficult to run the test on larger diameter housings.

#### 10.8.15.2.3 Evaluation of the test

The test is regarded as passed, if no tracking occurs (see IEC 62217), if erosion does not occur through the entire thickness of any shed or other part of the external coating up to the next layer of material, if the sheds and housing are not punctured, if the Power frequency sparkover voltage test measured before and after the test at the same ambient temperature within ± 3 K has not decreased by more than 10 %, and if the partial discharge measurement performed before and after the test is satisfactory, i.e. the partial discharge level shall not exceed 10 pC as measured according to the procedure of 9.1 c).



### 10.8.15.3 UV light test

#### 10.8.15.3.1 Test procedure

Select three specimens of shed and housing materials for this test (with markings included, if applicable). The insulator housing material shall be subjected to a 1 000 h UV light test using one of the following test methods. Markings on the housing, if any, shall be directly exposed to UV light:

- Xenon-arc methods: ISO 4892-1 and ISO 4892-2, using method A without dark periods, standard spray cycle, black-standard/black panel temperatures of 65 °C, an irradiance of around 550 W/m<sup>2</sup>.
- Fluorescent UV method: ISO 4892-1 and ISO 4892-3, using type I fluorescent UV lamp, exposure method 1 or 2.

#### 10.8.15.3.2 Evaluation of the test

After the test, markings on shed or housing material shall be legible; surface degradations such as cracks and raised areas are not permitted. In case of doubt concerning such degradation, two surface roughness measurements shall be made on each of the three specimens. The roughness,  $R_z$  as defined in ISO 4287, shall be measured along a sampling length of at least 2,5 mm.  $R_z$  shall not exceed 0,1 mm.

NOTE ISO 3274 gives details of surface roughness measurement instruments.

### 10.9 Routine tests

Clause 9 applies without modification.

## **Annex A**

(normative)

### **Special Environmental Conditions**

The following are typical abnormal service conditions which may require special consideration in the manufacture or application of surge arresters and should be called to the attention of the manufacturer.

- 1) Temperature in excess of +40 °C or below –40 °C.
- 2) Application at altitudes higher than 1 000 m.
- 3) Fumes or vapours which may cause deterioration of insulating surface or mounting hardware.
- 4) Excessive contamination by smoke, dirt, salt spray or other conducting materials.
- 5) Excessive exposure to moisture, humidity, dropping water or steam.
- 6) Live washing of arrester.
- 7) Explosive mixtures of dust, gases or fumes.
- 8) Abnormal mechanical conditions (earthquakes, vibrations, high wind velocities, high ice loads, high cantilever stresses).
- 9) Unusual transportation or storage.
- 10) Nominal frequencies below 48 Hz and above 62 Hz.
- 11) Heat sources near the arrester (see 5.4 b)).
- 12) Wind speed > 34 m/s.
- 13) Non-vertical erection and suspended erection.
- 14) Torsional loading of the arrester
- 15) Tensile loading of the arrester
- 16) Use of the arrester as a mechanical support.

## **Annex B**

(normative)

### **Typical information given with enquiries and tenders**

#### **B.1 Information given with enquiry**

##### **B.1.1 System data**

- Highest system voltage.
- Frequency.
- Maximum voltage to earth under system fault conditions (earth fault factor or system of neutral earthing).
- Maximum duration of the earth fault.
- Maximum value of temporary overvoltages and their maximum duration (earth fault, loss of load, ferro-resonance).
- Insulation level of equipment to be protected.
- Short-circuit current of the system at the arrester location.

##### **B.1.2 Service conditions**

For normal conditions, see 5.4.1.

Special environmental conditions:

- a) For ambient conditions, see 5.4.2 and Annex A:
  - for the natural pollution level, see IEC 60071-2.
- b) System:
  - possibility of generator overspeeding (voltage-versus-time characteristics);
  - nominal power frequency other than 48 Hz to 62 Hz;
  - load rejection and simultaneous earth faults. Formation during faults of a part of the system with an insulated neutral in a normally effectively earthed neutral system;
  - incorrect compensation of the earth fault current.

Any other special requirements with respect to service conditions shall be specified and quantified as far as possible.

##### **B.1.3 Arrester duty**

- a) Connection to system:
  - phase to earth;
  - neutral to earth;
  - phase to phase.
- b) Type of equipment being protected:
  - transformers (directly connected to a line or via cables);
  - rotating machines (directly connected to a line or via transformers);
  - reactors;
  - HF-reactors;
  - other equipment of substations;
  - gas-insulated substations (GIS);

- capacitor banks;
- cables (type and length), etc.

Maximum length of high-voltage conductor between arrester and equipment to be protected (protection distance).

#### **B.1.4 Characteristics of arrester**

Continuous operating voltage.

Rated voltage.

Steep current impulse residual voltage.

Standard nominal discharge current and residual voltages.

Switching current impulses and residual voltages.

For 10 kA and 20 kA arresters, repetitive charge transfer rating and thermal energy rating.

Short circuit rating.

Length and shape of creepage distance of arrester housing. Selected on the basis of service experience with surge arresters and/or other types of equipment in the actual area.

#### **B.1.5 Additional equipment and fittings**

Metal-enclosed arrester.

Type of mounting: pedestal, bracket, hanging (in what position) etc. and if insulating base is required for connection of surge counters. For bracket-mounted arresters, whether bracket is to be earthed or not.

Mounting orientation if other than vertical.

Earth lead disconnector/fault indicator if required.

Cross-section of connection lead.

#### **B.1.6 Any special abnormal conditions**

Any other special requirements in respect to service conditions shall be specified and quantified as far as possible.

### **B.2 Information given with tender**

All items from B.1.4 and B.1.5.

In addition:

- reference current and voltage at ambient temperature;
- power-frequency voltage versus time characteristics (see 8.6);
- lightning impulse residual voltage at 0,5, 1 and 2 times the nominal discharge current. If the complete arrester acceptance test cannot be carried out at one of those currents, the

residual voltage shall in addition be specified for current in the range of 0,01 to 0,25 times the nominal discharge current, see 6.3 and 8.3;

- pressure-relief function;
- clearances;
- mounting specifications;
- possibilities of mounting, drilling plans, insulating base, bracket;
- type of arrester terminals and permissible conductor size;
- maximum permissible length of lead between arrester and surge counter, and between surge counter and earth;
- dimensions and weights;
- cantilever strength.


IECNORM.COM : Click to view the full PDF of IEC 60099-6:2019

## Annex C (normative)

### Mechanical considerations

#### C.1 Test of bending moment

In the case of a multi-unit arrester, each unit shall be tested with the bending moment according to Figure C.1. If the units differ only in length, but are otherwise identical from material and design, it is not necessary to test each unit.



**Figure C.1 – Bending moment – multi-unit surge arrester**

Testing the complete arrester, the moment affecting the bottom flange is  $M_{b3} = F \times H_3$ .

The moment affecting the top flange of the bottom unit is  $M_{b2} = F \times H_2$ .

If one unit is tested separately (example for unit 3), the test force  $F_2$  for the test of the bottom flange of unit 3 is as follows:

$$F_2 \times (H_3 - H_2) = F \times H_3;$$

$$F_2 = \frac{F \times H_3}{(H_3 - H_2)}$$

The test of the top flange of unit 3 shall be performed with the unit in reversed position. Test force  $F_3$  for the test of the top flange of unit 3 is as follows:

$$F_3 \times (H_3 - H_2) = F \times H_2$$

$$F_3 = \frac{F \times H_2}{(H_3 - H_2)}$$

## C.2 Definition of mechanical loads

Figure C.2 indicates the relationships between mechanical load ratings.





Figure C.2 – Definition of mechanical loads

## C.3 Definition of seal leak rate

Figure C.3 schematically represents an arrester unit.



**Figure C.3 – Surge arrester unit**

The seal leak rate specifies the quantity of gas per unit of time which passes the seals of the housing at a pressure difference of at least 70 kPa. If the efficiency of the sealing system depends on the direction of the pressure gradient, the worst case shall be considered.

$$\text{Seal leak rate} = \frac{\Delta p_1 \times V}{\Delta t} \text{ at } |p_1 - p_2| \geq 70 \text{ kPa and at a temperature of } +20 \text{ }^\circ\text{C} \pm 15 \text{ K,}$$

where

$$\Delta p_1 = p_1(t_2) - p_1(t_1);$$

$p_1(t)$  is the internal gas pressure of the arrester housing as a function of time (Pa);

$p_2$  is the gas pressure exterior to the arrester (Pa);

$t_1$  is the start time of the considered time interval (s);

$t_2$  is the end time of the considered time interval (s);


$$\Delta t = t_2 - t_1;$$

$V$  is the internal gas volume of the arrester (m<sup>3</sup>).

#### **C.4 Calculation of wind-bending-moment**

Figure C.4 schematically represents an assembled arrester.





**Figure C.4 – Surge-arrester dimensions**

The wind-bending moment is given by

$$M_w = P \times H \times d_a \times C \times H/2 + P \times D \times h \times (H - l)$$

where

$$P = (P_1/2) \times V^2;$$

$$d_a = (2d_t + d_{s1} + d_{s2})/4 \text{ as per IEC 60815-2 } (d_{s1} = d_{s2} \text{ for non-alternating sheds})$$

$M_w$  is the bending moment caused by the wind (Nm);

$H$  is the height of the arrester (m);

$d_a$  is the mean value of the insulator diameter (m);

$h$  is the thickness of the grading ring (m);

$D$  is the diameter of the grading ring (m);

$l$  is the grading ring distance to the top (m);

$C$  is the coefficient of drag for cylindrical parts; equal to 0,8;

$P$  is the dynamic pressure of the wind ( $\text{N/m}^2$ );

$P_1$  is the density of air at 1,013 bar and 0 °C; equal to 1,29  $\text{kg/m}^3$ ;

$V$  is the wind velocity (m/s).

## C.5 Procedures of tests of bending moment for porcelain/cast resin and polymer-housed arresters

A flow chart of the procedures is shown in Figure C.5.




Figure C.5 – Flow chart of bending moment test procedures

IECNORM.COM : Click to view the full PDF of IEC 60099-6:2019

## SOMMAIRE

|                                                                                                        |     |
|--------------------------------------------------------------------------------------------------------|-----|
| AVANT-PROPOS .....                                                                                     | 87  |
| INTRODUCTION.....                                                                                      | 89  |
| 1 Domaine d'application .....                                                                          | 90  |
| 2 Références normatives .....                                                                          | 90  |
| 3 Termes et définitions .....                                                                          | 91  |
| 4 Identification et classification .....                                                               | 99  |
| 4.1 Identification des parafoudres .....                                                               | 99  |
| 4.2 Classification des parafoudres .....                                                               | 99  |
| 5 Caractéristiques assignées normalisées et conditions de service .....                                | 100 |
| 5.1 Tensions assignées normalisées .....                                                               | 100 |
| 5.2 Fréquences assignées normalisées .....                                                             | 100 |
| 5.3 Valeurs normalisées du courant nominal de décharge.....                                            | 100 |
| 5.4 Conditions de service.....                                                                         | 100 |
| 5.4.1 Conditions normales de service .....                                                             | 100 |
| 5.4.2 Conditions d'environnement particulières.....                                                    | 100 |
| 6 Exigences.....                                                                                       | 101 |
| 6.1 Tenue diélectrique .....                                                                           | 101 |
| 6.2 Tensions résiduelles .....                                                                         | 101 |
| 6.3 Niveaux de protection au choc .....                                                                | 101 |
| 6.4 Décharges partielles internes.....                                                                 | 101 |
| 6.5 Taux de fuite de l'étanchéité .....                                                                | 101 |
| 6.6 Stabilité thermique.....                                                                           | 102 |
| 6.7 Capacité de dissipation de chaleur de l'échantillon pour essai .....                               | 102 |
| 6.8 Tenue au transfert de charges répétitives .....                                                    | 102 |
| 6.9 Fonctionnement des parafoudres .....                                                               | 102 |
| 6.10 Caractéristiques de tension à fréquence industrielle en fonction du temps<br>d'un parafoudre..... | 102 |
| 6.11 Performances de tenue aux courts-circuits.....                                                    | 103 |
| 6.12 Dispositifs de déconnexion .....                                                                  | 103 |
| 6.12.1 Tenue du dispositif de déconnexion.....                                                         | 103 |
| 6.12.2 Fonctionnement du dispositif de déconnexion.....                                                | 103 |
| 6.13 Exigences pour les éléments de répartition internes .....                                         | 103 |
| 6.14 Amorçage à fréquence industrielle .....                                                           | 103 |
| 6.15 Efforts mécaniques .....                                                                          | 103 |
| 6.15.1 Généralités.....                                                                                | 103 |
| 6.15.2 Moment de flexion .....                                                                         | 103 |
| 6.15.3 Résistance aux contraintes d'environnement .....                                                | 104 |
| 6.15.4 Embase isolante et console de montage.....                                                      | 104 |
| 6.15.5 Valeur de l'effort moyen à la rupture (MBL).....                                                | 104 |
| 6.16 Compatibilité électromagnétique .....                                                             | 104 |
| 6.17 Fin de vie.....                                                                                   | 104 |
| 7 Conditions générales des procédures d'essai .....                                                    | 104 |
| 7.1 Appareillage de mesure et exactitude .....                                                         | 104 |
| 7.2 Échantillons pour essai .....                                                                      | 105 |
| 7.2.1 Généralités.....                                                                                 | 105 |
| 7.2.2 Échantillons pour les essais de tension résiduelle .....                                         | 105 |

|        |                                                                                                                                  |     |
|--------|----------------------------------------------------------------------------------------------------------------------------------|-----|
| 7.2.3  | Échantillons dédiés à l'essai de vérification des caractéristiques assignées de transfert de charges répétitives, $Q_{rs}$ ..... | 105 |
| 8      | Essais de type (essais de conception) .....                                                                                      | 106 |
| 8.1    | Généralités .....                                                                                                                | 106 |
| 8.2    | Essais de tenue diélectrique .....                                                                                               | 107 |
| 8.2.1  | Généralités .....                                                                                                                | 107 |
| 8.2.2  | Essais sur l'enveloppe d'un élément individuel .....                                                                             | 107 |
| 8.2.3  | Caractéristiques de l'air ambiant pendant les essais .....                                                                       | 107 |
| 8.2.4  | Modalités des essais sous pluie.....                                                                                             | 107 |
| 8.2.5  | Essai de tension de tenue au choc de foudre.....                                                                                 | 107 |
| 8.2.6  | Essai de tension de tenue à fréquence industrielle .....                                                                         | 108 |
| 8.3    | Essais de niveaux de protection au choc .....                                                                                    | 108 |
| 8.3.1  | Généralités.....                                                                                                                 | 108 |
| 8.3.2  | Essais de tension résiduelle .....                                                                                               | 108 |
| 8.3.3  | Essais d'amorçage .....                                                                                                          | 110 |
| 8.4    | Essai de vérification des caractéristiques assignées de transfert de charges répétitives, $Q_{rs}$ .....                         | 111 |
| 8.4.1  | Généralités.....                                                                                                                 | 111 |
| 8.4.2  | Résistances MO .....                                                                                                             | 112 |
| 8.4.3  | Éclateurs en série.....                                                                                                          | 113 |
| 8.5    | Essais de fonctionnement des parafoudres .....                                                                                   | 114 |
| 8.5.1  | Généralités.....                                                                                                                 | 114 |
| 8.5.2  | Procédure d'essai.....                                                                                                           | 115 |
| 8.5.3  | Valeurs assignées de charge thermique, $Q_{th}$ .....                                                                            | 118 |
| 8.6    | Essai de tension à fréquence industrielle en fonction du temps.....                                                              | 118 |
| 8.6.1  | Généralités.....                                                                                                                 | 118 |
| 8.6.2  | Échantillons pour essai.....                                                                                                     | 119 |
| 8.6.3  | Mesurages initiaux.....                                                                                                          | 119 |
| 8.6.4  | Procédure d'essai.....                                                                                                           | 120 |
| 8.6.5  | Évaluation de l'essai.....                                                                                                       | 121 |
| 8.7    | Essais des dispositifs de déconnexion des parafoudres .....                                                                      | 121 |
| 8.7.1  | Généralités.....                                                                                                                 | 121 |
| 8.7.2  | Essai de tenue en fonctionnement .....                                                                                           | 121 |
| 8.7.3  | Fonctionnement du dispositif de déconnexion.....                                                                                 | 122 |
| 8.7.4  | Essais mécaniques.....                                                                                                           | 123 |
| 8.7.5  | Essai de cycles de températures et de pompage d'étanchéité .....                                                                 | 124 |
| 8.8    | Essais d'amorçage à la tension à fréquence industrielle .....                                                                    | 124 |
| 8.9    | Essais de court-circuit.....                                                                                                     | 125 |
| 8.9.1  | Généralités.....                                                                                                                 | 125 |
| 8.9.2  | Préparation des échantillons pour essai .....                                                                                    | 125 |
| 8.9.3  | Montage de l'échantillon pour essai .....                                                                                        | 129 |
| 8.9.4  | Essais de court-circuit à courant de forte amplitude.....                                                                        | 130 |
| 8.9.5  | Essai de court-circuit à courant de faible amplitude .....                                                                       | 132 |
| 8.9.6  | Évaluation des résultats d'essai.....                                                                                            | 132 |
| 8.10   | Essai de moment de flexion .....                                                                                                 | 133 |
| 8.10.1 | Généralités.....                                                                                                                 | 133 |
| 8.10.2 | Présentation générale.....                                                                                                       | 133 |
| 8.10.3 | Préparation de l'échantillon .....                                                                                               | 133 |
| 8.10.4 | Procédure d'essai.....                                                                                                           | 134 |

|         |                                                                                                          |     |
|---------|----------------------------------------------------------------------------------------------------------|-----|
| 8.10.5  | Évaluation de l'essai.....                                                                               | 134 |
| 8.10.6  | Essai sur embase isolante et console de montage.....                                                     | 134 |
| 8.11    | Essais d'environnement.....                                                                              | 135 |
| 8.11.1  | Généralités.....                                                                                         | 135 |
| 8.11.2  | Préparation de l'échantillon.....                                                                        | 135 |
| 8.11.3  | Procédure d'essai.....                                                                                   | 135 |
| 8.11.4  | Évaluation de l'essai.....                                                                               | 135 |
| 8.12    | Essai de mesure du taux de fuite de l'étanchéité.....                                                    | 136 |
| 8.12.1  | Généralités.....                                                                                         | 136 |
| 8.12.2  | Préparation de l'échantillon.....                                                                        | 136 |
| 8.12.3  | Procédure d'essai.....                                                                                   | 136 |
| 8.12.4  | Évaluation de l'essai.....                                                                               | 136 |
| 8.13    | Essai de vérification de la tenue diélectrique des composants internes.....                              | 136 |
| 8.13.1  | Généralités.....                                                                                         | 136 |
| 8.13.2  | Procédure d'essai.....                                                                                   | 136 |
| 8.13.3  | Évaluation de l'essai.....                                                                               | 137 |
| 8.14    | Essai des éléments de répartition internes.....                                                          | 137 |
| 8.14.1  | Essai de vérification de la stabilité à long terme sous une tension de régime permanent.....             | 137 |
| 8.14.2  | Essai cyclique thermique.....                                                                            | 138 |
| 9       | Essais individuels de série et essais de réception.....                                                  | 139 |
| 9.1     | Essais individuels de série.....                                                                         | 139 |
| 9.2     | Essais de réception.....                                                                                 | 139 |
| 9.2.1   | Essais de réception normaux.....                                                                         | 139 |
| 9.2.2   | Essai spécial de stabilité thermique.....                                                                | 140 |
| 10      | Exigences d'essai pour les parafoudres à enveloppe synthétique.....                                      | 140 |
| 10.1    | Domaine d'application.....                                                                               | 140 |
| 10.2    | Références normatives.....                                                                               | 140 |
| 10.3    | Termes et définitions.....                                                                               | 141 |
| 10.4    | Identification et classification.....                                                                    | 141 |
| 10.5    | Caractéristiques assignées normalisées et conditions de service.....                                     | 141 |
| 10.6    | Exigences.....                                                                                           | 141 |
| 10.7    | Conditions générales d'exécution des essais.....                                                         | 141 |
| 10.8    | Essais de type (essais de conception).....                                                               | 142 |
| 10.8.1  | Généralités.....                                                                                         | 142 |
| 10.8.2  | Essais de tenue diélectrique.....                                                                        | 142 |
| 10.8.3  | Essais de niveaux de protection au choc.....                                                             | 142 |
| 10.8.4  | Essai de vérification des caractéristiques assignées de transfert de charges répétitives, $Q_{RS}$ ..... | 142 |
| 10.8.5  | Essais de fonctionnement des parafoudres.....                                                            | 142 |
| 10.8.6  | Essai de tension à fréquence industrielle en fonction du temps.....                                      | 143 |
| 10.8.7  | Essais des dispositifs de déconnexion des parafoudres.....                                               | 143 |
| 10.8.8  | Essais d'amorçage à la tension à fréquence industrielle.....                                             | 143 |
| 10.8.9  | Essais de court-circuit.....                                                                             | 143 |
| 10.8.10 | Essai de moment de flexion.....                                                                          | 148 |
| 10.8.11 | Essais d'environnement.....                                                                              | 154 |
| 10.8.12 | Essai de mesure du taux de fuite de l'étanchéité.....                                                    | 154 |
| 10.8.13 | Essai de vérification de la tenue diélectrique des composants internes.....                              | 154 |
| 10.8.14 | Essai des éléments de répartition internes.....                                                          | 154 |

|                      |                                                                                                                                                          |     |
|----------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------|-----|
| 10.8.15              | Essai de vieillissement climatique .....                                                                                                                 | 155 |
| 10.9                 | Essais individuels de série .....                                                                                                                        | 156 |
| Annexe A (normative) | Conditions d'environnement particulières .....                                                                                                           | 157 |
| Annexe B (normative) | Renseignements caractéristiques fournis dans les appels d'offres et les offres .....                                                                     | 158 |
| B.1                  | Renseignements fournis dans les appels d'offres .....                                                                                                    | 158 |
| B.1.1                | Caractéristiques du réseau .....                                                                                                                         | 158 |
| B.1.2                | Conditions de service .....                                                                                                                              | 158 |
| B.1.3                | Rôle du parafoudre .....                                                                                                                                 | 158 |
| B.1.4                | Caractéristiques du parafoudre .....                                                                                                                     | 159 |
| B.1.5                | Matériels et installations supplémentaires .....                                                                                                         | 159 |
| B.1.6                | Conditions anormales particulières .....                                                                                                                 | 159 |
| B.2                  | Renseignements fournis dans l'offre .....                                                                                                                | 159 |
| Annexe C (normative) | Considérations d'ordre mécanique .....                                                                                                                   | 161 |
| C.1                  | Essai de moment de flexion .....                                                                                                                         | 161 |
| C.2                  | Définition des efforts mécaniques .....                                                                                                                  | 162 |
| C.3                  | Définition du taux de fuite de l'étanchéité .....                                                                                                        | 162 |
| C.4                  | Calcul du moment de flexion dû au vent .....                                                                                                             | 163 |
| C.5                  | Procédures des essais de moment de flexion pour les parafoudres à enveloppe en porcelaine/résine moulée et les parafoudres à enveloppe synthétique ..... | 164 |
| Figure 1             | – Procédure de vérification des caractéristiques assignées de transfert de charges répétitives, $Q_{RS}$ , pour les résistances MO .....                 | 112 |
| Figure 2             | – Procédure de vérification des caractéristiques assignées de transfert de charges répétitives, $Q_{RS}$ , pour les éclateurs en série .....             | 114 |
| Figure 3             | – Procédure d'essai de vérification des caractéristiques assignées de transfert de charges thermiques, $Q_{th}$ .....                                    | 116 |
| Figure 4             | – Procédure d'essai de vérification de la caractéristique de la fréquence industrielle en fonction du temps (essai TOV) .....                            | 119 |
| Figure 5             | – Exemples d'éléments de parafoudres .....                                                                                                               | 128 |
| Figure 6             | – Exemples d'emplacements du fil fusible pour les parafoudres de "conception A" .....                                                                    | 129 |
| Figure 7             | – Exemples d'emplacements du fil fusible pour les parafoudres de "conception B" .....                                                                    | 129 |
| Figure 8             | – Montage d'essai de court-circuit pour les parafoudres à enveloppe en porcelaine .....                                                                  | 130 |
| Figure 9             | – Montage d'essai de court-circuit pour les parafoudres à enveloppe synthétique .....                                                                    | 146 |
| Figure 10            | – Exemple de circuit d'essai pour réappliquer le circuit prédégradé immédiatement avant l'application du courant d'essai de court-circuit .....          | 148 |
| Figure 11            | – Essai thermomécanique .....                                                                                                                            | 151 |
| Figure 12            | – Exemple de configuration pour l'essai thermomécanique et orientation de la charge en porte-à-faux .....                                                | 152 |
| Figure 13            | – Immersion dans l'eau .....                                                                                                                             | 153 |
| Figure C.1           | – Moment de flexion pour un parafoudre à plusieurs éléments .....                                                                                        | 161 |
| Figure C.2           | – Définitions des efforts mécaniques .....                                                                                                               | 162 |
| Figure C.3           | – Élément de parafoudre .....                                                                                                                            | 163 |

|                                                                                                                    |     |
|--------------------------------------------------------------------------------------------------------------------|-----|
| Figure C.4 – Dimensions du parafoudre .....                                                                        | 164 |
| Figure C.5 – Logigramme des procédures des essais de moment de flexion .....                                       | 165 |
| Tableau 1 – Classification des parafoudres .....                                                                   | 99  |
| Tableau 2 – Échelons des tensions assignées .....                                                                  | 100 |
| Tableau 3 – Essais de type de parafoudre .....                                                                     | 106 |
| Tableau 4 – Exigences pour les chocs de courant de grande amplitude .....                                          | 117 |
| Tableau 5 – Valeurs assignées des caractéristiques assignées de transfert de charges<br>thermiques, $Q_{th}$ ..... | 118 |
| Tableau 6 – Exigences d'essai concernant les parafoudres à enveloppe en porcelaine .....                           | 127 |
| Tableau 7 – Courants exigés pour les essais de court-circuit .....                                                 | 131 |
| Tableau 8 – Exigences d'essai concernant les parafoudres à enveloppe synthétique .....                             | 145 |

IECNORM.COM : Click to view the full PDF of IEC 60099-6:2019



## COMMISSION ÉLECTROTECHNIQUE INTERNATIONALE

## PARAFOUDRES –

**Partie 6: Parafoudres contenant des structures à éclateurs en série et en parallèle – Tension de réseau inférieure ou égale à 52 kV**

## AVANT-PROPOS

- 1) La Commission Electrotechnique Internationale (IEC) est une organisation mondiale de normalisation composée de l'ensemble des comités électrotechniques nationaux (Comités nationaux de l'IEC). L'IEC a pour objet de favoriser la coopération internationale pour toutes les questions de normalisation dans les domaines de l'électricité et de l'électronique. À cet effet, l'IEC – entre autres activités – publie des Normes internationales, des Spécifications techniques, des Rapports techniques, des Spécifications accessibles au public (PAS) et des Guides (ci-après dénommés "Publication(s) de l'IEC"). Leur élaboration est confiée à des comités d'études, aux travaux desquels tout Comité national intéressé par le sujet traité peut participer. Les organisations internationales, gouvernementales et non gouvernementales, en liaison avec l'IEC, participent également aux travaux. L'IEC collabore étroitement avec l'Organisation Internationale de Normalisation (ISO), selon des conditions fixées par accord entre les deux organisations.
- 2) Les décisions ou accords officiels de l'IEC concernant les questions techniques représentent, dans la mesure du possible, un accord international sur les sujets étudiés, étant donné que les Comités nationaux de l'IEC intéressés sont représentés dans chaque comité d'études.
- 3) Les Publications de l'IEC se présentent sous la forme de recommandations internationales et sont agréées comme telles par les Comités nationaux de l'IEC. Tous les efforts raisonnables sont entrepris afin que l'IEC s'assure de l'exactitude du contenu technique de ses publications; l'IEC ne peut pas être tenue responsable de l'éventuelle mauvaise utilisation ou interprétation qui en est faite par un quelconque utilisateur final.
- 4) Dans le but d'encourager l'uniformité internationale, les Comités nationaux de l'IEC s'engagent, dans toute la mesure possible, à appliquer de façon transparente les Publications de l'IEC dans leurs publications nationales et régionales. Toutes divergences entre toutes Publications de l'IEC et toutes publications nationales ou régionales correspondantes doivent être indiquées en termes clairs dans ces dernières.
- 5) L'IEC elle-même ne fournit aucune attestation de conformité. Des organismes de certification indépendants fournissent des services d'évaluation de conformité et, dans certains secteurs, accèdent aux marques de conformité de l'IEC. L'IEC n'est responsable d'aucun des services effectués par les organismes de certification indépendants.
- 6) Tous les utilisateurs doivent s'assurer qu'ils sont en possession de la dernière édition de cette publication.
- 7) Aucune responsabilité ne doit être imputée à l'IEC, à ses administrateurs, employés, auxiliaires ou mandataires, y compris ses experts particuliers et les membres de ses comités d'études et des Comités nationaux de l'IEC, pour tout préjudice causé en cas de dommages corporels et matériels, ou de tout autre dommage de quelque nature que ce soit, directe ou indirecte, ou pour supporter les coûts (y compris les frais de justice) et les dépenses découlant de la publication ou de l'utilisation de cette Publication de l'IEC ou de toute autre Publication de l'IEC, ou au crédit qui lui est accordé.
- 8) L'attention est attirée sur les références normatives citées dans cette publication. L'utilisation de publications référencées est obligatoire pour une application correcte de la présente publication.
- 9) L'attention est attirée sur le fait que certains des éléments de la présente Publication de l'IEC peuvent faire l'objet de droits de brevet. L'IEC ne saurait être tenue pour responsable de ne pas avoir identifié de tels droits de brevets et de ne pas avoir signalé leur existence.

La Norme internationale IEC 60099-6 a été établie par le comité d'études 37 de l'IEC: Parafoudres.

Cette deuxième édition annule et remplace la première édition parue en 2002. Cette édition constitue une révision technique.

Cette édition inclut les modifications techniques majeures suivantes par rapport à l'édition précédente.

- a) Un nouveau concept de classification des parafoudres et d'essai de tenue énergétique a été introduit: la classification de décharge de ligne a été remplacée par une classification fondée sur les caractéristiques assignées de transfert de charges répétitives ( $Q_{rs}$ ) et les caractéristiques assignées de transfert de charges thermiques ( $Q_{th}$ ). Le nouveau concept

différencie clairement le choc de la capacité de traitement de l'énergie thermique, cette différence étant reflétée dans les exigences, ainsi que dans les procédures d'essai associées.

- b) Des essais de tension de tenue à fréquence industrielle en fonction du temps – avec et sans service préalable – ont été introduits comme essais de type.
- c) Des exigences et des essais portant sur les dispositifs de déconnexion ont été ajoutés.
- d) Les définitions de nouveaux termes ont été ajoutées.
- e) L'Article 10 contient des exigences particulières pour les parafoudres à enveloppe synthétique. Celles-ci sont indiquées sous la forme de remplacements, d'ajouts ou d'amendements aux articles ou paragraphes concernés.

Le texte de cette Norme internationale est issu des documents suivants:

| FDIS        | Rapport de vote |
|-------------|-----------------|
| 37/450/FDIS | 37/451/RVD      |

Le rapport de vote indiqué dans le tableau ci-dessus donne toute information sur le vote ayant abouti à l'approbation de cette Norme internationale.

Ce document a été rédigé selon les Directives ISO/IEC, Partie 2

Une liste de toutes les parties de la série IEC 60099, publiées sous le titre général *Parafoudres*, peut être consultée sur le site web de l'IEC.

Le comité a décidé que le contenu de ce document ne sera pas modifié avant la date de stabilité indiquée sur le site web de l'IEC sous "<http://webstore.iec.ch>" dans les données relatives au document recherché. À cette date, le document sera

- reconduit,
- supprimé,
- remplacé par une édition révisée, ou
- amendé.

## INTRODUCTION

Cette partie de l'IEC 60099 présente les critères minimaux pour les exigences et pour les essais des parafoudres à oxyde métallique contenant des structures à éclateurs utilisés sur les réseaux de puissance en courant alternatif avec  $U_s$  supérieure à 1 kV, et inférieure ou égale à 52 kV.

Les parafoudres couverts par le présent document peuvent être utilisés sur des installations aériennes en lieu et place des parafoudres variables couverts par l'IEC 60099-4.

Le présent document comporte une procédure de vieillissement accéléré afin de simuler les effets à long terme de la tension et de la température sur le parafoudre. Cette procédure est nécessaire dans la mesure où les éclateurs et les éléments de résistances sont soumis à une tension à fréquence industrielle de réseau continue importante au cours de la durée de vie en service d'un parafoudre.

IECNORM.COM : Click to view the full PDF of IEC 60099-6:2019

## PARAFODRES –

### Partie 6: Parafoudres contenant des structures à éclateurs en série et en parallèle – Tension de réseau inférieure ou égale à 52 kV

#### 1 Domaine d'application

La présente partie de l'IEC 60099 s'applique aux parafoudres à résistance variable à oxyde métallique avec éclateur conçus pour limiter les surtensions sur les circuits d'alimentation à courant alternatif avec des tensions de réseau  $U_s$  supérieures à 1 kV, et inférieures ou égales à 52 kV. Le présent document s'applique fondamentalement à tous les parafoudres de classe de distribution à oxyde métallique avec éclateurs en série et/ou en parallèle internes, et à enveloppes en porcelaine ou synthétiques.

#### 2 Références normatives

Les documents suivants sont cités dans le texte de sorte qu'ils constituent, pour tout ou partie de leur contenu, des exigences du présent document. Pour les références datées, seule l'édition citée s'applique. Pour les références non datées, la dernière édition du document de référence s'applique (y compris les éventuels amendements).

IEC 60060-1, *Technique des essais à haute tension – Partie 1: Définitions et exigences générales*

IEC 60060-2, *Techniques des essais à haute tension – Partie 2: Systèmes de mesure*

IEC 60068-2-11:1981, *Essais fondamentaux climatiques et de robustesse mécanique – Partie 2-11: Essais – Essai Ka: Brouillard salin*

IEC 60068-2-14, *Essais d'environnement – Partie 2-14: Essais – Essai N: Variation de température*

IEC 60071-2:2018, *Coordination de l'isolement – Partie 2: Lignes directrices en matière d'application*

IEC 60270, *Techniques des essais à haute tension – Mesures des décharges partielles*

IEC TS 60815-2, *Selection and dimensioning of high-voltage insulators intended for use in polluted conditions – Part 2: Ceramic and glass insulators for a.c. systems* (disponible en anglais seulement)

IEC 62217, *Isolateurs polymériques à haute tension pour utilisation à l'intérieur ou à l'extérieur – Définitions générales, méthodes d'essai et critères d'acceptation*

ISO 4287, *Spécification géométrique des produits (GPS) – État de surface: Méthode du profil – Termes, définitions et paramètres d'état de surface*

ISO 4892-1, *Plastiques – Méthodes d'exposition à des sources lumineuses de laboratoire – Partie 1: Guide général*

ISO 4892-2, *Plastiques – Méthodes d'exposition à des sources lumineuses de laboratoire – Partie 2: Lampes à arc au xénon*

ISO 4892-3, *Plastiques – Méthodes d'exposition à des sources lumineuses de laboratoire – Partie 3: Lampes fluorescentes UV*

### 3 Termes et définitions

Pour les besoins du présent document, les termes et définitions suivants s'appliquent.

L'ISO et l'IEC tiennent à jour des bases de données terminologiques destinées à être utilisées en normalisation, consultables aux adresses suivantes:

- IEC Electropedia: disponible à l'adresse <http://www.electropedia.org/>
- ISO Online browsing platform: disponible à l'adresse <http://www.iso.org/obp>

#### 3.1

##### **essai de réception**

essai effectué sur les parafoudres ou sur des prélèvements d'une fourniture après accord entre le constructeur et l'utilisateur

#### 3.2

##### **dispositif de déconnexion pour parafoudre**

dispositif permettant de déconnecter du réseau un parafoudre en cas de défaillance de ce dernier afin d'éviter un défaut permanent sur le réseau et de signaler de façon visible le parafoudre défectueux

Note 1 à l'article: L'interruption du courant de défaut dans le parafoudre pendant l'ouverture du circuit ne dépend généralement pas du dispositif de déconnexion.

#### 3.3

##### **moment de flexion**

force perpendiculaire à l'axe longitudinal d'un parafoudre multipliée par la distance verticale entre l'embase (niveau le plus bas de la collerette) du parafoudre et le point d'application de la force

#### 3.4

##### **effort à la rupture**

force perpendiculaire à l'axe longitudinal d'un parafoudre à enveloppe en porcelaine ou en résine moulée, qui provoque la rupture mécanique de son enveloppe

#### 3.5

##### **parafoudre à enveloppe en résine moulée**

parafoudre qui utilise une enveloppe constituée d'une seule matière organique (par exemple, de la résine époxyde cycloaliphatique) qui se rompt de la même manière qu'une enveloppe en porcelaine sous l'action d'une contrainte excessive mécanique

#### 3.6

##### **courant permanent d'un parafoudre**

courant circulant à travers le parafoudre lorsque celui-ci est soumis à la tension de régime permanent

#### 3.7

##### **tension de régime permanent d'un parafoudre**

$U_c$

valeur désignée admissible de la tension de régime permanent efficace à fréquence industrielle qui peut être appliquée de façon continue entre les bornes du parafoudre selon 8.5

### 3.8

#### **limite de dégradation**

<mécanique>

valeur la plus faible d'une force perpendiculaire à l'axe longitudinal d'un parafoudre à enveloppe synthétique, qui provoque la rupture mécanique de son enveloppe

### 3.9

#### **énoncé de la forme d'un choc**

combinaison de deux valeurs, la première représentant la durée conventionnelle du front ( $T_1$ ) et la seconde la durée conventionnelle jusqu'à mi-valeur sur la queue ( $T_2$ )

Note 1 à l'article: L'onde est représentée par  $T_1/T_2$ , en microsecondes, le signe "/" n'ayant aucune signification mathématique.

### 3.10

#### **courant de décharge d'un parafoudre**

courant de choc qui s'écoule à travers le parafoudre

### 3.11

#### **décharge disruptive**

phénomène associé à une défaillance de l'isolation sous l'effet de la contrainte électrique, avec chute de la tension et passage d'un courant

Note 1 à l'article: Ce terme s'applique aux perforations électriques de diélectriques solides, liquides et gazeux, et à leurs combinaisons.

Note 2 à l'article: Une décharge disruptive dans un diélectrique solide entraîne une perte permanente de la rigidité diélectrique. Dans un diélectrique liquide ou gazeux, la perte de la rigidité diélectrique peut n'être que temporaire.

### 3.12

#### **parafoudre de classe de distribution**

parafoudre destiné à être utilisé sur les réseaux de distribution, typiquement de valeur  $U_s \leq 52$  kV, afin de protéger les composants principalement contre les effets de la foudre

Note 1 à l'article: Les parafoudres de classe de distribution peuvent avoir des courants nominaux de décharge,  $I_n$ , de 2,5 kA, 5 kA ou 10 kA.

Note 2 à l'article: Les parafoudres de distribution sont classés comme suit: "Distribution DH", "Distribution DM" et "Distribution DL" (voir Tableau 1).

### 3.13

#### **fraction électrique**

portion de parafoudre dont chacune des extrémités se termine par une électrode soumise au milieu environnant

### 3.14

#### **indicateur de défaut**

dispositif destiné à donner une indication de la défaillance d'un parafoudre, mais qui ne le déconnecte pas du réseau

### 3.15

#### **contournement**

décharge disruptive le long d'une surface solide

### 3.16

#### **courant de suite**

courant provenant de la source d'alimentation connectée qui s'écoule à travers un parafoudre lors et à la suite du passage du courant de décharge

**3.17****front d'un choc**

partie d'un choc précédant la crête

**3.18****choc de courant de grande amplitude**

<d'un parafoudre> valeur de crête du courant de décharge de forme d'un choc 4/10 utilisé pour vérifier la stabilité du parafoudre lors des coups de foudre directs

**3.19****enveloppe**

élément isolant externe d'un parafoudre qui procure la ligne de fuite nécessaire et protège les éléments internes contre le milieu environnant

Note 1 à l'article: Une enveloppe peut être constituée de plusieurs éléments assurant la résistance mécanique et la protection contre le milieu environnant.

**3.20****choc**

onde de tension ou de courant unidirectionnelle qui, sans oscillations notables, croît rapidement jusqu'à une valeur maximale et tombe à zéro, habituellement moins rapidement, avec, éventuellement, de petites ondes de polarité opposée, les paramètres de définition étant la polarité, la valeur de crête, la durée du front et la durée jusqu'à mi-valeur

**3.21****embase isolante**

isolateur (ou ensemble isolateur) de petites dimensions sur lequel est monté le parafoudre afin de fournir un moyen de connexion d'un dispositif de surveillance du courant entre l'embase du parafoudre et la terre

**3.22****éléments de répartition internes d'un parafoudre avec éclateur intérieur**

Impédances de répartition, connectées en parallèle au(x) éclateur(s) intérieur(s), afin de contrôler la tension dans la section de l'éclateur

**3.23****éléments internes**

résistance à oxyde métallique avec structure de maintien et système de répartition interne, lorsque cela est prévu

**3.24****choc de courant de foudre**

choc de courant 8/20 dont les limites de réglage sont telles que les valeurs mesurées sont comprises entre 7  $\mu$ s et 9  $\mu$ s pour la durée conventionnelle de front et entre 18  $\mu$ s et 22  $\mu$ s pour la durée jusqu'à mi-valeur

Note 1 à l'article: Pour la mesure de la tension résiduelle lors des essais de type (voir 8.3.2.3), la durée jusqu'à mi-valeur n'est pas un paramètre critique et aucune tolérance n'est imposée.

**3.25****décharge au choc de foudre**

choc de courant de demi-onde pratiquement sinusoïdal dont la durée est comprise entre 200  $\mu$ s et 230  $\mu$ s, période au cours de laquelle la valeur instantanée du courant de choc est supérieure à 5 % de sa valeur de crête

**3.26****niveau de protection contre les chocs de foudre**

LIPL ou  $U_{pl}$

tension résiduelle maximale du parafoudre pour le courant nominal de décharge

Note 1 à l'article: L'abréviation "LIPL" est dérivée du terme anglais développé correspondant "lightning impulse protection level".

### 3.27

#### **choc de courant de longue durée**

choc de courant rectangulaire qui augmente rapidement jusqu'à la valeur maximale, reste essentiellement constant pendant une période spécifiée, puis chute rapidement à zéro, les paramètres de définition étant la polarité, la valeur de crête, la durée conventionnelle de la crête et la durée totale conventionnelle

### 3.28

#### **effort moyen à la rupture**

##### **MBL**

effort moyen à la rupture pour les parafoudres à enveloppe en porcelaine ou en résine moulée, déterminé à partir d'essais

Note 1 à l'article: L'abréviation "MBL" est dérivée du terme anglais développé correspondant "mean breaking load".

### 3.29

#### **fraction mécanique**

portion de parafoudre à l'intérieur de laquelle un dispositif mécanique empêche le déplacement axial des résistances à oxyde métallique

Note 1 à l'article: Une fraction électrique d'un parafoudre peut comporter deux fractions mécaniques ou plus (voir Figure 5).

Note 2 à l'article: Une fraction mécanique peut comporter deux fractions électriques ou plus (voir Figure 5).

### 3.30

#### **console de montage**

moyen par lequel un parafoudre de classe de distribution est physiquement fixé à un poteau ou à toute autre structure

Note 1 à l'article: Pour les parafoudres de classe de distribution à enveloppe synthétique, la console de montage est généralement constituée d'un matériau isolant et fixée sur l'extrémité inférieure (sol) du parafoudre; pour les parafoudres de classe de distribution à enveloppe en porcelaine, la console est généralement en métal (souvent de l'acier) et est connectée au moyen d'une "sangle de sûreté" disposée autour de l'enveloppe en porcelaine à une certaine distance de l'extrémité au sol du parafoudre.

### 3.31

##### **In**

#### **courant nominal de décharge d'un parafoudre**

valeur de crête du choc de courant de foudre utilisé pour désigner un parafoudre

### 3.32

#### **résistance MO**

partie du parafoudre qui, par sa caractéristique variable de la tension en fonction du courant, fonctionne comme une résistance de faible valeur pour les surtensions, limitant ainsi la tension aux bornes du parafoudre, et comme une résistance de valeur élevée à la tension normale à fréquence industrielle

### 3.33

#### **valeur de crête d'un choc**

valeur maximale d'un choc de tension ou de courant

Note 1 à l'article: Des oscillations superposées peuvent être négligées.

### 3.34

#### **valeur de crête de polarité opposée d'un choc**

amplitude maximale de polarité opposée atteinte par un choc de tension ou de courant lorsqu'il oscille autour de zéro avant d'atteindre une valeur nulle permanente



**3.35****parafoudre à enveloppe synthétique**

parafoudre utilisant des matériaux synthétiques et composites pour l'enveloppe

Note 1 à l'article: Des configurations avec un volume interne de gaz sont possibles. L'étanchéité peut être assurée par le polymère lui-même ou l'utilisation d'un système séparé.

**3.36****parafoudre à enveloppe en porcelaine**

parafoudre utilisant la porcelaine comme matériau d'enveloppe, avec des fixations et un système d'étanchéité

**3.37****caractéristique de tenue sous tension à fréquence industrielle en fonction du temps**

<d'un parafoudre> durées maximales pendant lesquelles les tensions à fréquence industrielle correspondantes peuvent être appliquées aux parafoudres sans entraîner de détérioration ou d'instabilité thermique, dans des conditions spécifiées selon 6.10

**3.38****limiteur de pression**

<d'un parafoudre> dispositif destiné à limiter la pression interne d'un parafoudre et à éviter la rupture brutale de l'enveloppe à la suite du passage prolongé du courant de défaut ou d'un contournement interne du parafoudre

**3.39****courant présumé**

<d'un circuit> courant qui circulerait en un emplacement donné d'un circuit si un court-circuit était établi en cet emplacement au moyen d'une connexion d'impédance négligeable

**3.40****caractéristiques de protection**

<d'un parafoudre> combinaison du niveau de protection contre les chocs de foudre (LIPL – *lightning impulse protection level*), niveau de protection contre les chocs de manœuvre (SIPL – *switching impulse protection level*) et niveau de protection contre les chocs de courant à front raide (STIPL – *steep current impulse protection level*)

**3.41****perforation**

claquage

décharge disruptive à travers un solide

**3.42****fréquence assignée d'un parafoudre**

fréquence du réseau pour laquelle le parafoudre est prévu

**3.43**

$I_s$

**courant assigné de court-circuit**

courant à fréquence industrielle soumis à l'essai le plus élevé qui peut se développer dans un parafoudre défailant sous la forme d'un courant de court-circuit sans provoquer de rupture explosive de l'enveloppe, ou de flammes nues pendant plus de 2 min dans les conditions d'essai spécifiées

**3.44**

$U_r$

**tension assignée d'un parafoudre**

surtension efficace à fréquence industrielle de 10 s maximale admissible qui peut être appliquée entre le parafoudre, comme le vérifient l'essai TOV et l'essai de fonctionnement des parafoudres

Note 1 à l'article: La tension assignée est utilisée comme paramètre de référence pour la spécification des caractéristiques de fonctionnement.

### 3.45

#### **caractéristiques assignées de transfert de charges répétitives**

$Q_{rs}$

capacité de transfert de charges spécifiée maximale d'un parafoudre, sous la forme d'un événement simple ou d'un groupe de surtensions qui peut être transmise par un parafoudre sans provoquer de défaillance mécanique ou de dégradation électrique inacceptable des résistances MO

Note 1 à l'article: La charge est calculée comme la valeur absolue du courant intégré dans le temps. Pour les besoins du présent document, il s'agit de la charge accumulée dans un événement simple ou d'un groupe de surtensions ne durant pas plus de 2 s et qui peut être suivie par un événement ultérieur à un intervalle de temps pas plus court que 60 s.

### 3.46

$U_{res}$

#### **tension résiduelle d'un parafoudre**

valeur de crête de la tension entre les bornes d'un parafoudre pendant le passage du courant de décharge

Note 1 à l'article: L'expression "tension de décharge" est utilisée dans certains pays.

### 3.47

#### **essais individuels de série**

essais effectués sur chaque parafoudre, élément ou matériau, le cas échéant, pour vérifier que le produit répond aux spécifications de conception

### 3.48

#### **étanchéité**

<aux gaz et à l'eau>

capacité d'un parafoudre à empêcher l'entrée de corps étrangers affectant son comportement électrique et/ou mécanique

### 3.49

#### **éclateur en série**

éclateur(s) intentionnel(s), placé(s) entre des électrodes espacées et monté(s) en série avec la valve du parafoudre, assurant une isolation importante entre cette dernière et la ligne ou le sol, voire les deux, dans des conditions normales de ligne-tension

### 3.50

#### **fraction de parafoudre**

<fraction distribuée au prorata>

partie complète d'un parafoudre, correctement assemblée, nécessaire pour représenter le comportement d'un parafoudre complet lors d'un essai particulier

Note 1 à l'article: Une fraction de parafoudre n'est pas nécessairement un élément de parafoudre. Pour certains essais, une résistance MO seule constitue une fraction.

### 3.51

#### **ailette**

élément isolant saillant de l'enveloppe destiné à en augmenter la ligne de fuite

### 3.52

#### **effort à long terme spécifié**

**SLL**

force perpendiculaire à l'axe longitudinal d'un parafoudre qu'il est admis d'appliquer en service, en permanence, sans provoquer de dommages mécaniques au parafoudre

Note 1 à l'article: L'abréviation "SLL" est dérivée du terme anglais développé correspondant "specified long-term load".

### 3.53

#### **effort à court terme spécifié**

##### **SSL**

force la plus élevée, perpendiculaire à l'axe longitudinal d'un parafoudre, qu'il est admis d'appliquer en service pendant de courtes périodes et pendant des événements relativement rares (par exemple, des charges dues à des courants de court-circuit et de fortes rafales de vent) sans provoquer de dommages mécaniques au parafoudre

Note 1 à l'article: Le SSL ne se réfère pas à des exigences de résistance mécanique pendant des secousses sismiques. Voir C.2

Note 2 à l'article: L'abréviation "SSL" est dérivée du terme anglais développé correspondant "specified short-term load".

### 3.54

#### **choc de courant à front raide**

choc de courant avec une durée conventionnelle de front de 1  $\mu\text{s}$  avec des limites de réglage du matériel telles que les valeurs mesurées sont comprises entre 0,9  $\mu\text{s}$  et 1,1  $\mu\text{s}$ . La durée conventionnelle jusqu'à mi-valeur sur la queue ne dépasse pas 20  $\mu\text{s}$

Note 1 à l'article: Pour la mesure de la tension résiduelle lors des essais de type, la durée jusqu'à mi-valeur sur la queue n'est pas un paramètre critique et aucune tolérance n'est imposée (voir 8.3.2.2).

### 3.55

#### **niveau de protection contre les chocs de courant à front raide**

##### **STIPL**

tension résiduelle maximale du parafoudre pour un choc de courant à front raide d'amplitude égale à l'amplitude du courant nominal de décharge

Note 1 à l'article: L'abréviation "STIPL" est dérivée du terme anglais développé correspondant "steep current impulse protection level".

### 3.56

#### **queue d'un choc**

partie d'un choc postérieure à la crête

### 3.57

#### **effort en tête**

force perpendiculaire à l'axe longitudinal du parafoudre mesurée au niveau de son axe

### 3.58

#### **caractéristiques assignées de transfert de charges thermiques**

##### **$Q_{th}$**

charge spécifiée maximale qui peut être transmise par un parafoudre ou une fraction de parafoudre dans un délai de 3 min lors d'un essai de récupération thermique sans provoquer d'emballement thermique

Note 1 à l'article: Ces caractéristiques assignées sont vérifiées par l'essai de type de fonctionnement des parafoudres.

### 3.59

#### **emballement thermique**

<d'un parafoudre> situation dans laquelle la perte active de façon prolongée par un parafoudre dépasse la capacité de dissipation thermique de l'enveloppe et des connexions, et conduit à une augmentation cumulative de la température des éléments de résistance MO qui se termine par une défaillance du parafoudre

### 3.60

#### **stabilité thermique**

<d'un parafoudre> état d'un parafoudre si, à la suite d'un fonctionnement ayant entraîné un échauffement, la température des résistances MO baisse en fonction de la durée lorsque le parafoudre est soumis à la tension de régime permanent spécifiée et dans des conditions ambiantes spécifiées

### 3.61

#### **effort de torsion**

chacune des forces horizontales appliquées en partie haute de l'enveloppe d'un parafoudre installé en position verticale, qui ne s'appliquent pas sur son axe longitudinal

### 3.62

#### **essais de type**

#### **essais de conception**

essais effectués après la mise au point d'un nouveau modèle de parafoudre pour déterminer ses caractéristiques et montrer qu'il est conforme à la norme appropriée

Note 1 à l'article: Une fois ces essais effectués, ils peuvent ne pas être repris sauf si des modifications viennent en changer les caractéristiques de conception. Dans ce cas, seuls les essais nécessaires sont à répéter.

### 3.63

#### **choc de courant à demi-onde sinusoïdale unipolaire**

choc de courant unipolaire comprenant un demi-cycle de courant pratiquement sinusoïdal

### 3.64

#### **élément de parafoudre**

partie d'un parafoudre, entièrement contenue dans une enveloppe, qui peut être connectée en série et/ou en parallèle avec d'autres éléments pour réaliser un parafoudre ayant des valeurs assignées de tension et/ou de courant plus élevées

### 3.65

$T_1$

#### **durée conventionnelle du front d'un choc de courant**

durée exprimée en microsecondes égale à 1,25 fois le temps nécessaire au courant pour croître de 10 % à 90 % de sa valeur de crête

Note 1 à l'article: S'il existe des oscillations sur le front, il convient de prendre les points de référence à 10 % et à 90 % sur la courbe moyenne tracée à travers les oscillations.

### 3.66

#### **origine conventionnelle**

<d'un choc> point d'une courbe "tension en fonction du temps" ou "courant en fonction du temps" déterminé par l'intersection de l'axe des temps, à tension ou courant nul, et de la droite passant par deux points de référence sur le front du choc

Note 1 à l'article: Pour les chocs de courant, les points de référence doivent être égaux à 10 % et 90 % de la valeur de crête.

Note 2 à l'article: Cette définition ne s'applique que lorsque l'échelle des abscisses et celle des ordonnées sont toutes deux linéaires.

Note 3 à l'article: S'il existe des oscillations sur le front, il convient de prendre les points de référence à 10 % et à 90 % sur la courbe moyenne tracée à travers les oscillations.

### 3.67

#### **raideur conventionnelle du front d'un choc**

quotient de la valeur de crête par la durée conventionnelle du front d'un choc

**3.68****durée conventionnelle jusqu'à mi-valeur sur la queue d'un choc** **$T_2$** 

intervalle de temps entre l'origine conventionnelle et l'instant auquel la tension ou le courant a diminué jusqu'à atteindre la moitié de sa valeur de crête. Cette durée est exprimée en microsecondes

**4 Identification et classification****4.1 Identification des parafoudres**

Les parafoudres à oxyde métallique contenant des structures à éclateurs doivent être identifiés au moyen des indications minimales suivantes qui doivent figurer sur une plaque signalétique placée en permanence sur le parafoudre:

- la désignation du parafoudre (voir Tableau 1);
- la tension de régime permanent;
- la tension assignée;
- la fréquence assignée, uniquement si elle diffère des fréquences normales; voir 5.2;
- le courant nominal de décharge;
- le courant assigné de court-circuit en kiloampères (kA). Pour les parafoudres pour lesquels aucune valeur assignée de tenue aux courts-circuits n'est revendiquée, la valeur "0" doit être indiquée;
- le nom du constructeur ou sa marque de fabrique, le type et l'identification du parafoudre complet;
- l'année de construction;
- si la dimension de la plaque signalétique est suffisante, il convient d'y faire figurer également:
- les caractéristiques assignées de transfert de charges répétitives,  $Q_{rs}$ .

**4.2 Classification des parafoudres**

Les parafoudres de classe de distribution sont classés comme indiqué dans le Tableau 1, et ils doivent satisfaire au moins aux exigences d'essai et aux caractéristiques de fonctionnement spécifiées dans le Tableau 3.

**Tableau 1 – Classification des parafoudres**

| Classe de parafoudre                                                                                                                                                                                                                                                                        | Distribution |       |        |
|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------|-------|--------|
| Désignation                                                                                                                                                                                                                                                                                 | DH           | DM    | DL     |
| Courant nominal de décharge <sup>a</sup>                                                                                                                                                                                                                                                    | 10 kA        | 5 kA  | 2,5 kA |
| $Q_{rs}$ (C)                                                                                                                                                                                                                                                                                | ≥ 0,4        | ≥ 0,2 | ≥ 0,1  |
| $Q_{th}$ (C)                                                                                                                                                                                                                                                                                | ≥ 1,1        | ≥ 0,7 | ≥ 0,45 |
| <sup>a</sup> D'autres courants peuvent être spécifiés sur accord entre le constructeur et l'utilisateur.<br><br>NOTE Les lettres "H", "M" et "L" désignent un fonctionnement "important" ('high' en anglais), "moyen" ('medium' en anglais) et "faible" ('low' en anglais), respectivement. |              |       |        |

## 5 Caractéristiques assignées normalisées et conditions de service

### 5.1 Tensions assignées normalisées

Les tensions assignées normalisées (en kV, valeur efficace) des parafoudres sont spécifiées dans le Tableau 2 avec des échelons de tension constants dans les plages de tensions spécifiées:

**Tableau 2 – Échelons des tensions assignées**

| Plage de tensions assignées<br>kV | Échelons de tension assignée<br>kV efficace |
|-----------------------------------|---------------------------------------------|
| 3 à 30                            | 1 kV                                        |
| 30 à 52                           | 3 kV                                        |

D'autres valeurs de tensions assignées peuvent être acceptées.

### 5.2 Fréquences assignées normalisées

Les fréquences assignées normalisées sont de 50 Hz et 60 Hz.

### 5.3 Valeurs normalisées du courant nominal de décharge

Les valeurs normalisées du courant nominal de décharge 8/20 sont: 10 kA, 5 kA et 2,5 kA.

### 5.4 Conditions de service

#### 5.4.1 Conditions normales de service

Les parafoudres conformes au présent document doivent pouvoir fonctionner dans les conditions normales de service suivantes:

- a) une température ambiante de l'air comprise entre  $-40^{\circ}\text{C}$  et  $+40^{\circ}\text{C}$ ;
- b) un rayonnement solaire;

NOTE Les effets d'un rayonnement solaire maximal ( $1,1 \text{ kW/m}^2$ ) sont pris en compte en préchauffant l'éprouvette lors des essais de type. D'autres sources de chaleur qui peuvent affecter l'utilisation du parafoudre ne sont pas prises en compte dans les conditions normales de service.

- c) une altitude ne dépassant pas 1 000 m;
- d) la fréquence de la source d'alimentation en courant alternatif doit être comprise entre 48 Hz au minimum et 62 Hz au maximum;
- e) la tension à fréquence industrielle appliquée de façon continue entre les bornes du parafoudre ne dépasse pas sa tension de régime permanent;
- f) une vitesse du vent  $\leq 34 \text{ m/s}$ ;
- g) un montage vertical, non suspendu.

#### 5.4.2 Conditions d'environnement particulières

Les parafoudres destinés à des utilisations différentes ou soumis à des conditions de service autres que les conditions normales peuvent exiger une étude spéciale pour leur conception, leur construction ou leur utilisation. L'utilisation du présent document en cas de conditions d'environnement particulières est soumise à un accord entre le constructeur et l'acheteur. Une liste des conditions anormales de service possibles est donnée dans l'Annexe A.

## 6 Exigences

### 6.1 Tenue diélectrique

Le parafoudre doit être conçu de sorte que les enveloppes soient capables de résister de manière appropriée aux tensions lors de la conduction des courants de choc de foudre, et à des surtensions à fréquence industrielle maximales anticipées. La capacité de tenue diélectrique externe des enveloppes doit être démontrée par des essais selon 8.2, tandis que leur capacité de tenue diélectrique interne doit être démontrée par des essais selon 8.13.

### 6.2 Tensions résiduelles

L'objectif du mesurage des tensions résiduelles est d'obtenir les valeurs maximales de ces tensions résiduelles pour un type donné et pour tous les courants et formes d'ondes spécifiés. Ces valeurs sont déduites du résultat des essais de type ainsi que de la valeur spécifiée et publiée par le constructeur pour la tension résiduelle maximale sous le courant de choc de foudre utilisé lors des essais individuels de série.

La tension résiduelle maximale d'un modèle de parafoudre donné, pour un courant et une forme d'onde donnés, est calculée en multipliant la tension résiduelle des fractions soumises à l'essai lors des essais de type par un facteur d'échelle spécifique. Le facteur d'échelle est égal au rapport entre la tension résiduelle maximale déclarée, telle que vérifiée pendant les essais individuels de série, et la tension résiduelle mesurée sur les fractions pour le même courant et la même forme d'onde.

La documentation du constructeur doit contenir, pour chaque parafoudre énuméré, les informations suivantes concernant la tension résiduelle:

- la tension résiduelle maximale au choc de foudre pour les courants de choc d'au moins 0,5, 1 et 2 fois le courant nominal de décharge du parafoudre (voir 8.3.2.3)
- la tension résiduelle maximale de choc de courant à front raide, à l'exclusion de la contribution de tension inductive, pour un courant de choc dont la valeur de crête est égale au courant nominal de décharge du parafoudre (voir 8.3.2.2)
- la tension résiduelle maximale de choc de courant à front raide, y compris la contribution de tension inductive, pour un courant de choc dont la valeur de crête est égale au courant nominal de décharge du parafoudre. Cette tension résiduelle doit être égale à

NOTE Les tensions résiduelles maximales types pour différents types de parafoudres sont données dans l'Annexe F de l'IEC 60099-5:2018.

### 6.3 Niveaux de protection au choc

Le parafoudre doit être soumis à l'essai afin de déterminer si le niveau de protection pour une forme d'onde spécifiée dépend de la valeur maximale d'amorçage au choc (8.3.3) ou de la tension résiduelle (8.3.2), selon la plus grande des deux valeurs.

### 6.4 Décharges partielles internes

Dans des conditions normales de fonctionnement en environnement sec, les décharges partielles internes doivent être inférieures à un niveau susceptible de provoquer l'endommagement des éléments internes. Ceci doit être démontré par un essai individuel de série selon le point c) de 9.1.

### 6.5 Taux de fuite de l'étanchéité

Pour les parafoudres avec volume interne de gaz et système séparé d'étanchéité, des taux de fuite de l'étanchéité doivent être spécifiés comme cela est défini en 8.12 et au point d) de 9.1.

## 6.6 Stabilité thermique

Après accord entre le constructeur et l'acheteur, un essai spécial de stabilité thermique peut être réalisé selon 9.2.2.

## 6.7 Capacité de dissipation de chaleur de l'échantillon pour essai

Pour l'essai de fonctionnement des parafoudres (8.5) et l'essai de tension à fréquence industrielle en fonction du temps (8.6), le comportement de l'échantillon pour essai dépend, dans une large mesure, de sa capacité à dissiper la chaleur, c'est-à-dire à se refroidir à la suite d'une contrainte de décharge.

En conséquence, pour que l'essai apporte des renseignements corrects, les échantillons pour essai doivent avoir une capacité de dissipation de chaleur et une chaleur massique équivalentes à celles du parafoudre complet, tant en régime transitoire qu'en régime permanent. En principe, lorsqu'elles sont soumises à la même contrainte de tension dans les mêmes conditions ambiantes, il convient que les résistances MO atteignent la même température dans l'échantillon et dans le parafoudre complet.

## 6.8 Tenue au transfert de charges répétitives

Les parafoudres complets doivent supporter des transferts de charges répétitives suivant les modalités décrites pour les essais de type (voir 8.4).

La tenue au transfert de charges répétitives est démontrée sur des parafoudres complets dont les tensions assignées sont comprises entre 3 kV et 12 kV dans l'essai de vérification des caractéristiques assignées de transfert de charges répétitives (voir 8.4.2.2).

NOTE Il peut exister des applications particulières pour lesquelles les transferts de charges simples provoquent des dissipations d'énergie supérieures aux caractéristiques assignées d'énergie thermique de même nature.

## 6.9 Fonctionnement des parafoudres

Les parafoudres doivent être capables d'absorber l'énergie générée par les manœuvres ou la charge de transfert générée par les chocs de foudre, et doivent par la suite pouvoir faire l'objet d'une récupération thermique sous l'application d'une surtension temporaire et suivant des conditions de tension de régime permanent. Cette capacité est démontrée par l'essai de fonctionnement des parafoudres (voir 8.5).

## 6.10 Caractéristiques de tension à fréquence industrielle en fonction du temps d'un parafoudre

Le constructeur doit indiquer les durées admissibles d'application de différentes valeurs de la tension à fréquence industrielle qui peut être appliquée au parafoudre après que ce dernier a été préchauffé à la température initiale selon 8.5.2.3 sans détérioration ou emballement thermique. Les informations doivent être fournies sans l'application d'énergie ou de charge préalable et – dans le cas de  $I_n = 10$  kA – sans l'application des caractéristiques assignées de transfert de charges thermiques  $Q_{th}$ .

Ces indications doivent être présentées sous forme de courbes de la tension à fréquence industrielle en fonction du temps (courbes TOV), avec application d'énergie ou de charge préalable à l'application de la tension à fréquence industrielle indiquée sur la courbe susmentionnée. La caractéristique TOV est démontrée sur un parafoudre complet qui représente le transfert thermique le plus défavorable pour l'essai de vérification de la caractéristique de tension à fréquence industrielle en fonction du temps (essai TOV) (voir 8.6).



### 6.11 Performances de tenue aux courts-circuits

Le constructeur doit déclarer des caractéristiques assignées de courant de court-circuit pour chaque famille de parafoudres. La valeur assignée "zéro" peut être revendiquée uniquement pour les applications avec des courants de court-circuit prévus inférieurs à 1 kA. Dans ce cas, la valeur "0" doit être indiquée sur la plaque signalétique. Dans tous les cas, le parafoudre doit être soumis à un essai de court-circuit selon 8.9 pour indiquer qu'il ne subit pas de défaillance telle qu'elle occasionne une rupture explosive de l'enveloppe et que l'autoextinction de flammes nues (le cas échéant) se produise dans un délai défini.

### 6.12 Dispositifs de déconnexion

#### 6.12.1 Tenue du dispositif de déconnexion

Lorsqu'un parafoudre est équipé d'un dispositif de déconnexion (intégré ou séparé), ce dispositif doit supporter, sans fonctionner, chacun des essais suivants:

- essai de vérification des caractéristiques assignées de transfert de charges répétitives,  $Q_{rs}$  (voir 8.4.2.2);
- essai de fonctionnement des parafoudres avec les valeurs assignées des caractéristiques assignées de charge thermique,  $Q_{th}$  (voir 8.5.2);
- essais mécaniques sur accord entre le constructeur et l'utilisateur (voir NOTE à 8.7.4.1);
- essai de cycles de températures et de pompage d'étanchéité (voir 8.7.5)

#### 6.12.2 Fonctionnement du dispositif de déconnexion

Le laps de temps de fonctionnement du dispositif de déconnexion est déterminé pour trois valeurs de courant selon 8.7.3. Le dispositif doit assurer clairement une séparation effective et permanente.

### 6.13 Exigences pour les éléments de répartition internes

Les éléments de répartition internes, s'ils sont utilisés dans le parafoudre, doivent être capables de résister à la combinaison de contraintes qui apparaissent en service, et l'impédance des éléments de répartition doit également présenter une stabilité suffisante au cours de la durée de vie en service. Ceci doit être démontré par l'essai de fonctionnement des parafoudres (voir 8.5) et l'essai TOV (voir 8.6) réalisés avec des éléments de répartition internes inclus dans les fractions d'essai.

De plus, les éléments doivent résister aux essais de vieillissement accéléré et aux essais cycliques spécifiés en 8.13.

### 6.14 Amorçage à fréquence industrielle

Un essai d'amorçage à fréquence industrielle doit être réalisé sur des parafoudres avec éclateurs. La tension minimale d'amorçage à fréquence industrielle du parafoudre doit être indiquée par le constructeur.

### 6.15 Efforts mécaniques

#### 6.15.1 Généralités

Le constructeur doit spécifier les efforts maximaux en tête admissibles lors de l'installation et en service, tels que des efforts de flexion, de torsion et de traction.

#### 6.15.2 Moment de flexion

Le parafoudre doit être capable de résister aux valeurs des efforts de flexion déclarées par le constructeur (voir 8.10).

Lors de la détermination de l'effort mécanique appliqué à un parafoudre, il convient que l'utilisateur prenne en compte par exemple, le vent, la glace et les forces électromagnétiques susceptibles d'affecter l'installation.

Il convient que les parafoudres emballés résistent aux contraintes de transport spécifiées par l'utilisateur conformément à l'IEC 60721-3-2, et qui ne soient jamais inférieures à la classe 2M1.

NOTE Contrairement aux parafoudres à enveloppe en porcelaine, les parafoudres à enveloppe synthétique peuvent présenter des déformations mécaniques en service.

### **6.15.3 Résistance aux contraintes d'environnement**

Le parafoudre doit être capable de résister aux contraintes d'environnement définies en 8.11.

### **6.15.4 Embase isolante et console de montage**

Lorsqu'une embase isolante et/ou une console de montage sont fournies avec le parafoudre, celles-ci doivent être soumises à des essais mécaniques séparément du parafoudre (voir 8.10.6).

### **6.15.5 Valeur de l'effort moyen à la rupture (MBL)**

Pour les parafoudres à enveloppe en porcelaine et à enveloppe de résine moulée, le MBL doit être  $\geq 1,2$  fois l'effort à court terme spécifié (SSL). Ceci doit être démontré dans l'essai de moment de flexion décrit en 8.10.

## **6.16 Compatibilité électromagnétique**

Les parafoudres ne sont pas sensibles aux perturbations électromagnétiques et aucun essai d'immunité n'est donc nécessaire.

Dans des conditions normales de fonctionnement en environnement sec, les parafoudres ne doivent pas émettre de perturbations significatives. À la demande des utilisateurs, chaque constructeur doit fournir des informations suffisantes pour que tous les composants du parafoudre puissent être mis au rebut et/ou recyclés conformément aux règlements internationaux et nationaux.

## **6.17 Fin de vie**

À la demande des utilisateurs, chaque constructeur doit fournir des informations suffisantes pour que tous les composants du parafoudre puissent être mis au rebut et/ou recyclés conformément aux règlements internationaux et nationaux.

## **7 Conditions générales des procédures d'essai**

### **7.1 Appareillage de mesure et exactitude**

L'appareillage de mesure doit satisfaire aux exigences de l'IEC 60060-2. Les valeurs obtenues doivent être acceptées comme valeurs exactes à des fins de conformité aux articles d'essai pertinents.

Sauf indication contraire, tous les essais aux tensions à fréquence industrielle doivent être effectués sous une tension alternative ayant une fréquence comprise entre les limites de 48 Hz et 62 Hz et une forme d'onde pratiquement sinusoïdale.

## 7.2 Échantillons pour essai

### 7.2.1 Généralités

Sauf spécification contraire, tous les essais doivent être effectués sur des éléments de parafoudres complets. Ces matériels doivent être neufs, propres, complètement montés (par exemple, avec les anneaux de garde s'ils sont utilisés) et installés dans des conditions simulant le plus fidèlement possible les conditions de service.

En général, les échantillons doivent couvrir la tension résiduelle la plus élevée et la tension de référence la plus faible du type de résistances MO utilisées dans le parafoudre. Lorsque les caractéristiques assignées de transfert de charges thermiques sont spécifiées pour l'essai de fonctionnement des parafoudres et pour l'essai TOV (voir 8.5 et 8.6), les échantillons doivent avoir le niveau de protection le plus élevé contre les chocs de foudre  $U_{pl}$  par unité de longueur du modèle. Lorsque les caractéristiques assignées d'énergie thermique sont spécifiées pour l'essai de fonctionnement des parafoudres, les échantillons pour essai doivent avoir une valeur de tension de référence à l'extrémité inférieure de la plage de variation déclarée par le constructeur. Pour satisfaire à ces exigences, les conditions suivantes doivent être remplies:

- a) Le rapport entre la tension assignée du parafoudre complet et la tension assignée de la fraction est appelé  $n$ . Le volume des éléments de résistances MO utilisés comme échantillons pour essai ne doit pas être supérieur au volume minimal de l'ensemble des éléments de résistances MO utilisés dans le parafoudre complet divisé par  $n$ .
- b) La tension de régime permanent appliquée pour les essais de récupération thermique doit satisfaire à l'exigence suivante: Le rapport entre la tension de régime permanent et la tension assignée de la fraction ne doit pas être inférieur au rapport maximal revendiqué pour le type de parafoudre.

### 7.2.2 Échantillons pour les essais de tension résiduelle

Les échantillons dédiés aux essais de tension résiduelle doivent être des parafoudres complets, des colonnes de résistances MO connectées en série ou des résistances MO individuelles en air calme. Pour les parafoudres à plusieurs colonnes, les échantillons peuvent être constitués du nombre réel de résistances MO ou de colonnes de résistances montées en parallèle, ou d'une seule résistance MO, voire d'une seule colonne de résistances, respectivement.

### 7.2.3 Échantillons dédiés à l'essai de vérification des caractéristiques assignées de transfert de charges répétitives, $Q_{rs}$

#### 7.2.3.1 Généralités

Les résistances MO et les éclateurs en série doivent être soumis à l'essai.

#### 7.2.3.2 Résistances MO

Les échantillons doivent être soit des parafoudres complets, soit des résistances MO en air calme ou dans le milieu environnant réel du modèle. Le choix est laissé au constructeur.

Les échantillons doivent avoir la longueur la plus élevée du type de résistances MO utilisées dans la conception et doivent avoir une contrainte de tension résiduelle  $10 \text{ kA}$  non inférieure à  $0,97 \times (U_{10 \text{ kA}} \text{ par mm de longueur de résistance MO})_{\max}$ , où  $(U_{10 \text{ kA}} \text{ par mm de longueur de résistance MO})_{\max}$  est la contrainte de tension résiduelle  $10 \text{ kA}$  la plus élevée spécifiée par le constructeur pour toute longueur du type de résistances MO utilisées dans le parafoudre. Si seuls des échantillons avec une contrainte de tension résiduelle  $10 \text{ kA}$  sont disponibles, la charge transférée exigée doit être augmentée pour l'essai du facteur

$$(U_{10 \text{ kA}} \text{ par mm de longueur de résistance MO})_{\max} / (U_{10 \text{ kA}} \text{ par mm de longueur de résistance MO})_{\text{réelle}}$$

### 7.2.3.3 Éclateurs

Les échantillons doivent être des éclateurs avec l'écartement le plus court utilisés dans la conception des parafoudres

## 8 Essais de type (essais de conception)

### 8.1 Généralités

Les essais de type définis dans cet article s'appliquent aux parafoudres à enveloppe en porcelaine. Les essais s'appliquent également aux parafoudres à enveloppe synthétique sauf indication contraire en 10.8.

Les essais de type doivent être réalisés comme indiqué dans le Tableau 3.

**Tableau 3 – Essais de type de parafoudre**

| Classe de parafoudre                                                                                             | Distribution            |
|------------------------------------------------------------------------------------------------------------------|-------------------------|
| Courant nominal de décharge                                                                                      | 10 kA<br>5 kA<br>2,5 kA |
| Valeur $U_s$ (kV) type, valeur efficace                                                                          | ≤ 52                    |
| 1 Essais de tenue diélectrique de l'enveloppe des parafoudres                                                    |                         |
| a) Choc de foudre                                                                                                | 8.2.5                   |
| c) Fréquence industrielle                                                                                        | 8.2.6                   |
| 2 Essai de niveaux de protection au choc                                                                         | 8.3                     |
| 3 Tenue au transfert de charges répétitives                                                                      | 8.4                     |
| 4 Essai de fonctionnement des parafoudres                                                                        | 8.5                     |
| 5 Tension à fréquence industrielle en fonction du temps                                                          | 8.6                     |
| 6 Dispositif de déconnexion/indicateur de défaut de parafoudre (pour les parafoudres équipés de ces dispositifs) | 8.7                     |
| 7 Essai de tension d'amorçage à fréquence industrielle                                                           | 8.8                     |
| 8 Essais de court-circuit                                                                                        | 8.9                     |
| 9 Moment de flexion                                                                                              | 8.10                    |
| 10 Essais d'environnement                                                                                        | 8.11                    |
| 11 Taux de fuite de l'étanchéité                                                                                 | 8.12                    |
| 12 Essai de vérification de la tenue diélectrique des composants internes d'un parafoudre                        | 8.13                    |
| 13 Essai des éléments de répartition internes                                                                    | 8.14                    |
| Les nombres des lignes 1 à 13 se réfèrent aux articles et aux paragraphes du présent document.                   |                         |
| NOTE Les essais de type dédiés aux parafoudres à enveloppe synthétique sont spécifiés en 10.8.                   |                         |

Le nombre exigé d'échantillons et leurs caractéristiques sont indiqués dans chaque article. Les parafoudres qui diffèrent entre eux seulement par des modalités de montage ou par la disposition de la structure de maintien et qui, par ailleurs, sont fondés sur les mêmes éléments et une construction semblable, se traduisant par des caractéristiques de fonctionnement identiques, y compris les caractéristiques de dissipation de chaleur et l'atmosphère interne, sont considérés comme étant du même type.

## 8.2 Essais de tenue diélectrique

### 8.2.1 Généralités

Les essais de tenue à la tension démontrent la capacité de tenue à la tension de l'isolation externe de l'enveloppe des parafoudres. Pour d'autres configurations, l'essai doit faire l'objet d'un accord entre le constructeur et l'utilisateur.

Les essais doivent être réalisés dans les conditions et sous les tensions d'essai spécifiées en 6.1 et rappelées ci-dessous. La surface extérieure des éléments isolants doit être nettoyée soigneusement et les éléments internes doivent être retirés ou rendus inopérants pour permettre d'effectuer ces essais.

Lorsque l'une quelconque des conditions qui associent la distance d'amorçage d'arc à sec à la tension d'essai, comme cela est décrit en 8.2.5 ou 8.2.6, est satisfaite, l'essai pertinent spécifié en 8.2.5 ou 8.2.6 peut ne pas être réalisé, étant donné que, dans ces conditions, la tension de tenue diélectrique du parafoudre satisfait intrinsèquement aux exigences minimales.

### 8.2.2 Essais sur l'enveloppe d'un élément individuel

Les essais applicables doivent être effectués sur la plus grande enveloppe de parafoudre. Si ceci ne représente pas la contrainte de tension spécifique par unité de longueur la plus élevée, des essais supplémentaires doivent être réalisés sur l'enveloppe de l'élément ayant la plus forte contrainte de tension spécifique.

Pour l'essai, les résistances MO doivent être retirées de l'enveloppe ou remplacées par des isolateurs.

### 8.2.3 Caractéristiques de l'air ambiant pendant les essais

La tension à appliquer pendant un essai de tenue est déterminée en multipliant la tension de tenue spécifiée par le facteur de correction, compte tenu de la densité de l'air et de l'humidité. Voir l'IEC 60060-1.

La correction due à l'humidité ne doit pas être appliquée pour les essais sous pluie.

### 8.2.4 Modalités des essais sous pluie

L'isolation externe des parafoudres de type extérieur doit être soumise à des essais de tenue sous pluie suivant la procédure d'essai décrite dans l'IEC 60060-1.

### 8.2.5 Essai de tension de tenue au choc de foudre

Le parafoudre doit être soumis à un essai à sec normalisé de tension de tenue au choc de foudre conformément à l'IEC 60060-1. La tension d'essai doit être au moins égale à 1,3 fois la tension résiduelle maximale du parafoudre au courant nominal de décharge.

NOTE Le facteur de 1,3 est obtenu à partir de  $1,15 \cdot e^{1000/8 \cdot 150}$ , qui reflète un facteur de coordination de 15 % afin de tenir compte des courants de décharge supérieurs aux courants nominaux et de la nature statistique de la tension de tenue diélectrique, ainsi qu'une marge de 13 % afin de tenir compte de la variation de la pression atmosphérique du niveau de la mer jusqu'aux altitudes en service normal inférieures ou égales à 1 000 m.

Quinze chocs consécutifs à la valeur de la tension d'essai doivent être appliqués pour chaque polarité. Le parafoudre doit être considéré comme ayant satisfait à l'essai si aucune décharge disruptive interne n'a lieu et si le nombre de décharges disruptives externes ne dépasse pas deux pour chaque série de 15 chocs. La tension d'essai doit être égale au niveau de protection au choc de foudre normal du parafoudre multiplié par 1,3.

Si la distance d'amorçage d'arc à sec ou la somme des distances partielles d'amorçage d'arc à sec est supérieure à la tension d'essai divisée par 500 kV/m, cet essai n'est pas exigé.

### 8.2.6 Essai de tension de tenue à fréquence industrielle

Les enveloppes des parafoudres destinés à un usage extérieur doivent être soumises à un essai sous pluie, et celles des parafoudres destinés à un usage intérieur doivent être soumises à un essai à sec.

Les enveloppes des parafoudres de classe de distribution selon le Tableau 1 doivent supporter pendant 1 min une tension à fréquence industrielle dont la valeur de crête est égale au niveau de protection contre les chocs de foudre multiplié par 0,88.

NOTE 1 Le facteur de 0,88 tient compte d'une marge de sécurité de 1,15 pour des courants de choc de foudre supérieurs au courant nominal de décharge, d'un facteur de correction d'altitude de 1,13 pour une altitude d'installation de 1 000 m, d'un facteur 0,8 sous forme d'un rapport type entre le niveau de protection contre les chocs de manœuvre et de foudre et d'un facteur de conversion d'essai de  $0,6 \times \sqrt{2}$  pour la conversion entre la tension de choc de manœuvre et la valeur de crête de la tension à fréquence industrielle selon le Tableau 2 de l'IEC 60071-2:2018.

NOTE 2 Si la distance d'amorçage d'arc à sec ou la somme des distances partielles d'amorçage d'arc à sec est plus grande que celle donnée par l'équation  $d = [1,82 \times (e^{(U/859)} - 1)]^{0,833}$ , où  $d$  est la distance en m et  $U$  est la valeur de crête de la tension d'essai à fréquence industrielle en kV, cet essai n'est pas exigé. -

NOTE 3 L'équation est issue de la formule G.1 de l'IEC 60071-2:2018, où la valeur de crête de  $U_{50}$  est donnée sous la forme  $\times \sqrt{2} \times \ln(1 + 0,55 \times d^{1,2})$ ,  $d$  étant la distance. Suivant les recommandations de l'IEC 60071-2, pour les besoins du présent document, le facteur d'écart  $k$  est censé être égal à 1, la tension de tenue est censée être égale à 90 % de  $U_{50}$ , et un facteur de réduction de 10 % de  $U_{50}$  est prévu par hypothèse pour les conditions humides par rapport à un environnement sec.

## 8.3 Essais de niveaux de protection au choc

### 8.3.1 Généralités

L'objectif du mesurage du niveau de protection au choc consiste à obtenir le niveau de protection maximal pour un type donné et pour tous les courants et formes d'onde de tensions spécifiés.

La procédure d'essai générale suivante doit être appliquée:

- Appliquer les ondes de tension au choc présumées, mesurer les tensions de crête de parafoudre obtenues et comparer ces tensions avec le niveau de tension résiduelle approprié.
- Lorsque la tension maximale de parafoudre résultant de l'application de ces chocs de tension présumés est inférieure au niveau de tension résiduelle de parafoudre, le niveau de protection pour cette forme d'onde est alors le niveau de tension résiduelle de parafoudre.
- À défaut, des essais d'amorçage doivent être effectués et le niveau de protection pour cette forme d'onde est la valeur maximale d'amorçage. Les niveaux de protection au choc doivent être établis par l'amorçage à front d'onde et l'amorçage au choc 1,2/50.

### 8.3.2 Essais de tension résiduelle

#### 8.3.2.1 Généralités

La mesure de la tension résiduelle lors de l'essai de type a pour objectif de fournir les éléments nécessaires au calcul de la tension résiduelle maximale. Cela passe par la détermination du rapport entre les tensions aux courants de chocs spécifiés et le niveau de tension vérifié lors des essais individuels de série. Cette dernière tension résiduelle peut être soit la tension pour un courant nominal de décharge, soit être la tension résiduelle pour un courant de choc de foudre approprié compris entre 0,01 et 2 fois le courant nominal de décharge, selon le choix fait par le constructeur pour les modalités des essais individuels de série.

La tension résiduelle maximale au courant de choc de foudre utilisée pour les essais individuels de série doit être spécifiée et publiée par le constructeur. Pour obtenir les tensions résiduelles maximales du modèle considéré pour tous les courants et toutes les formes d'ondes spécifiés, les tensions résiduelles mesurées sur les fractions d'essai sont multipliées par le rapport entre la tension résiduelle maximale déclarée au courant de l'essai individuel de série et la tension résiduelle mesurée sur la fraction pour le même courant.

Tous les essais de tension résiduelle doivent être effectués sur les trois mêmes échantillons de parafoudres complets ou de fractions de parafoudre. Le temps séparant les décharges doit être suffisant pour permettre aux échantillons de revenir à une température égale à la température ambiante dans des limites de 5 °C.

### 8.3.2.2 Essai de tension résiduelle au choc de courant à front raide

Un choc de courant à front raide avec une valeur de crête égale au courant nominal de décharge du parafoudre  $\pm 5\%$  doit être appliqué à chacun des trois échantillons. La valeur de crête et la forme de choc de tension apparaissant aux bornes des trois échantillons doivent être enregistrées et, si nécessaire, corrigées des effets inductifs du circuit de mesure de la tension, ainsi qu'en fonction de la géométrie de l'échantillon pour essai et du circuit d'essai.

La procédure suivante doit être utilisée pour déterminer si une correction des effets inductifs est exigée:

- Un choc de courant à front raide tel que décrit ci-dessus doit être appliqué à un bloc métallique non ferreux de mêmes dimensions que les échantillons de résistances MO en essai. La valeur de crête et la forme d'onde apparaissant aux bornes du bloc métallique doivent être enregistrées.
- Si la tension de crête sur le bloc métallique est inférieure à 2 % de la tension de crête des échantillons de résistances MO, aucune correction inductive des mesurages effectués sur les résistances MO n'est exigée.
- Si la tension de crête sur le bloc métallique est comprise entre 2 % et 20 % de la tension de crête de l'échantillon de résistance MO, alors la forme de choc de tension aux bornes du bloc métallique doit être soustraite de la forme de choc des tensions mesurées sur chacune des résistances MO, et les valeurs de crête des formes de choc ainsi obtenues doivent être enregistrées comme valeurs corrigées des tensions des résistances MO.
- Si la tension de crête sur le bloc métallique est supérieure à 20 % de la tension de crête sur les échantillons de résistances MO, alors le circuit d'essai et le circuit de mesure de la tension doivent être améliorés, et l'essai doit être repris.

NOTE 1 Une manière possible de réaliser des formes d'onde de courant identiques pour tous les mesurages consiste à les appliquer en même temps sur l'échantillon pour essai et sur le bloc métallique en série dans le circuit d'essai. Il est nécessaire d'inverser uniquement leurs positions respectives pour la mesure de la chute de tension sur le bloc métallique ou sur l'échantillon pour essai.

La tension résiduelle la plus élevée parmi les trois tensions résiduelles mesurées, corrigée si nécessaire comme indiqué ci-dessus, et multipliée par le facteur d'échelle (voir 7.2) est définie comme le niveau de protection contre les courants à front raide du parafoudre, à l'exclusion de la contribution de la tension inductive de ce dernier.

NOTE 2 La présence de conducteurs de connexion destinés à relier le parafoudre au réseau d'alimentation introduit une chute de tension inductive supplémentaire pour les chocs de courant à front raide.

### 8.3.2.3 Essai de tension résiduelle au choc de foudre

Chacun des trois échantillons doit être soumis à un choc de courant de foudre avec des valeurs de crête approximativement égales à 0,5, 1 et 2 fois le courant nominal de décharge du parafoudre. La durée conventionnelle du front doit être comprise entre 7  $\mu$ s et 9  $\mu$ s, tandis que la durée jusqu'à mi-valeur (qui n'est pas critique) peut avoir n'importe quelle tolérance. Les tensions résiduelles sont déterminées selon 6.2. Les valeurs maximales des tensions résiduelles déterminées doivent être portées sur une courbe donnant la tension résiduelle en



fonction du courant de décharge. La tension résiduelle lue sur cette courbe correspondant au courant nominal de décharge est définie comme le niveau de protection contre les chocs de foudre du parafoudre.

Si un essai individuel de série du parafoudre complet ne peut être effectué à l'un des courants susmentionnés, des essais de type complémentaires doivent alors être effectués avec un courant compris entre 0,01 et 0,25 fois le courant nominal de décharge, pour comparaison avec le parafoudre complet.

### **8.3.3 Essais d'amorçage**

#### **8.3.3.1 Généralités**

Des essais d'amorçage doivent être effectués sur trois échantillons de parafoudres complets de chaque tension assignée vérifiée par essai. Les caractéristiques de fonctionnement applicables aux autres tensions assignées de même type à  $\pm 20\%$  (ou 3 kV, selon la plus grande des deux valeurs) d'un échantillon pour essai assigné peuvent être déterminées par réglage du niveau de tension proportionnellement aux tensions assignées. Compte tenu de la dépendance à la température d'amorçage de l'éclateur, il convient d'effectuer les essais à une température comprise entre 20 °C et 25 °C, ainsi que d'effectuer un essai supplémentaire à une température élevée (de préférence entre 40 °C et 50 °C). En cas de différence avérée entre les résultats, le plus élevé des deux résultats doit alors être utilisé pour des essais et des comparaisons ultérieurs.

#### **8.3.3.2 Niveau de protection à front rapide**

##### **8.3.3.2.1 Généralités**

Cet essai détermine si l'amorçage du parafoudre pour un choc de foudre à front d'onde peut dépasser sa tension résiduelle du courant à front raide.

##### **8.3.3.2.2 Essai de détermination de l'amorçage au choc à front d'onde**

Cet essai est réalisé en appliquant à la fois des chocs à polarité positive et des chocs à polarité négative. L'amplitude présumée de l'onde d'essai doit être égale au minimum à 1,2 fois la tension résiduelle du courant à front raide du parafoudre. Au moins cinq décharges doivent être mesurées pour chaque polarité. Le taux nominal de montée du front d'onde d'essai doit être de 8,33 kV/µs pour chaque kilovolt de tension assignée de parafoudre.

La tension de parafoudre maximale enregistrée au cours de cinq chocs de polarité positive et cinq chocs de polarité négative doit être comparée à la tension résiduelle de courant à front raide. Si la tension résiduelle de courant à front raide dépasse les valeurs de tension mesurées au cours de l'essai de choc décrit ci-dessus, elle correspond au niveau de protection à front rapide et aucun essai ultérieur n'est exigé sur cette forme d'onde. Si la tension mesurée au cours de l'essai de choc dépasse la tension résiduelle de courant à front raide, passer à 8.3.3.2.3 afin de déterminer le niveau de protection à front rapide.

##### **8.3.3.2.3 Essais d'amorçage au choc à front d'onde-**

Cet essai doit être réalisé en appliquant à la fois des chocs à polarité positive et des chocs à polarité négative. La valeur de crête présumée de l'onde d'essai doit être suffisamment élevée pour que l'amorçage du parafoudre se produise avant d'atteindre 90 % de la valeur de crête de l'onde d'essai. Au moins cinq amorçages doivent être enregistrés pour chaque polarité et la valeur de crête la plus élevée ainsi enregistrée doit être consignée comme la valeur d'amorçage à front d'onde maximale du parafoudre d'essai et prise comme le niveau de protection à front rapide. Le taux nominal de montée du front d'onde d'essai doit être le même que celui décrit en 8.3.3.2.2.



### 8.3.3.3 Essai de niveaux de protection au choc de foudre normal

#### 8.3.3.3.1 Généralités

Cet essai détermine si la tension d'amorçage du parafoudre pour un choc de foudre normal peut dépasser la tension résiduelle obtenue à partir d'un choc 8/20 au courant nominal comme indiqué en 8.3.3.3.2.

#### 8.3.3.3.2 Essai de détermination de l'amorçage au choc de foudre normal

L'essai est réalisé en utilisant au moins cinq ondes positives et cinq ondes négatives. Une amplitude présumée minimale égale à 1,2 fois la tension résiduelle du parafoudre au courant nominal de décharge tel qu'indiqué en 8.3.2.3 doit être utilisée. La tension de parafoudre maximale enregistrée lors des cinq chocs de foudre normaux à polarité positive et des cinq chocs de foudre normaux à polarité négative doit être comparée à la tension résiduelle obtenue avec les courants nominaux de décharge en 8.3.2.3. Si la tension résiduelle de courant nominal de décharge dépasse les valeurs de tension mesurées au cours de l'essai de tension d'amorçage au choc de foudre normal décrit plus haut, elle correspond au niveau de protection normalisé contre la foudre et aucun essai ultérieur n'est exigé sur cette forme d'onde. Si la tension mesurée au cours de l'essai de choc de foudre normal dépasse la tension résiduelle de courant nominal de décharge, passer à 8.3.3.3.3 (essai de tension d'amorçage au choc de foudre normal) afin de déterminer le niveau de protection au choc de foudre normal.

#### 8.3.3.3.3 Essai d'amorçage au choc de foudre normal

L'objectif de cet essai consiste à déterminer la tension de tenue au choc de foudre normal la plus élevée d'une durée de plus de 3  $\mu$ s que le parafoudre supporte sans amorçage.

Pour chaque polarité, la procédure d'essai doit être la suivante:

- a) Déterminer la tension de charge de base de l'alternateur,  $U_G$ , selon la méthode décrite dans la note suivante et enregistrer la tension de crête et le temps d'amorçage (lorsque celui-ci se produit) pour chacun des 20 chocs qui permettent d'établir  $U_G$ .

NOTE La procédure qui permet d'établir  $U_G$  est la suivante: Commencer par l'application d'un choc dont la tension de crête présumée est quelque peu inférieure à la tension d'amorçage attendue du parafoudre, en augmentant la tension de charge de l'alternateur par paliers de 5 % environ pour les chocs ultérieurs jusqu'à ce qu'un amorçage se produise. Appliquer ensuite une série de 20 chocs, en réduisant la tension de crête présumée de 5 % environ après chaque amorçage et en augmentant cette même tension également de 5 % environ après chaque essai de tenue.  $U_G$  est la tension de charge moyenne de l'alternateur utilisée au cours de la série de 20 chocs.

- b) Appliquer cinq chocs au moyen d'une tension de charge de l'alternateur inférieure ou égale à 1,05  $U_G$  et enregistrer la tension de crête et le temps d'amorçage. En l'absence d'amorçage dans un délai de 3,0  $\mu$ s après le point zéro conventionnel pour chacun des cinq chocs, augmenter la tension de charge de l'alternateur par incréments supplémentaires de 0,05  $U_G$  au plus jusqu'à l'obtention d'un niveau qui provoque un amorçage dans un délai de 3,0  $\mu$ s après le point zéro conventionnel pour chacune des cinq applications. La tension de crête présumée la plus élevée de chaque polarité exigée pour l'obtention de cinq amorçages avec cinq applications successives de chocs d'essai à une tension de charge constante de l'alternateur doit être consignée comme le niveau de protection au choc de foudre normal du parafoudre.

### 8.4 Essai de vérification des caractéristiques assignées de transfert de charges répétitives, $Q_{rs}$

#### 8.4.1 Généralités

L'objectif de cet essai consiste à vérifier les caractéristiques assignées de transfert de charges répétitives,  $Q_{rs}$ , d'un parafoudre. Une valeur  $Q_{rs}$  issue de la liste des valeurs donnée dans le Tableau 1 doit être attribuée au parafoudre.

La capacité de transfert de charges répétitives est spécifiée comme une contrainte de courant de choc qui peut être supportée par les résistances MO et les éclateurs d'un parafoudre à vingt reprises sans dommage mécanique ou sans dommage électrique inacceptable. Il est considéré qu'une contrainte de courant de choc représente un transfert de charges qui peut se produire dans des conditions de réseau réelles.

Les caractéristiques assignées de transfert de charges répétitives sont liées à une certaine probabilité de défaillance très faible, et ne constituent de ce fait pas une valeur déterministe, mais en revanche statistique. L'essai est réalisé sur des résistances MO individuelles et des éclateurs à une valeur de charge égale à au moins 1,1 fois la valeur assignée  $Q_{rs}$  choisie dans le Tableau 1 selon la classe de parafoudre soumise à l'essai.

La charge a été choisie comme base d'essai pour une meilleure comparaison entre les différentes marques de résistances MO.

Des courants de chocs de foudre 8/20  $\mu$ s doivent être utilisés.

## 8.4.2 Résistances MO

### 8.4.2.1 Généralités

Des essais doivent être réalisés sur 10 échantillons de résistances MO sélectionnés selon 7.2.3.2. Au choix du constructeur, les échantillons peuvent être des résistances MO individuelles ou être combinés en colonnes de deux résistances ou plus sous réserve de soumettre à l'essai un nombre total de 10 résistances.

### 8.4.2.2 Procédure d'essai

La Figure 1 présente la procédure d'essai pour les résistances MO.

|                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                    |
|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <p>Mesurages initiaux</p> <ul style="list-style-type: none"> <li>Essai de tension résiduelle au courant nominal de décharge</li> </ul>                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                             |
| <p>Application de 1,1 fois <math>Q_{rs}</math></p> <ul style="list-style-type: none"> <li>1<sup>re</sup> séquence: 20 chocs par échantillon</li> <li>Si, au cours de la première séquence, un échantillon de résistance MO au plus est défaillant: l'essai de résistances MO est satisfait</li> <li>Si deux échantillons de résistances MO au plus sont défaillants au cours de la première séquence: effectuer la seconde séquence avec 10 nouveaux échantillons de résistances MO (20 chocs par échantillon)</li> </ul> <p>Si trois échantillons de résistances MO ou plus sont défaillants au cours de la première séquence, ou si tout échantillon de résistance MO est défaillant dans la seconde séquence: l'essai de résistances MO n'est pas satisfait</p> |
| <p>Mesurages finaux</p> <ul style="list-style-type: none"> <li>capacité de tenue à un choc de courant 8/20 d'au moins 0,5 kA/cm<sup>2</sup> de densité de courant de crête ou 2 fois la valeur <math>I_n</math>, selon la plus faible des deux valeurs</li> </ul> <p>Essai de tension résiduelle au courant nominal de décharge</p>                                                                                                                                                                                                                                                                                                                                                                                                                                |

IEC

**Figure 1 – Procédure de vérification des caractéristiques assignées de transfert de charges répétitives,  $Q_{rs}$ , pour les résistances MO**

La procédure suivante doit être suivie:

- Chaque échantillon doit être soumis à un essai de tension résiduelle au courant nominal de décharge. Pour les échantillons de parafoudres à plusieurs colonnes, le courant

nominal de décharge appliqué pour l'essai est le courant nominal de décharge le plus élevé utilisé pour le type d'échantillon de tout modèle.

- Dans une première séquence d'essai, chaque échantillon doit être soumis à vingt chocs de courant de foudre 8/20 administrés en dix ensembles de deux chocs, avec un temps de 50 s à 60 s entre les chocs au sein d'un même ensemble, et un temps suffisant entre les ensembles pour permettre un refroidissement à la température ambiante.

Le contenu de la charge de chaque choc doit être au moins égal aux caractéristiques assignées de transfert de charges répétitives revendiquées multipliées par 1,1;

NOTE L'exigence concernant la réalisation d'un essai à au moins 1,1 fois les valeurs de charge assignée est considérée comme garantissant une confiance suffisante dans le fait que les caractéristiques de fonctionnement des résistances MO individuelles peuvent également être attribuées aux parafoudres complets construits à partir de ce type de résistances MO.

- Si un échantillon est défaillant, une seconde séquence identique à la première doit être effectuée sur 10 échantillons supplémentaires (si deux échantillons ou plus sont défaillants, l'essai complet n'est pas satisfait).
- Les échantillons conservés doivent être soumis à un choc de courant 8/20 d'au moins 0,5 kA/cm<sup>2</sup> de densité de courant de crête ou 2 fois la valeur  $I_n$ , selon la plus faible des deux valeurs.
- Ces échantillons doivent une nouvelle fois être soumis à un essai de tension résiduelle au courant nominal de décharge.

#### 8.4.2.3 Évaluation de l'essai

L'essai doit être considéré comme satisfait pour les résistances MO lorsque toutes les exigences suivantes sont satisfaites:

- un échantillon au plus a présenté une défaillance pendant la première séquence, ou deux échantillons au plus ont présenté une défaillance au cours de deux séquences d'essai.

NOTE Lorsqu'une seule défaillance se produit au cours de la première séquence et lorsque cela se produit, dans le cas le plus défavorable, lors de la toute première application de choc, 180 chocs sans aucune défaillance auront été appliqués à la fin de la séquence, donnant une probabilité de défaillance maximale de  $1/181 = 0,0056$  ou 0,56 % pour l'essai complet. Lorsque deux défaillances se produisent au cours de la première séquence et lorsque cela se produit, une nouvelle fois dans le cas le plus défavorable, lors des toutes premières applications sur deux échantillons, 360 chocs sans aucune défaillance auront été appliqués à la fin des deux séquences, donnant de nouveau une probabilité de défaillance maximale de  $2/362 = 0,0056$  ou 0,56 % pour l'essai complet.

- absence de dommage mécanique des résistances restantes lors de l'inspection visuelle
- chaque échantillon restant démontre une capacité de tenue à un choc de courant 8/20 d'au moins 0,5 kA/cm<sup>2</sup> de densité de courant de crête ou 2 fois la valeur  $I_n$ , selon la plus faible des deux valeurs
- la variation de la tension résiduelle des échantillons conservés à un courant nominal de décharge est de  $\pm 5$  %

#### 8.4.3 Éclateurs en série

##### 8.4.3.1 Généralités

Des essais doivent être réalisés sur trois éclateurs en série avec l'écartement le plus court parmi tous les éclateurs en série utilisés dans la conception des parafoudres. Au choix du constructeur, les éclateurs peuvent être soumis à l'essai séparément des résistances MO ou en série avec trois échantillons de résistances MO (voir 8.4.2).

##### 8.4.3.2 Procédure d'essai

La Figure 2 présente la procédure d'essai pour les éclateurs en série.

|                                                                                                                                                                   |
|-------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Mesurages initiaux                                                                                                                                                |
| <ul style="list-style-type: none"> <li>• Essai de tension d'amorçage à fréquence industrielle</li> <li>• Essai de tension d'amorçage au choc de foudre</li> </ul> |
| Application de 1,1 fois $Q_{rs}$                                                                                                                                  |
| Mesurages finaux                                                                                                                                                  |
| <ul style="list-style-type: none"> <li>• Essai de tension d'amorçage à fréquence industrielle</li> <li>• Essai de tension d'amorçage au choc de foudre</li> </ul> |

IEC

**Figure 2 – Procédure de vérification des caractéristiques assignées de transfert de charges répétitives,  $Q_{rs}$ , pour les éclateurs en série**

La procédure suivante doit être suivie:

- Chaque échantillon doit être soumis à un essai d'amorçage à fréquence industrielle et à un essai de tension d'amorçage au choc de foudre.
- Chaque échantillon doit être soumis à vingt chocs de courant administrés en dix ensembles de deux chocs, avec un temps de 50 s à 60 s entre les chocs au sein d'un même ensemble, et un temps suffisant entre les ensembles pour permettre un refroidissement à la température ambiante.

La forme d'onde et la durée des chocs de courant ne sont pas importantes, à l'exception du fait que le contenu de la charge de chaque choc doit être au moins égal aux caractéristiques assignées de transfert de charges répétitives revendiquées multipliées par 1,1.

- Chaque échantillon doit être une nouvelle fois soumis à un essai d'amorçage à fréquence industrielle et à un essai de tension d'amorçage au choc de foudre.

#### 8.4.3.3 Évaluation

L'essai doit être considéré comme satisfait si les deux exigences suivantes sont satisfaites:

- la tension d'amorçage à fréquence industrielle de la totalité des trois échantillons d'éclateurs en série n'est pas inférieure à la valeur d'amorçage revendiquée
- la tension d'amorçage au choc de foudre de la totalité des trois échantillons d'éclateurs en série n'est pas supérieure au niveau de protection revendiqué.

### 8.5 Essais de fonctionnement des parafoudres

#### 8.5.1 Généralités

L'objectif de cet essai consiste à vérifier la capacité du parafoudre à la récupération thermique après injection de l'énergie thermique assignée,  $Q_{th}$ , respectivement, sous une surtension temporaire appliquée et dans les conditions de tension de régime permanent suivantes. L'essai doit être réalisé sur trois échantillons.

NOTE Trois échantillons pour essai sont spécifiés bien que la stabilité thermique ne présente foncièrement pas de caractère statistique. Ceci compense les facteurs statistiques tels qu'un réglage de tension incorrect, la variabilité de la caractéristique de la perte active, la tolérance lors de l'injection d'énergie, etc.

Les échantillons doivent satisfaire aux exigences de 7.2.

Des caractéristiques assignées d'énergie thermique  $Q_{th}$ , issues du Tableau 5 doivent être attribuées à chaque modèle de parafoudre.

La partie de l'essai dédiée à la caractérisation et au conditionnement (8.5.2.2) peut être effectuée à une température ambiante de  $20\text{ °C} \pm 15\text{ K}$  sur les résistances MO en air calme ou sur un parafoudre.

La partie de cet essai dédiée à la récupération thermique (8.5.2.3) doit être effectuée sur des parafoudres complets (voir 6.7). Des méthodes appropriées doivent permettre de démontrer que l'exigence concernant la température initiale est satisfaite au début de la partie de l'essai dédiée à la récupération thermique.

L'incertitude relative entre les mesurages de la tension appliquée ne doit pas être de plus de  $\pm 1\%$ . Ceci peut être réalisé par tous moyens adaptés, par exemple, à l'aide de montages de mesure identiques ou par étalonnage de tous les montages de mesure utilisés à  $\pm 1\%$ . La valeur de crête de la tension ne doit pas varier de plus de  $1\%$  entre la valeur à vide et la valeur à pleine charge. Le rapport de la tension de crête à la valeur efficace ne doit pas s'écarter de  $\sqrt{2}$  de plus de  $2\%$ . Pendant les essais, la tension à fréquence industrielle ne doit pas s'écarter des valeurs spécifiées de plus de  $\pm 1\%$ .

## **8.5.2 Procédure d'essai**

### **8.5.2.1 Généralités**

La Figure 3 présente la procédure d'essai.

IECNORM.COM : Click to view the full PDF of IEC 60099-6:2019

|                                                                                                                                                                                                                                                                                                                                                                                                  |
|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <p>Essais préalables</p> <ul style="list-style-type: none"> <li>• Vérification de l'équivalence thermique du parafoudre complet</li> </ul>                                                                                                                                                                                                                                                       |
| <p>Essais initiaux pour la caractérisation des échantillons</p> <ul style="list-style-type: none"> <li>• Essai de tension résiduelle au courant nominal de décharge</li> </ul>                                                                                                                                                                                                                   |
| <p>Détermination de la tension de régime permanent et de la tension assignée de l'échantillon (voir 7.2)</p>                                                                                                                                                                                                                                                                                     |
| <p>Conditionnement</p> <p>Essai de conditionnement; 4 ensembles de 5 chocs superposés avec une tension à fréquence industrielle continue <math>U_r</math></p> <p>Un choc de courant de grande amplitude (selon le Tableau 4)</p>                                                                                                                                                                 |
| <p>Réservé pour utilisation ultérieure</p>                                                                                                                                                                                                                                                                                                                                                       |
| <p>Préchauffage à la température initiale selon 8.5.2.3</p>                                                                                                                                                                                                                                                                                                                                      |
| <p>Parafoudres de classe de distribution:</p> <ul style="list-style-type: none"> <li>• Transfert de charges thermiques assignées, <math>Q_{th}</math>, dans un délai d'une minute par deux chocs de courant de foudre 8/20 <math>\mu</math>s selon 8.5.3</li> </ul>                                                                                                                              |
| <p>Application de la tension assignée de l'échantillon pendant 10 s (dans un délai de 100 ms après injection de l'énergie ou de la charge)</p>                                                                                                                                                                                                                                                   |
| <p>Application de la tension de régime permanent de l'échantillon pendant au moins 30 min (jusqu'à la démonstration de la réussite ou de l'échec de l'essai)</p>                                                                                                                                                                                                                                 |
| <p>Évaluation de l'essai</p> <ul style="list-style-type: none"> <li>• Récupération thermique</li> <li>• Aucun dommage physique</li> <li>• Variation de la tension résiduelle au courant nominal de décharge à <math>\pm 5\%</math></li> <li>• L'interruption finale du courant de suite doit se produire au plus tard à la fin du demi-cycle qui suit le cycle d'application du choc.</li> </ul> |

IEC

**Figure 3 – Procédure d'essai de vérification des caractéristiques assignées de transfert de charges thermiques,  $Q_{th}$**

Les exigences concernant la température initiale sont indiquées en 8.5.2.3.

### 8.5.2.2 Caractérisation et conditionnement

La procédure suivante doit être appliquée pour la caractérisation et le conditionnement:

- Chaque échantillon doit être soumis à un essai de tension résiduelle au courant nominal de décharge avant et après l'essai.
- Chaque échantillon doit être soumis à 4 ensembles de 5 chocs superposés sur une tension à fréquence industrielle continue de  $U_r$ . L'intervalle entre les chocs doit être compris entre 50 s et 60 s, et l'intervalle entre les ensembles doit être compris entre 25 min et 30 min. La mise sous tension de l'échantillon pour essai n'est pas exigée entre les ensembles de chocs.

- Les échantillons doivent, à des fins de conditionnement, être soumis à un choc de courant de grande amplitude comme cela est spécifié dans le Tableau 4.
- Le choc doit être de la même polarité que celle des chocs de courant pour le transfert de charges, dans la partie de l'essai dédiée à la récupération thermique.
- Après application du choc de courant de grande amplitude, les échantillons doivent être stockés à la température ambiante.

L'échauffement des échantillons pendant une durée plus longue à des températures très élevées, l'application d'une tension alternative ou l'application de courants de choc de polarité opposée, peuvent produire une récupération à partir des effets de vieillissement électrique potentiels, et ne sont par conséquent pas admis.

**Tableau 4 – Exigences pour les chocs de courant de grande amplitude**

| Classification des parafoudres | Courant de crête 4/10<br>kA |
|--------------------------------|-----------------------------|
| 10 kA                          | 100                         |
| 5 kA                           | 65                          |
| 2,5 kA                         | 25                          |

Les tolérances admises sur le réglage de l'appareillage d'essai doivent être telles que les valeurs mesurées des chocs de courant se situent dans les limites suivantes:

- a) valeur de crête comprise entre 90 % et 110 % de la valeur spécifiée;
- b) durée conventionnelle du front comprise entre 3,5  $\mu$ s et 4,5  $\mu$ s;
- c) durée conventionnelle jusqu'à mi-valeur comprise entre 9  $\mu$ s et 11  $\mu$ s;
- d) la valeur de crête de toute onde de courant de la polarité opposée doit être inférieure à 20 % de la valeur de crête du courant;
- e) la présence de petites oscillations sur l'onde de choc est admise à condition que leur amplitude au voisinage de la crête du choc soit inférieure à 5 % de la valeur de crête. Dans ces conditions, à des fins de mesurage, une courbe moyenne doit être admise pour déterminer la valeur de crête.

### 8.5.2.3 Essai de récupération thermique

La procédure suivante doit être appliquée pour la partie de l'essai dédiée à la récupération thermique:

- Les échantillons pour essai complets doivent être préchauffés à une température initiale au moins égale à 60 °C.
- Le préchauffage ne doit pas durer plus de vingt heures.
- La température des résistances MO doit être mesurée immédiatement avant le transfert de charge.
- Chaque échantillon doit être soumis à un transfert de charge. Dans un délai de 100 ms suivant le transfert de charge, une tension égale à la tension assignée de l'échantillon (voir 7.2), doit être appliquée pendant 10 s et par la suite une tension égale à la tension de régime permanent de ce même échantillon (voir 7.2) doit être appliquée pendant 30 min au minimum afin de démontrer la stabilité thermique. La composante résistive de la dissipation de courant ou de puissance, la température ou toute combinaison de ces éléments doit être contrôlée jusqu'à la réduction conséquente de la valeur mesurée (réussite), mais pendant au moins 30 min, ou jusqu'à la présence évidente d'un emballement thermique (échec).

#### 8.5.2.4 Évaluation de l'essai

L'essai doit être considéré comme satisfait lorsque tous les critères suivants sont satisfaits:

- la récupération thermique a été démontrée;
- aucun dommage physique n'est apparent;
- toute variation de la tension résiduelle au courant nominal de décharge avant et après l'essai est de  $\pm 5 \%$ ;

L'interruption finale du courant de suite doit se produire au plus tard à la fin du demi-cycle qui suit le cycle d'application du choc.

#### 8.5.3 Valeurs assignées de charge thermique, $Q_{th}$

Les valeurs des caractéristiques assignées de charge thermique,  $Q_{th}$ , données en C, doivent être prises dans le Tableau 5.

**Tableau 5 – Valeurs assignées des caractéristiques assignées de transfert de charges thermiques,  $Q_{th}$**

| Courant nominal de décharge (kA) | Caractéristiques assignées $Q_{th}$ (C) | $Q_{th}$ par choc (C) | Amplitude de courant 8/20 $\mu$ s (kA) correspondante (de manière approximative) (informative) |
|----------------------------------|-----------------------------------------|-----------------------|------------------------------------------------------------------------------------------------|
| 2,5                              | 0,45                                    | 0,23 ( $\pm 10 \%$ )  | 14                                                                                             |
| 5                                | 0,7                                     | 0,35 ( $\pm 10 \%$ )  | 22                                                                                             |
| 10                               | 1,1                                     | 0,55 ( $\pm 10 \%$ )  | 34                                                                                             |

### 8.6 Essai de tension à fréquence industrielle en fonction du temps

#### 8.6.1 Généralités

L'objectif de cet essai consiste à démontrer la capacité de tenue (à la surtension temporaire) TOV du parafoudre. Dans cet essai, la TOV est strictement une surtension à fréquence industrielle pendant des périodes comprises entre 0,1 s et 3 600 s.

Les informations du constructeur doivent comporter des courbes dont l'abscisse désigne l'échelle de temps et l'ordonnée l'unité de  $U_r$ . De plus, le constructeur doit publier un tableau de valeurs TOV énumérées en unité de  $U_r$  avec trois chiffres significatifs, pour les durées de 0,1 s, 1 s, 10 s, 100 s et 1 000 s. Les valeurs données dans le tableau doivent être celles des courbes et doivent inclure les éléments "sans service préalable" et "avec service préalable". La courbe et le tableau publiés doivent indiquer la plage des caractéristiques assignées des parafoudres pour laquelle ils s'appliquent.

La valeur TOV "avec service préalable" et la durée de 10 s doivent être au moins égales à  $U_r$ .

La Figure 4 présente la procédure d'essai.



|                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                              |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Essais initiaux                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                              |
| <ul style="list-style-type: none"> <li>Essai de tension résiduelle au courant nominal de décharge</li> </ul>                                                                                                                                                                                                                                                                                                                                                                                                                                                                 |
| Détermination de la tension de régime permanent et de la tension assignée.                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                   |
| Préchauffage à la température initiale selon 8.5.2.3                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                         |
| <p>Avec service préalable (4 nouveaux échantillons) (uniquement pour les parafoudres DH )</p> <ul style="list-style-type: none"> <li>Transfert de charges thermiques assignées, <math>Q_{th}</math>, dans un délai d'une minute par deux chocs de courant de foudre 8/20 <math>\mu s</math> selon 8.5.3</li> <li>Application de la tension et de la durée d'essai selon la courbe TOV (dans un délai de 100 ms)</li> <li>Application de la tension de régime permanent pendant au moins 30 min (jusqu'à la démonstration de la réussite ou de l'échec de l'essai)</li> </ul> |
| <p>Sans service préalable (2 nouveaux échantillons)</p> <ul style="list-style-type: none"> <li>Application de la tension et de la durée d'essai selon la courbe TOV</li> <li>Application de la tension de régime permanent pendant au moins 30 min (jusqu'à la démonstration de la réussite ou de l'échec de l'essai)</li> </ul>                                                                                                                                                                                                                                             |
| <p>Évaluation de l'essai</p> <ul style="list-style-type: none"> <li>Récupération thermique</li> <li>Aucun dommage physique</li> <li>Variation de la tension résiduelle au courant nominal de décharge à <math>\pm 5 \%</math></li> <li>La valeur d'essai de tension d'amorçage à fréquence industrielle ne doit pas être inférieure à la valeur d'amorçage revendiquée</li> </ul>                                                                                                                                                                                            |

IEC

**Figure 4 – Procédure d'essai de vérification de la caractéristique de la fréquence industrielle en fonction du temps (essai TOV)**

### 8.6.2 Échantillons pour essai

Les échantillons pour essai doivent satisfaire aux exigences de 7.2.

Les échantillons pour essai doivent être des parafoudres complets avec des tensions assignées de 3 kV à 12 kV qui peuvent être utilisés à condition que la vitesse de refroidissement du parafoudre représente la vitesse de refroidissement la plus faible pour toutes les caractéristiques assignées du modèle.

Six échantillons au total doivent être soumis à l'essai comme suit:

- “avec service préalable” – un échantillon dans chacune des quatre gammes énumérées en 8.6.4.2
- “sans service préalable” – un échantillon dans chacune des deux gammes sélectionnées dans la liste en 8.6.4.2.

Pour un type et un modèle de parafoudre donnés, lorsque des résistances MO de diverses dimensions sont utilisées, les résistances MO sélectionnées pour la fraction d'essai TOV doivent avoir le volume minimal par valeur  $U_c$ .

### 8.6.3 Mesurages initiaux

Un essai de mesure initiale de la tension résiduelle doit être effectué au courant nominal de décharge.

## 8.6.4 Procédure d'essai

### 8.6.4.1 Généralités

L'échantillon pour essai doit être connecté à une source d'alimentation dont la fréquence est comprise dans la plage de 48 Hz à 62 Hz. La fréquence nominale d'essai (50 Hz ou 60 Hz) doit être indiquée dans les informations publiées. Les valeurs de crête de la tension à fréquence industrielle doivent être mesurées aux bornes du parafoudre au cours de l'application de la surtension. La valeur de crête minimale mesurée divisée par  $\sqrt{2}$  est la valeur par unité qui doit être utilisée pour l'affichage des données avec la tension assignée de référence.

Une attention toute particulière doit être accordée dans le cas d'une source de tension faible. La déformation de la tension (crête plate) sous une charge de courant instable très importante peut engendrer une injection d'énergie bien plus élevée à un niveau de tension de crête donné par comparaison avec la situation propre à une forme de tension théoriquement sinusoïdale. Il est par conséquent recommandé d'utiliser une source de tension d'un courant de court-circuit d'au moins 3 kA afin d'éviter toute injection d'énergie exagérément élevée dans l'échantillon à un niveau de tension de crête donné.

Les essais doivent être réalisés en air calme à  $20\text{ °C} \pm 15\text{ K}$  sur des fractions thermiquement distribuées au prorata. Les échantillons doivent être chauffés pendant une durée suffisante pour atteindre l'équilibre thermique, et la température des résistances MO doit être au moins de  $60\text{ °C}$ . Des méthodes appropriées doivent permettre de démontrer que l'exigence concernant la température initiale est satisfaite au début de la partie de l'essai dédiée à la récupération thermique.

### 8.6.4.2 Essai "avec service préalable"

Cet essai est applicable aux parafoudres de  $I_n = 10\text{ kA}$  uniquement. Quatre nouveaux échantillons pour essai doivent être soumis à l'essai "avec service préalable". Chaque échantillon doit être soumis à l'essai selon les paliers (en s) donnés ci-dessous:

- 1) 0,1 à 1
- 2) 1,1 à 10
- 3) 10,1 à 100
- 4) 101 à 3 600

Le constructeur doit publier les informations TOV pour les conditions "avec service préalable" pour chacune des quatre périodes énumérées. Le service préalable consiste en une injection des caractéristiques assignées de charge thermique  $Q_{th}$ . La procédure d'essai doit être la procédure donnée en 8.5.2.3, dans laquelle la tension TOV spécifiée se substitue à la tension assignée. La charge (en C) doit être mesurée et doit être indiquée avec les informations TOV publiées pertinentes concernant le service préalable.

### 8.6.4.3 Essai "sans service préalable"

Cet essai est applicable aux parafoudres de tous courants nominaux de décharge. Deux nouveaux échantillons pour essai doivent être soumis à l'essai "sans service préalable". Le constructeur doit publier les informations TOV pour les conditions "sans service préalable" pour deux des quatre périodes énumérées en 8.6.4.2. Un nouvel échantillon dans chacun des deux intervalles de temps non adjacents choisis dans cette liste doit être soumis à l'essai. Immédiatement après application de la surtension sur l'échantillon, la tension de régime permanent (voir 7.2) doit être appliquée pendant une durée minimale de 30 min. La température des résistances MO, la composante résistive de la dissipation de courant ou de la puissance absorbée doivent être surveillées jusqu'à la réduction conséquente de la valeur mesurée (réussite) ou jusqu'à la présence évidente d'un emballement thermique (échec).

### 8.6.5 Évaluation de l'essai

Un échantillon doit être considéré comme ayant satisfait à l'essai lorsque tous les critères suivants sont satisfaits:

- la récupération thermique a été démontrée;
- aucun dommage physique n'est apparent;
- toute variation de la tension résiduelle au courant nominal de décharge avant et après l'essai est de  $\pm 5\%$ ;
- La valeur d'essai de tension d'amorçage à fréquence industrielle ne doit pas être inférieure à la valeur d'amorçage revendiquée

La courbe publiée par le constructeur a été vérifiée lorsque l'ensemble des six échantillons a été soumis à l'essai à des tensions TOV et avec des durées correspondantes supérieures ou égales aux valeurs indiquées sur la courbe, et lorsque tous les échantillons ont satisfait aux critères d'évaluation. Tous les points d'essai doivent figurer sur la courbe.

## 8.7 Essais des dispositifs de déconnexion des parafoudres

### 8.7.1 Généralités

L'objectif de l'essai portant sur le dispositif de déconnexion consiste à vérifier que le dispositif de déconnexion d'un parafoudre peut supporter toutes les contraintes associées à leur application dans les parafoudres hors fonctionnement. L'essai démontre également que le dispositif de déconnexion fonctionne selon la caractéristique temps/courant publiée par le constructeur. Par ailleurs, l'étanchéité et la résistance mécanique du dispositif de déconnexion doivent être vérifiées (voir 6.12).

Ces essais doivent être effectués sur des parafoudres équipés de dispositifs de déconnexion ou sur l'ensemble dispositif de déconnexion seul, si celui-ci est conçu de manière à ne pas être affecté par l'échauffement des pièces adjacentes du parafoudre en position d'installation normale. L'échantillon pour essai doit être monté conformément aux recommandations publiées par le constructeur en utilisant la taille et la rigidité maximales recommandées et la longueur de fil de connexion la plus courte recommandée. En l'absence de recommandations publiées, le conducteur doit être de cuivre nu tressé serré d'approximativement 5 mm de diamètre et de 30 cm de longueur, disposé pour permettre une liberté de mouvement du dispositif de déconnexion/indicateur de défaut lorsqu'il fonctionne.

### 8.7.2 Essai de tenue en fonctionnement

#### 8.7.2.1 Généralités

Pour les dispositifs de déconnexion conçus pour être fixés sur un parafoudre ou être intercalés sur le trajet du conducteur de ligne ou sur celui du conducteur de terre sous forme d'accessoire, un essai de transfert de charges et un essai de fonctionnement des parafoudres doivent être effectués séparément ou en liaison avec les essais des échantillons de parafoudre. Pour les parafoudres équipés de dispositifs de déconnexion intégrés, les essais doivent être effectués conjointement aux essais réalisés sur les parafoudres. Les dispositifs de déconnexion doivent résister aux essais sans fonctionnement des parafoudres.

#### 8.7.2.2 Essai de vérification des caractéristiques assignées de transfert de charges répétitives, $Q_{rs}$

Cet essai doit être effectué selon 8.4, avec des valeurs de transfert de charges correspondant à la classification la plus élevée des parafoudres avec lesquels le dispositif de déconnexion doit être utilisé. L'essai doit être effectué avec des courants de choc de foudre 8/20  $\mu s$ . Il doit être effectué sur trois échantillons avec la même charge que celle spécifiée pour le parafoudre (voir 8.4.4).

### 8.7.2.3 Essai de fonctionnement des parafoudres

Cet essai doit être effectué selon 8.5 avec le dispositif de déconnexion des échantillons en série avec un échantillon pour essai du modèle de parafoudre. L'essai doit être effectué sur trois échantillons avec les mêmes caractéristiques assignées de charge thermique que celles spécifiées pour le parafoudre.

### 8.7.2.4 Évaluation de l'essai

Les essais doivent être considérés comme satisfaits si:

- aucun échantillon ne fonctionne au cours des essais de 8.7.2.2 et 8.7.2.3
- et
- soit
    - la résistance ou la capacité des éléments de répartition n'a pas varié de plus de 20 %
    - ou
    - si chacun des échantillons utilisés pour les essais de 8.7.2.2 et 8.7.2.3 fonctionne de façon satisfaisante dans un essai de fonctionnement ultérieur lorsqu'il conduit un courant symétrique efficace de 20 A.

## 8.7.3 Fonctionnement du dispositif de déconnexion

### 8.7.3.1 Essai de détermination du “temps en fonction du courant”

Un essai de fonctionnement doit être effectué sur les dispositifs de déconnexion des parafoudres afin de déterminer la caractéristique temps-courant, c'est-à-dire la relation entre le temps en s et le courant en ampères symétriques efficaces exigée pour faire fonctionner le dispositif de déconnexion. Il est admis que le fonctionnement réel du dispositif de déconnexion se produise après l'interruption du courant.

Les données nécessaires pour tracer une courbe du temps en fonction du courant doivent être obtenues pour trois niveaux différents de courant en régime initialement symétrique auxquels cinq échantillons sont associés – 20 A, 200 A et 800 A (eff.)  $\pm 10\%$  – ledit courant traversant l'échantillon pour essai des dispositifs de déconnexion, avec ou sans parafoudre, comme cela est exigé par 8.7.1. Lorsque des courants d'intensité inférieure sont revendiqués, ils doivent être soumis à l'essai (par exemple, 5 A). Pour les essais effectués sur des dispositifs de déconnexion qui sont affectés par l'échauffement interne des parafoudres associés, les résistances MO du parafoudre doivent être court-circuitées par un fil de cuivre nu de 0,08 mm à 0,13 mm de diamètre afin de provoquer l'amorçage d'arc interne.

La tension d'essai peut avoir toute valeur convenable permettant d'assurer le passage du plein courant dans l'arc contournant les éléments du parafoudre et permettant d'amorcer et de maintenir un amorçage d'arc dans tous les éclateurs dont peut dépendre le fonctionnement du dispositif de déconnexion. La tension d'essai ne doit pas dépasser la tension assignée du parafoudre de la plus faible tension assignée avec lequel le dispositif de déconnexion doit être utilisé.

Étant donné que le dispositif de déconnexion n'est pas un dispositif d'élimination des défauts, les circuits d'essai doivent comporter des dispositifs de coupure. Un dispositif d'ouverture, tel qu'un fusible ou un interrupteur, peut être utilisé avec un dispositif de réglage de la durée d'écoulement du courant dans l'échantillon pour essai.

NOTE Une méthode de préparation du circuit d'essai consiste à régler tout d'abord les paramètres du circuit d'essai, l'échantillon pour essai étant mis provisoirement en court-circuit par une connexion d'impédance négligeable afin d'obtenir la valeur de courant exigée. L'interrupteur de fermeture peut être temporisé afin de fermer le circuit dans un délai correspondant à quelques degrés de la crête de tension afin de produire un courant sensiblement symétrique.

Pour tous les échantillons soumis à l'essai, la valeur efficace du courant traversant l'éprouvette et la durée du courant jusqu'au premier déplacement du dispositif de déconnexion doivent être tracées sur la courbe. La courbe de la caractéristique "temps en fonction du courant" du dispositif de déconnexion doit être tracée sous la forme d'une courbe lissée reliant les points correspondant aux durées maximales.

Selon le montage d'essai et l'amplitude du courant d'essai, l'arc ne s'éteint pas après le fonctionnement du dispositif de déconnexion. Dans ce cas, l'essai relatif à la courbe de la caractéristique "temps en fonction du courant" doit être effectué en soumettant les échantillons pour essai à des durées régulées d'écoulement du courant afin de déterminer la durée minimale, pour chacun des trois niveaux de courant, qui provoque systématiquement un fonctionnement satisfaisant du dispositif de déconnexion. Les valeurs à retenir pour la courbe de la caractéristique "temps en fonction du courant" doivent correspondre à cinq fonctionnements satisfaisants du dispositif de déconnexion au cours de cinq essais. Ou, si un essai non satisfaisant se produit, cinq essais complémentaires effectués au même niveau de courant et avec la même durée doivent aboutir à des fonctionnements satisfaisants.

#### **8.7.3.2 Évaluation des caractéristiques de fonctionnement du dispositif de déconnexion**

Le dispositif doit assurer clairement une séparation effective et permanente. S'il n'est pas nettement évident que le dispositif a accompli une séparation effective et permanente, une tension à fréquence industrielle égale à 1,2 fois la tension assignée du parafoudre à tension assignée la plus élevée avec lequel le dispositif de déconnexion doit être utilisé, doit être appliquée pendant 1 min sans que la valeur efficace de l'écoulement du courant ne dépasse 1 mA. À chaque valeur du courant, la courbe caractéristique établie doit avoir une valeur temporelle inférieure ou égale à celle indiquée dans les informations publiées par le constructeur.

### **8.7.4 Essais mécaniques**

#### **8.7.4.1 Généralités**

Des essais de moment de flexion, d'effort de traction et d'effort de torsion doivent être réalisés sur les dispositifs de déconnexion utilisés avec un parafoudre NGLA. Pour les parafoudres autres que les parafoudres NGLA, ces essais peuvent être réalisés sur accord entre l'utilisateur et le constructeur.

NOTE Généralement, les dispositifs de déconnexion utilisés sur les parafoudres de classe de distribution sont soumis à des charges très faibles en raison du poids des fils de connexion, et ne sont par conséquent pas soumis à ces essais. Toutefois, les dispositifs de déconnexion peuvent être exposés à un couple ou à d'autres charges lors de l'installation, même si la contrainte mécanique en service est négligeable.

#### **8.7.4.2 Essai de moment de flexion**

L'essai doit être effectué sur cinq nouveaux échantillons. L'effort de flexion doit être augmenté progressivement sur chaque échantillon, jusqu'à ce que la rupture se produise dans un temps compris entre 30 s et 90 s. L'essai est satisfaisant lorsque les valeurs de l'effort à la rupture dépassent la valeur spécifiée par le constructeur. Lorsqu'un échantillon n'atteint pas la valeur de rupture spécifiée, cinq échantillons supplémentaires doivent être soumis à l'essai avec succès.

#### **8.7.4.3 Essai d'effort de traction**

L'essai doit être effectué sur cinq nouveaux échantillons. L'effort de flexion doit être augmenté progressivement sur chaque échantillon, jusqu'à ce que la rupture se produise dans un temps compris entre 30 s et 90 s. L'essai est satisfaisant lorsque les valeurs de l'effort à la rupture dépassent la valeur spécifiée par le constructeur. Lorsqu'un échantillon n'atteint pas la valeur de rupture spécifiée, cinq échantillons supplémentaires doivent être soumis à l'essai avec succès.

#### 8.7.4.4 Essai d'effort de torsion

L'essai doit être effectué sur cinq nouveaux échantillons. L'effort de flexion doit être augmenté progressivement sur chaque échantillon, jusqu'à ce que la rupture se produise dans un temps compris entre 30 s et 90 s. L'essai est satisfaisant lorsque les valeurs de l'effort à la rupture dépassent la valeur spécifiée par le constructeur. Lorsqu'un échantillon n'atteint pas la valeur de rupture spécifiée, cinq échantillons supplémentaires doivent être soumis à l'essai avec succès.

#### 8.7.5 Essai de cycles de températures et de pompage d'étanchéité

Un essai de cycles de températures doit être effectué sur dix nouveaux échantillons selon 8.11.3.2 suivi d'un essai de pompage d'étanchéité sur chaque échantillon.

Pour l'essai de pompage d'étanchéité, les échantillons pour essai doivent être chauffés de manière uniforme à une température de  $60\text{ °C} \pm 3\text{ °C}$  et maintenus à cette température pendant une durée minimale de 1 h. Les échantillons doivent ensuite être placés dans un bain d'eau froide à une température de  $4\text{ °C} \pm 3\text{ °C}$  pendant une durée minimale de 2 h. Le temps de transfert entre le milieu chaud et froid ne doit pas dépasser 5 min. Le cycle d'essai doit être effectué à 10 reprises. Le poids de l'eau du bain d'eau froide doit correspondre au minimum à 10 fois le poids des échantillons pour essai.

Dans un délai de 24 h après que la température ambiante a été atteinte, la résistance ou la capacité de l'élément de répartition de chaque échantillon doit être mesurée et les échantillons doivent être ouverts en vue d'une inspection visuelle. Les dispositifs de déconnexion doivent avoir satisfait aux essais si l'examen visuel des éléments internes et des surfaces des échantillons pour essai ne détecte aucune trace d'humidité et si la résistance ou la capacité de l'élément de répartition n'a pas varié de plus de 20 %.

#### 8.8 Essais d'amorçage à la tension à fréquence industrielle

Des essais à sec et sous pluie doivent être effectués sur trois échantillons de parafoudres complets de chaque tension assignée vérifiée par essai. Les caractéristiques de fonctionnement applicables aux autres tensions assignées de même type à  $\pm 20\%$  (ou 3 kV, selon la plus grande des deux valeurs) d'un échantillon pour essai assigné peuvent être déterminées par réglage du niveau de tension proportionnellement aux tensions assignées. La tension appliquée au parafoudre doit être activée à une valeur suffisamment faible pour éviter l'amorçage du parafoudre par le choc de manœuvre résultant, et être augmentée rapidement à une vitesse uniforme jusqu'à l'amorçage de l'éclateur en série. La durée au cours de laquelle la tension peut dépasser la tension assignée du parafoudre doit être comprise entre 2 s et 5 s lors de l'essai des parafoudres avec des résistances de répartition qui peuvent être endommagées par surchauffe si la tension appliquée dépasse la tension assignée pendant une durée trop longue. Après amorçage, la tension d'essai doit être désactivée le plus rapidement possible, de préférence par déclenchement automatique et dans un délai de 0,5 s dans tous les cas.

L'effort exercé sur le circuit d'essai par un parafoudre comportant des résistances de répartition instables de conductivité élevée engendre des harmoniques. Le circuit d'essai doit ainsi avoir une impédance suffisamment faible pour maintenir la forme d'onde de la tension sur l'éprouvette dans les limites spécifiées dans l'IEC 60060-1 et l'IEC 60060-2.

La tension doit être appliquée au moins cinq fois avec un intervalle de 10 s environ entre des applications successives.

La valeur moyenne d'amorçage des cinq essais est choisie comme la tension d'amorçage à fréquence industrielle à des fins de comparaison des essais effectués avant et après les autres essais de type.

## 8.9 Essais de court-circuit

### 8.9.1 Généralités

Tous les parafoudres doivent être soumis à l'essai pour indiquer qu'une défaillance du parafoudre ne donne pas lieu à une rupture explosive de l'enveloppe du parafoudre et que les flammes nues s'autoéteignent (le cas échéant) dans un délai défini. Chaque type de parafoudre est soumis à l'essai avec quatre valeurs de courants de court-circuit au maximum. Si le parafoudre est équipé d'un autre dispositif comme substitut d'un limiteur de pression conventionnel, ce dispositif doit être inclus dans l'essai.

La fréquence de l'alimentation du courant d'essai de court-circuit doit être comprise entre 48 Hz et 62 Hz.

En ce qui concerne les performances au courant de court-circuit, il est important de distinguer deux conceptions de parafoudres:

- Les parafoudres de "conception A" sont tels qu'un canal utilisé par le gaz suit toute la longueur de l'élément de parafoudre et remplit  $\geq 50$  % du volume interne qui n'est pas occupé par les parties actives internes.
- Les parafoudres de "conception B" sont solides et sans volume interne de gaz ou ont un volume de gaz interne remplissant  $< 50$  % du volume interne qui n'est pas occupé par les parties actives internes.

NOTE 1 Généralement, les parafoudres de "conception A" sont des parafoudres à enveloppe en porcelaine, ou des parafoudres à enveloppe synthétique à isolateurs composites creux équipés de limiteurs de pression, ou à points faibles préinstallés dans l'enveloppe composite capables de s'ouvrir en explosant ou en basculant à une pression spécifiée, ce qui permet de réduire la pression interne.

Généralement, les parafoudres de "conception B" ne possèdent pas de limiteur de pression et sont solides sans volume interne de gaz. Si les résistances MO connaissent une défaillance électrique, il se produit un arc à l'intérieur du parafoudre. Cet arc provoque une évaporation importante et éventuellement la combustion de l'enveloppe et/ou du matériau interne. Ces performances de tenue aux courts-circuits des parafoudres sont déterminées par leur capacité à contrôler l'éclatement ou l'ouverture de l'enveloppe dus aux effets de l'arc, évitant ainsi une rupture explosive.

NOTE 2 Dans ce contexte, les "parties actives" sont les résistances MO et les éventuelles entretoises métalliques qui y sont directement connectées en série.

NOTE 3 Après accord entre le constructeur et l'utilisateur, la procédure d'essai peut être modifiée pour inclure, par exemple, un certain nombre d'opérations de réenclenchement, avec la procédure et les critères d'acceptation faisant l'objet d'un accord entre le constructeur et l'utilisateur.

### 8.9.2 Préparation des échantillons pour essai

#### 8.9.2.1 Généralités

En fonction du type de parafoudre et de la tension d'essai, des exigences différentes s'appliquent concernant le nombre d'échantillons pour essai, le début du passage du courant de court-circuit et l'amplitude de la première valeur de crête du courant de court-circuit. Le Tableau 6 donne un résumé de ces exigences.

Pour les essais à courant de forte amplitude, les échantillons pour essai doivent être constitués par l'élément de parafoudre le plus long utilisé pour la conception avec sa tension assignée la plus élevée utilisée pour chaque modèle de parafoudre différent.

Pour l'essai à courant de faible amplitude, l'échantillon pour essai doit être constitué par un élément de parafoudre avec sa tension assignée la plus élevée utilisée pour chaque modèle de parafoudre différent. La Figure 5 présente différents exemples d'éléments de parafoudre.



### 8.9.2.2 Parafoudres de “conception A”

Les échantillons doivent être préparés avec des moyens pour conduire le courant de court-circuit exigé en utilisant un fil fusible. Le fil fusible doit être en contact direct avec les résistances MO, être situé aussi loin que possible du canal utilisé par le gaz et court-circuiter la partie active interne complète, comme le représente la Figure 6 pour différents modèles possibles de parafoudres de conception B. L'emplacement réel du fil fusible au cours de l'essai doit être consigné dans le rapport d'essai.

Fil fusible le long de la surface des résistances MO, situé aussi loin que possible du canal utilisé par le gaz. Le matériau et la taille du fil fusible doivent être choisis de sorte que, pour les essais à courant de court-circuit de forte amplitude et d'amplitude réduite, la fusion du fil se produit au cours des 30 premiers degrés électriques après le début du passage du courant d'essai. Pour l'essai à courant de faible amplitude, le temps de fusion n'est soumis à aucune limite.

Pour que le fil fusible fonde dans les limites de temps spécifiées et qu'il crée une condition appropriée à l'amorçage de l'arc, il est généralement recommandé d'utiliser un fil fusible avec un matériau à faible résistance (par exemple, cuivre, aluminium ou argent) d'un diamètre d'environ 0,2 mm à 0,5 mm. Des sections de fil fusible plus importantes sont applicables aux éléments de parafoudres préparés pour des courants d'essai de court-circuit plus élevés. Lorsque l'amorçage de l'arc est difficile à réaliser, un fil fusible de dimensions plus importantes, mais d'un diamètre inférieur ou égal à 1,5 mm, peut être utilisé dans la mesure où il facilite l'établissement de l'arc. Dans de tels cas, un fil fusible spécialement préparé, ayant une section plus importante sur la plus grande partie de la hauteur du parafoudre avec une courte section plus mince au milieu, peut également faciliter l'opération.

Les parafoudres de “conception A” avec des ailettes polymères appliquées à une enveloppe principale en porcelaine ou à d'autres isolateurs creux et qui sont aussi fragiles que la céramique, doivent être considérés et soumis aux essais comme des parafoudres à enveloppe en porcelaine.

Les échantillons pour essai doivent être remplis du milieu environnant (gaz) utilisé dans les parafoudres.

### 8.9.2.3 Parafoudres de “conception B”

Les échantillons doivent être préparés avec des moyens pour conduire le courant de court-circuit exigé en utilisant un fil fusible. Le fil fusible doit être en contact direct avec les résistances MO, être situé aussi loin que possible du canal utilisé par le gaz et court-circuiter la partie active interne complète, comme le représente la Figure 7 pour différents modèles possibles de parafoudres de conception B. L'emplacement réel du fil fusible au cours de l'essai doit être consigné dans le rapport d'essai.

Le matériau et la taille du fil fusible doivent être choisis de sorte que, pour les essais à courant de court-circuit de forte amplitude et d'amplitude réduite, la fusion du fil se produit au cours des 30 premiers degrés électriques après le début du passage du courant d'essai. Pour l'essai à courant de faible amplitude, le temps de fusion n'est soumis à aucune limite.


Pour que le fil fusible fonde dans les limites de temps spécifiées et qu'il crée une condition appropriée à l'amorçage de l'arc, il est généralement recommandé d'utiliser un fil fusible avec un matériau à faible résistance (par exemple, cuivre, aluminium ou argent) d'un diamètre d'environ 0,2 mm à 0,5 mm. Des sections de fil fusible plus importantes sont applicables aux éléments de parafoudres préparés pour des courants d'essai de court-circuit plus élevés. Lorsque l'amorçage de l'arc est difficile à réaliser, un fil fusible de dimensions plus importantes, mais d'un diamètre inférieur ou égal à 1,5 mm, peut être utilisé dans la mesure où il facilite l'établissement de l'arc. Dans de tels cas, un fil fusible spécialement préparé, ayant une section plus importante sur la plus grande partie de la hauteur du parafoudre avec une courte section plus mince au milieu, peut également faciliter l'opération.

Dans le cas d'un volume interne de gaz, les échantillons pour essai doivent être remplis du milieu environnant (gaz) utilisé dans les parafoudres.




Tableau 6 – Exigences d'essai concernant les parafoudres à enveloppe en porcelaine

|                | Nombre exigé d'échantillons pour essai | Début du passage du courant de court-circuit                                                                             | Rapport de la première valeur de crête de courant sur la valeur efficace du courant de court-circuit exigé selon le |                                                   |                                              |                                  |                                 |                                              |
|----------------|----------------------------------------|--------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------------------|---------------------------------------------------|----------------------------------------------|----------------------------------|---------------------------------|----------------------------------------------|
|                |                                        |                                                                                                                          | Tension d'essai: 77 % à 107 % de $U_r$                                                                              |                                                   |                                              | Tension d'essai: < 77 % de $U_r$ |                                 |                                              |
|                |                                        |                                                                                                                          | Courant assigné de court-circuit                                                                                    | Courant de court-circuit réduit                   | Courant de court-circuit de faible amplitude | Courant assigné de court-circuit | Courant de court-circuit réduit | Courant de court-circuit de faible amplitude |
| "Conception A" | 4                                      | Fil fusible le long de la surface des résistances MO, à l'intérieur ou le plus près possible du canal utilisé par le gaz | Présumé: $\geq 2,5$<br>Réal: aucune exigence                                                                        | Présumé: $\geq \sqrt{2}$<br>Réal: aucune exigence | Réal: $\geq \sqrt{2}$                        | Réal: $\geq 2,5$                 | Réal: $\geq \sqrt{2}$           | Réal: $\geq \sqrt{2}$                        |
| "Conception B" | 4                                      | Fil fusible le long de la surface des résistances MO, situé le plus loin possible du canal utilisé par le gaz            | Présumé: $\geq \sqrt{2}$<br>Réal: aucune exigence                                                                   | Présumé: $\geq \sqrt{2}$<br>Réal: aucune exigence | Réal: $\geq \sqrt{2}$                        | Réal: $\geq \sqrt{2}$            | Réal: $\geq \sqrt{2}$           | Réal: $\geq \sqrt{2}$                        |




IEC

**Figure 5 – Exemples d'éléments de parafoudres**



IEC

**Figure 6 – Exemples d'emplacements du fil fusible pour les parafoudres de “conception A”**




IEC

**Figure 7 – Exemples d'emplacements du fil fusible pour les parafoudres de “conception B”**

### 8.9.3 Montage de l'échantillon pour essai

Pour un parafoudre monté sur embase, le dispositif de montage est représenté à la Figure 8. La distance entre le sol et la plate-forme isolante et les conducteurs doit être comme indiqué dans cette Figure.

Dimensions en mètres



NOTE Toutes les connexions et tous les événements de soufflage sont sur le même plan.

**Figure 8 – Montage d'essai de court-circuit pour les parafoudres à enveloppe en porcelaine**

Pour les parafoudres qui ne sont pas montés sur embase (par exemple, parafoudres montés sur poteau), l'échantillon pour essai doit être monté sur un poteau non métallique en utilisant des consoles de montage et des dispositifs normalement utilisés pour leur installation en service réel. Pour les besoins de l'essai, la console de montage doit être considérée comme faisant partie de l'embase du parafoudre. Dans les cas où cette configuration diffère des instructions du constructeur, le parafoudre doit être monté conformément aux recommandations d'installation du constructeur. La totalité du conducteur entre l'embase et le capteur de courant doit être isolée à au moins 1 000 V. L'extrémité supérieure de l'échantillon pour essai doit être équipée avec l'embase du parafoudre du même modèle ou d'un capot haut.

Le montage du parafoudre au cours de l'essai de court-circuit et, plus spécifiquement, la disposition des conducteurs doivent représenter la condition la plus défavorable en service.

NOTE La disposition représentée à la Figure 8 est la plus défavorable à utiliser durant la phase initiale de l'essai avant la relaxation de la surpression (en particulier dans le cas d'un parafoudre équipé d'un limiteur de pression). Le positionnement de l'échantillon comme représenté à la Figure 8, avec ses événements côté source d'essai, peut conduire l'arc externe à être envoyé plus près de l'enveloppe du parafoudre que dans d'autres cas. En conséquence, un effet de choc thermique peut causer des fissures et des bris excessifs des ailettes en porcelaine, en comparaison avec les autres orientations possibles des événements.

## 8.9.4 Essais de court-circuit à courant de forte amplitude

### 8.9.4.1 Généralités

Un nombre total de trois échantillons doit être soumis à des essais de courants sur la base d'un courant assigné de court-circuit choisi dans le Tableau 7. Les trois échantillons doivent être préparés selon 8.9.2 et montés selon 8.9.3.

Les essais doivent être effectués à l'aide d'un circuit d'essai monophasé, de préférence avec une tension d'essai à vide comprise entre 77 % et 107 % de la tension assignée de

l'échantillon pour essai, comme stipulé en 8.9.4.2. Cependant, il est probable que des essais sur des parafoudres à haute tension doivent être effectués dans des laboratoires ne disposant pas nécessairement de la puissance de court-circuit suffisante pour effectuer ces essais à 77 % ou plus de la tension assignée des échantillons pour essai. En conséquence, une procédure de rechange pour effectuer les essais de court-circuit à courant de forte amplitude avec une tension réduite est donnée en 8.9.4.3. La durée totale mesurée du courant d'essai circulant dans le circuit doit être  $\geq 0,2$  s.

**Tableau 7 – Courants exigés pour les essais de court-circuit**

| Classe de parafoudre =<br>courant nominal de<br>décharge                                                                                                                                                                                                                                                                                                                                                                                                                                                                    | Courant assigné de<br>court-circuit $I_s$ | Courants de court-<br>circuit réduits $\pm 10$ % |     | Courant de court-circuit de<br>faible amplitude d'une<br>durée de 1 s <sup>a</sup> |
|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------|--------------------------------------------------|-----|------------------------------------------------------------------------------------|
| kA                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                          | kA                                        | kA                                               |     | A                                                                                  |
| 10 ou 5                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                     | 20                                        | 12                                               | 6   | 600 ou 200 $\pm$                                                                   |
| 10 ou 5                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                     | 16                                        | 6                                                | 3   | 600 ou 200 $\pm$                                                                   |
| 10, 5 ou 2,5                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                | 10                                        | 6                                                | 3   | 600 ou 200 $\pm$                                                                   |
| 10, 5 ou 2,5                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                | 5                                         | 3                                                | 1,5 | 600 ou 200 $\pm$                                                                   |
| 10, 5 ou 2,5                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                | 2,5 kA                                    | –                                                | –   | 600 ou 200 $\pm$                                                                   |
| 10, 5 ou 2,5                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                | 1 kA                                      | –                                                | –   | Amplitude et durée sur<br>accord entre l'utilisateur et le<br>constructeur         |
| 10, 5 ou 2,5                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                | < 1 kA <sup>b</sup>                       | –                                                | –   | Amplitude et durée sur<br>accord entre l'utilisateur et le<br>constructeur         |
| <sup>a</sup> Pour les parafoudres destinés à être installés dans des réseaux à neutre mis à la terre ou non par bobine de compensation, l'augmentation de la durée de l'essai au-delà de 1 s, jusqu'à 30 min, peut être autorisée après accord entre le constructeur et l'utilisateur. Dans ce cas, le courant de court-circuit de faible amplitude doit être réduit à 50 A $\pm$ 20 A, et l'échantillon pour essai et les critères d'acceptation doivent faire l'objet d'un accord entre le constructeur et l'utilisateur. |                                           |                                                  |     |                                                                                    |
| <sup>b</sup> Des essais à courant de forte amplitude ne sont pas exigés dans ce cas.                                                                                                                                                                                                                                                                                                                                                                                                                                        |                                           |                                                  |     |                                                                                    |
| NOTE Si un parafoudre existant est qualifié pour l'un des courants assignés de court-circuit de ce tableau, il est estimé comme satisfaisant à l'essai pour toute valeur de courant assigné inférieure à cette première valeur.                                                                                                                                                                                                                                                                                             |                                           |                                                  |     |                                                                                    |

Si un type existant de parafoudre, déjà qualifié pour l'un des courants assignés du présent tableau est en cours de qualification pour une valeur de courant assigné supérieure indiquée dans le tableau, il convient qu'il ne soit soumis aux essais qu'à cette nouvelle valeur assignée. Toute extrapolation ne peut être étendue qu'à deux niveaux du courant assigné de court-circuit.

Si un nouveau type de parafoudre doit être qualifié pour une valeur de courant assignée supérieure aux valeurs données dans ce tableau, il doit être soumis à l'essai à la valeur proposée pour ce courant assigné, à 50 % et à 25 % du courant assigné.

#### 8.9.4.2 Essais à courant de forte amplitude à tension pleine (77 % à 107 % de la tension assignée)

La valeur présumée du courant doit être mesurée par un essai préalable avec le parafoudre court-circuité ou remplacé par une connexion rigide d'impédance négligeable.

La durée d'un tel essai peut être limitée au minimum de temps nécessaire pour mesurer la valeur de crête et la composante symétrique de la forme d'onde de courant.

Pour les parafoudres de "conception B" soumis aux essais à la valeur du courant assigné de court-circuit, la valeur de crête du premier demi-cycle du courant présumé doit être d'au moins  $\sqrt{2}$  fois la valeur efficace du courant assigné de court-circuit.

Pour tous les courants de court-circuit réduits, la valeur efficace doit être conforme au Tableau 7 et la valeur de crête du premier demi-cycle du courant présumé doit être au moins égale à  $\sqrt{2}$  fois la valeur efficace de ce courant.

La connexion shunt rigide doit être retirée après vérification du courant présumé et le ou les parafoudres échantillons doivent être soumis aux essais avec les mêmes paramètres de circuit.

NOTE La résistance de l'arc restreint à l'intérieur du parafoudre peut réduire la valeur efficace de la composante symétrique et la valeur de crête du courant mesuré. Cela ne remet pas l'essai en cause, puisqu'il est effectué à au moins la tension de service normale et puisque l'effet sur le courant d'essai est le même que celui qui se produirait lors d'une défaillance en service.

Il convient de préférence que le rapport X/R de l'impédance du circuit d'essai, sans connecter le parafoudre, soit au moins de 15. Dans les cas où le rapport X/R de l'impédance du circuit d'essai est inférieur à 15, la tension d'essai peut être augmentée ou l'impédance peut être réduite, de sorte que,

- pour le courant assigné de court-circuit, la valeur de crête du premier demi-cycle du courant présumé soit égale ou supérieure à 2,5 fois le niveau du courant d'essai exigé;
- pour les essais à niveau de courant réduit, les tolérances du Tableau 7 soient satisfaites.

#### **8.9.4.3 Essai à courant de forte amplitude à une tension assignée inférieure à 77 %**

Lorsque les essais sont effectués avec une tension de circuit d'essai  $< 77\%$  de la tension assignée des échantillons pour essai, les paramètres du circuit d'essai doivent être ajustés de telle sorte que la valeur efficace de la composante symétrique du courant réel d'essai du parafoudre doit être égale ou supérieure au niveau de courant d'essai exigé choisi dans le Tableau 7.

Pour les parafoudres de "conception B" soumis aux essais à la valeur du courant assigné de court-circuit, la valeur de crête du premier demi-cycle du courant réel d'essai du parafoudre doit être d'au moins  $\sqrt{2}$  fois la valeur efficace du courant assigné de court-circuit.

Pour tous les courants de court-circuit réduits, la valeur efficace doit être conforme au Tableau 7 et la valeur de crête du demi-cycle du courant réel d'essai du parafoudre doit être au moins égale à  $\sqrt{2}$  fois la valeur efficace de ce courant.

#### **8.9.5 Essai de court-circuit à courant de faible amplitude**

L'essai doit être effectué en utilisant un circuit d'essai quelconque qui produit un courant traversant l'échantillon pour essai de  $600\text{ A} \pm 200\text{ A}$  en valeur efficace, mesuré environ 0,1 s après le début de l'écoulement de courant de court-circuit. Le courant doit s'écouler pendant au moins 1 s après la fusion du fil fusible.

Se reporter à 8.9.6 concernant la manipulation d'un parafoudre pour lequel la relaxation ne s'est pas produite.

#### **8.9.6 Évaluation des résultats d'essai**

L'essai est considéré comme réussi si les trois critères suivants sont satisfaits:

- a) Pas de rupture explosive. Une défaillance de structure de l'échantillon est admise tant que les critères b) et c) sont satisfaits.
- b) Aucune partie de l'échantillon pour essai ne doit pouvoir être trouvée à l'extérieur de l'enceinte, sauf
  - des fragments de céramique tels que des résistances à oxyde métallique ou de porcelaine pesant moins de 60 g chacun;
  - les opercules d'évents et diaphragmes du limiteur de pression;

- les parties souples de polymères.
- c) Le parafoudre doit être capable d'autoéteindre les flammes nues dans un délai de 2 min après l'essai. Toute partie éjectée (dans ou hors de l'enceinte) doit autoéteindre également les flammes nues dans un délai de 2 min. Une durée plus courte pour l'autoextinction des flammes nues pour les parties éjectées peut faire l'objet d'un accord entre le constructeur et l'utilisateur.

Si le parafoudre n'a visiblement pas connu de relaxation à la fin de l'essai, il convient de prendre des précautions, car l'enveloppe peut rester sous pression après l'essai. Ceci est applicable à tous les niveaux de courant d'essai, mais ceci est plus particulièrement pertinent pour les essais de court-circuit à courant de faible amplitude.

Pour les parafoudres à utiliser dans des applications dans lesquelles l'intégrité et une résistance mécaniques sont exigées après une défaillance, différentes procédures d'essai et évaluations peuvent être établies entre le constructeur et l'utilisateur (par exemple, il peut être exigé qu'à l'issue des essais, il convient que le parafoudre puisse encore être levé et retiré par son extrémité supérieure).

## **8.10 Essai de moment de flexion**

### **8.10.1 Généralités**

Cet essai s'applique aux parafoudres à enveloppe en porcelaine et en résine moulée pour  $U_s \leq 52$  kV pour lesquels le constructeur revendique une résistance à la rupture en flexion. L'essai doit être réalisé sur le parafoudre sans embase isolante ou console de montage.

L'ensemble de la procédure d'essai est présenté sur le logigramme à l'Annexe C.

### **8.10.2 Présentation générale**

Cet essai démontre la capacité du parafoudre à résister aux valeurs des efforts de flexion déclarées par le constructeur. Normalement, un parafoudre n'est pas conçu pour supporter un effort de torsion. Si un parafoudre est soumis à des efforts de torsion, un essai particulier peut être nécessaire après accord entre le constructeur et l'utilisateur.

L'essai doit être réalisé sur des éléments de parafoudres complets sans embase isolante ou console de montage, et sans surpression interne. Pour les parafoudres à un seul élément, l'essai doit être réalisé sur l'élément le plus long du modèle. Lorsqu'un parafoudre comporte plus d'un élément ou lorsqu'il supporte des moments de flexion spécifiés différents à chaque extrémité, l'essai doit être réalisé sur l'élément le plus long pour chacun des moments de flexion spécifiés différents, les charges étant déterminées selon C.1.

L'essai doit être réalisé en deux étapes, qui peuvent être effectuées sans ordre imposé:

- un essai de moment de flexion permettant de déterminer la valeur de l'effort moyen à la rupture (MBL);
- un essai de moment de flexion statique avec une charge d'essai égale à l'effort à court terme spécifié (SSL), c'est-à-dire 100 % de la valeur de C.2.

### **8.10.3 Préparation de l'échantillon**

Une extrémité de l'échantillon doit être solidement fixée à une surface de montage rigide de l'appareillage d'essai et une charge doit être appliquée à l'autre extrémité (libre) de l'échantillon, de manière à produire le moment de flexion exigé à l'extrémité fixe. La direction de la charge doit traverser l'axe longitudinal du parafoudre et lui être perpendiculaire. Si le parafoudre n'est pas axisymétrique par rapport à sa résistance à la flexion, le constructeur doit fournir des informations concernant cette résistance non symétrique et la charge doit être appliquée selon un angle soumettant la partie la plus faible du parafoudre au moment de flexion maximale. -

#### 8.10.4 Procédure d'essai

##### 8.10.4.1 Procédure d'essai pour déterminer la valeur de l'effort moyen à la rupture (MBL)

Trois échantillons doivent être soumis aux essais. Si l'essai de vérification du SSL (voir 8.10.4.2) est réalisé en premier, les échantillons de cet essai peuvent alors être utilisés pour déterminer le MBL. Les échantillons pour essai peuvent ne pas contenir leurs éléments internes. Pour chaque échantillon, l'effort de flexion doit être augmenté progressivement jusqu'à ce qu'il y ait rupture dans un délai de 30 s à 90 s. "Rupture" signifie une fracture de l'enveloppe ainsi que les dommages que peuvent subir le dispositif de fixation ou les embouts d'extrémité.

L'effort moyen à la rupture, MBL, est calculé comme étant la valeur moyenne des efforts à la rupture des échantillons pour essai.

NOTE L'enveloppe d'un parafoudre peut éclater lorsqu'elle est soumise à une charge et peut présenter un danger en cas de manutention.

##### 8.10.4.2 Procédure d'essai de vérification de l'effort à court terme spécifié (SSL)

Trois échantillons doivent être soumis aux essais. Les échantillons pour essai doivent contenir leurs éléments internes. Avant les essais, chaque échantillon pour essai doit être soumis à un contrôle d'étanchéité (voir point d) de 9.1) et à un essai de décharges partielles internes (voir point c) de 9.1). Si ces essais ont déjà été réalisés comme essais individuels de série, ils peuvent ne pas être répétés pour le moment.

L'effort de flexion doit être augmentée progressivement sur chaque échantillon, jusqu'à la valeur du SSL avec une tolérance de  $\pm 5\%$ , dans un délai de 30 s à 90 s. Une fois atteinte, la charge d'essai doit être maintenue pendant 60 s à 90 s. La déformation doit être mesurée pendant cette durée. Puis, la charge doit être progressivement relâchée et la déformation résiduelle doit être relevée. La déformation résiduelle doit être mesurée au cours de la période de 1 min à 10 min qui suit le relâchement de la charge.

NOTE L'enveloppe d'un parafoudre peut éclater lorsqu'elle est soumise à une charge et peut présenter un danger en cas de manutention.

##### 8.10.5 Évaluation de l'essai

Le parafoudre doit être considéré comme ayant satisfait à l'essai si

- la valeur de l'effort moyen à la rupture MBL, est  $\geq 1,2 \times \text{SSL}$ ;
- pour l'essai SSL
  - il n'y a aucun dommage mécanique visible;
  - la déformation permanente restante est égale à  $\leq 3 \text{ mm}$  ou  $\leq 10 \%$  de la déformation maximale pendant l'essai, selon la plus grande des deux valeurs;
  - les échantillons pour essai satisfont à l'essai d'étanchéité conformément au point d) de 9.1;
  - le niveau de décharges partielles internes des échantillons pour essai ne dépasse pas la valeur spécifiée en 9.1 c).

##### 8.10.6 Essai sur embase isolante et console de montage

Lorsque le parafoudre est fourni avec une embase isolante et/ou une console de montage, l'embase et/ou la console doivent être soumises à un essai de flexion. Trois échantillons de l'embase et de la console doivent être soumis aux essais. L'effort de flexion doit être augmenté progressivement sur chaque échantillon, jusqu'à la valeur d'un effort équivalent au SSL du parafoudre dans un délai de 30 s à 90 s. Une fois atteinte, la charge d'essai doit être maintenue pendant 60 s à 90 s. La charge doit ensuite être relâchée progressivement.