

INTERNATIONAL ELECTROTECHNICAL COMMISSION  
COMMISSION ÉLECTROTECHNIQUE INTERNATIONALE

---

**IEC 61000-4-11**  
Edition 3.0 2020-01

**IEC 61000-4-11**  
Édition 3.0 2020-01

**ELECTROMAGNETIC COMPATIBILITY (EMC) –**

**Part 4-11: Testing and measurement techniques**  
– Voltage dips, short interruptions and voltage  
variations immunity tests for equipment with  
input current up to 16 A per phase

**COMPATIBILITE ELECTROMAGNETIQUE (CEM) –**

**Partie 4-11: Techniques d'essai et de mesure –**  
Essais d'immunité aux creux de tension,  
coupures brèves et variations de tension pour  
les appareils à courant d'entrée inférieur ou égal  
à 16 A par phase

**C O R R I G E N D U M 1**

Corrections to the French version appear after the English text.

Les corrections à la version française sont données après le texte anglais.


**5.3 Voltage variations**

*Replace the heading with the following new heading:*

**5.3 Voltage variations (optional)**

**Figure 2 – Short interruption**

*Replace Figure 2 with the following new figure:*



IEC

**Table 4 – Generator specifications**

Replace the text of the sixth row with the following new text:

Voltage rise (and fall) time $t_r$ (and $t_f$ ), see Figure 1b), Figure 2 and Figure 3, during abrupt change, generator loaded with 100 $\Omega$ resistive load	Between 1 $\mu$ s and 5 $\mu$ s
---	---------------------------------

### 8.3.2 Voltage dips and short interruptions

Replace, in the sixth paragraph,

"See Figure 5b)."

with:

"See Figure 5."

IECNORM.COM : Click to view the full PDF of IEC 61000-4-11:2020/COR1:2020