

Standard on Facility Fire Brigades

2020



IMPORTANT NOTICES AND DISCLAIMERS CONCERNING NFPA® STANDARDS

NFPA® codes, standards, recommended practices, and guides ("NFPA Standards"), of which the document contained herein is one, are developed through a consensus standards development process approved by the American National Standards Institute. This process brings together volunteers representing varied viewpoints and interests to achieve consensus on fire and other safety issues. While the NFPA administers the process and establishes rules to promote fairness in the development of consensus, it does not independently test, evaluate, or verify the accuracy of any information or the soundness of any judgments contained in NFPA Standards.

The NFPA disclaims liability for any personal injury, property, or other damages of any nature whatsoever, whether special, indirect, consequential or compensatory, directly or indirectly resulting from the publication, use of, or reliance on NFPA Standards. The NFPA also makes no guaranty or warranty as to the accuracy or completeness of any information published herein.

In issuing and making NFPA Standards available, the NFPA is not undertaking to render professional or other services for or on behalf of any person or entity. Nor is the NFPA undertaking to perform any duty owed by any person or entity to someone else. Anyone using this document should rely on his or her own independent judgment or, as appropriate, seek the advice of a competent professional in determining the exercise of reasonable care in any given circumstances.

The NFPA has no power, nor does it undertake, to police or enforce compliance with the contents of NFPA Standards. Nor does the NFPA list, certify, test, or inspect products, designs, or installations for compliance with this document. Any certification or other statement of compliance with the requirements of this document shall not be attributable to the NFPA and is solely the responsibility of the certifier or maker of the statement.

REVISION SYMBOLS IDENTIFYING CHANGES FROM THE PREVIOUS EDITION

Text revisions are shaded. A \triangle before a section number indicates that words within that section were deleted and a \triangle to the left of a table or figure number indicates a revision to an existing table or figure. When a chapter was heavily revised, the entire chapter is marked throughout with the \triangle symbol. Where one or more sections were deleted, a \bullet is placed between the remaining sections. Chapters, annexes, sections, figures, and tables that are new are indicated with an N.

Note that these indicators are a guide. Rearrangement of sections may not be captured in the markup, but users can view complete revision details in the First and Second Draft Reports located in the archived revision information section of each code at www.nfpa.org/docinfo. Any subsequent changes from the NFPA Technical Meeting, Tentative Interim Amendments, and Errata are also located there.

REMINDER: UPDATING OF NFPA STANDARDS

Users of NFPA codes, standards, recommended practices, and guides ("NFPA Standards") should be aware that these documents may be superseded at any time by the issuance of a new edition, may be amended with the issuance of Tentative Interim Amendments (TIAs), or be corrected by Errata. It is intended that through regular revisions and amendments, participants in the NFPA standards development process consider the then-current and available information on incidents, materials, technologies, innovations, and methods as these develop over time and that NFPA Standards reflect this consideration. Therefore, any previous edition of this document no longer represents the current NFPA Standard on the subject matter addressed. NFPA encourages the use of the most current edition of any NFPA Standard [as it may be amended by TIA(s) or Errata] to take advantage of current experience and understanding. An official NFPA Standard at any point in time consists of the current edition of the document, including any issued TIAs and Errata then in effect.

To determine whether an NFPA Standard has been amended through the issuance of TIAs or corrected by Errata, visit the "Codes & Standards" section at www.nfpa.org.

ISBN: 978-145592568-1 (PDF)

ADDITIONAL IMPORTANT NOTICES AND DISCLAIMERS CONCERNING NFPA® STANDARDS

Updating of NFPA Standards

Users of NFPA codes, standards, recommended practices, and guides ("NFPA Standards") should be aware that these documents may be superseded at any time by the issuance of a new edition, may be amended with the issuance of Tentative Interim Amendments (TIAs), or be corrected by Errata. It is intended that through regular revisions and amendments, participants in the NFPA standards development process consider the then-current and available information on incidents, materials, technologies, innovations, and methods as these develop over time and that NFPA Standards reflect this consideration. Therefore, any previous edition of this document no longer represents the current NFPA Standard on the subject matter addressed. NFPA encourages the use of the most current edition of any NFPA Standard [as it may be amended by TIA(s) or Errata] to take advantage of current experience and understanding. An official NFPA Standard at any point in time consists of the current edition of the document, including any issued TIAs and Errata then in effect.

To determine whether an NFPA Standard has been amended through the issuance of TIAs or corrected by Errata, visit the "Codes & Standards" section at www.nfpa.org.

Interpretations of NFPA Standards

A statement, written or oral, that is not processed in accordance with Section 6 of the Regulations Governing the Development of NFPA Standards shall not be considered the official position of NFPA or any of its Committees and shall not be considered to be, nor be relied upon as, a Formal Interpretation.

Patents

The NFPA does not take any position with respect to the validity of any patent rights referenced in, related to, or asserted in connection with an NFPA Standard. The users of NFPA Standards bear the sole responsibility for determining the validity of any such patent rights, as well as the risk of infringement of such rights, and the NFPA disclaims liability for the infringement of any patent resulting from the use of or reliance on NFPA Standards.

NFPA adheres to the policy of the American National Standards Institute (ANSI) regarding the inclusion of patents in American National Standards ("the ANSI Patent Policy"), and hereby gives the following notice pursuant to that policy:

NOTICE: The user's attention is called to the possibility that compliance with an NFPA Standard may require use of an invention covered by patent rights. NFPA takes no position as to the validity of any such patent rights or as to whether such patent rights constitute or include essential patent claims under the ANSI Patent Policy. If, in connection with the ANSI Patent Policy, a patent holder has filed a statement of willingness to grant licenses under these rights on reasonable and nondiscriminatory terms and conditions to applicants desiring to obtain such a license, copies of such filed statements can be obtained, on request, from NFPA. For further information, contact the NFPA at the address listed below.

Law and Regulations

Users of NFPA Standards should consult applicable federal, state, and local laws and regulations. NFPA does not, by the publication of its codes, standards, recommended practices, and guides, intend to urge action that is not in compliance with applicable laws, and these documents may not be construed as doing so.

Copyrights

NFPA Standards are copyrighted. They are made available for a wide variety of both public and private uses. These include both use, by reference, in laws and regulations, and use in private self-regulation, standardization, and the promotion of safe practices and methods. By making these documents available for use and adoption by public authorities and private users, the NFPA does not waive any rights in copyright to these documents.

Use of NFPA Standards for regulatory purposes should be accomplished through adoption by reference. The term "adoption by reference" means the citing of title, edition, and publishing information only. Any deletions, additions, and changes desired by the adopting authority should be noted separately in the adopting instrument. In order to assist NFPA in following the uses made of its documents, adopting authorities are requested to notify the NFPA (Attention: Secretary, Standards Council) in writing of such use. For technical assistance and questions concerning adoption of NFPA Standards, contact NFPA at the address below.

For Further Information

All questions or other communications relating to NFPA Standards and all requests for information on NFPA procedures governing its codes and standards development process, including information on the procedures for requesting Formal Interpretations, for proposing Tentative Interim Amendments, and for proposing revisions to NFPA standards during regular revision cycles, should be sent to NFPA headquarters, addressed to the attention of the Secretary, Standards Council, NFPA, 1 Batterymarch Park, P.O. Box 9101, Quincy, MA 02269-9101; email: stds_admin@nfpa.org.

For more information about NFPA, visit the NFPA website at www.nfpa.org. All NFPA codes and standards can be viewed at no cost at www.nfpa.org/docinfo.

Copyright © 2019 National Fire Protection Association[®]. All Rights Reserved.

NFPA® 600

Standard on

Facility Fire Brigades

2020 Edition

This edition of NFPA 600, *Standard on Facility Fire Brigades*, was prepared by the Technical Committee on Loss Prevention Procedures and Practices. It was issued by the Standards Council on November 4, 2019, with an effective date of November 24, 2019, and supersedes all previous editions.

This edition of NFPA 600 was approved as an American National Standard on November 24, 2019.

Origin and Development of NFPA 600

In 1902 NFPA adopted Suggestions for Organizing Private Fire Departments recommended by the Committee on Private Fire Department Regulations. In 1912 NFPA adopted two pamphlets, Organization and Execution of Exit Drills and Organization and Drilling of Private Fire Brigades, on the recommendation of the Committee on Private Fire Departments and Fire Drills. In 1924 the NFPA adopted Suggestions for the Organization, Drilling and Equipment of Private Fire Brigades on the recommendation of the Committee on Field Practice, and revisions were adopted in 1930, 1937, and 1949.

Jurisdiction for the publication was transferred in 1948 to the new Committee on Fire Brigades and Watchmen, and a revised edition was published in 1955. The guide was completely revised in 1967

In 1969 the committee was reorganized as the Technical Committee on Loss Prevention Procedures and Practices, and the guide was reconfirmed in 1975. In 1981 a complete revision was accomplished, and a partial revision was made in the 1986 edition, as well as a redesignation from NFPA 27 to NFPA 600.

In 1992 the document was completely revised as a standard to provide a minimum level of occupational safety and health for industrial fire brigade members consistent with the Occupational Safety and Health Administration (OSHA). The standard incorporated the concepts of advanced exterior fire fighting and site-specific hazards for the first time. These concepts were needed for industrial fire brigades to properly address the types of situations they encounter.

In 1996 the document was revised to include industrial fire departments, which were previously addressed in NFPA 1500, Standard on Fire Department Occupational Safety and Health Program. This reorganization assisted the authority having jurisdiction and owner/operators in determining the standard they must comply with and if they are in compliance. Other changes made the document more user friendly and better clarified the requirements of the standard.

Changes to the 2000 edition were mainly editorial or were provided for clarification. A noteworthy exception was the change in the number of industrial fire brigade members for interior structural fire fighting. Two industrial fire brigade members were now required to be available for rescue, whereas the previous edition required only one.

The 2005 edition incorporated revised definitions that correspond to preferred terms found in the Glossary of Terms. One of the definition changes incorporated a broader scope for the medical professionals who assess medical and physical fitness of fire brigade members. The term *qualified physician* was replaced by *qualified health care professional* to reflect actual practice.

The 2005 edition added references to the professional qualification standard, NFPA 1081, Standard for Industrial Fire Brigade Member Professional Qualifications, which was adopted after the effective date of the 2000 edition. The standard was also revised and reorganized in accordance with the Manual of Style for NFPA Technical Committee Documents.

For the 2015 edition, the standard was reorganized. The committee believed that the hazards to a fire brigade from interior structural and advanced exterior fire fighting were the same, including the potential for an IDLH environment, and therefore the consolidated requirements from the two separate chapters into one chapter applicable to both. In addition, the committee changed the title of the document from *Industrial Fire Brigades* to *Facility Fire Brigades*, recognizing that fire brigades exist beyond industrial settings. The word *facility* replaced *industrial* throughout the standard.

In the 2020 edition, several modifications were made to increase the scope of the standard and to provide the stakeholder with more concise language. In Chapter 1, new material was added for facility fire brigades that respond to offsite fire emergencies in conjunction with local fire departments.

The individual(s) designated by senior management is responsible for the organization, management, and nonemergency response functions of the facility fire brigade.

In Chapter 3, definitions were expanded to include specific details about potential time intervals and adding timing flexibility.

In Chapter 4, the language was modified in several areas to provide clarification on responsibilities. The language was edited to indicate who is in charge of an incident when an incipient fire occurs. The revised language also provides direction for designated representatives within an organizational statement. The role of the facility fire brigade leader was also better defined. These changes were made to avoid potential confusion about responsibilities during a fire emergency.

Mandatory language was added regarding the requirement to develop a site-specific risk management policy for employees who serve as facility fire brigade members. It was added to clarify the potential risks that are involved with responding to a fire emergency.

Section 4.11 was modified to reflect proper inventory management so that the items needed for a response would be readily available.

In Chapter 6, a requirement was added to ensure that protective thermal clothing and protective equipment are used and maintained according to the standards of NFPA 1851, *Standard on Selection, Care, and Maintenance of Protective Ensembles for Structural Fire Fighting and Proximity Fire Fighting.* This requirement was added to ensure the proper protection of facility fire brigade members during a fire emergency.

Annex A was revised to cite federal regulations accurately and to match the requirements of 29 CFR 1910.156, "Fire Brigades."

Technical Committee on Loss Prevention Procedures and Practices

Joseph A. Cocciardi, *Chair* Cocciardi and Associates, Inc., PA [SE] Rep. Commonwealth of Pennsylvania

Paul H. Aube, Termont, Canada [SE]

George J. Browne, TUV/SUD America Inc./Global Risk

Consultants Corporation, NJ [SE]

Thomas L. Caisse, FM Global, RI [I]

Gary L. Guenette, Johnson Controls, WI [M]

Edward M. Hawthorne, Shell Oil Company, TX [U]

Rep. American Petroleum Institute

Haruki Howell, McKee Foods Corporation, TN [U]

Jeff Kling, Arconic Davenport Works, IA [M]

Ryan Ludwick, Hemlock Semiconductor Corporation, MI [U]

John Richard Lussi, Talen Energy, PA [U]

Jeff Martin, Elite Fire Protection, Canada [IM]

Warren Burns, Telgian Corporation, AZ [SE]

Michael M. Dillon, [ENSEN HUGHES, IL [M]

Richard Philbrick, Shell Oil Company, TX [U]

(Alt. to Edward M. Hawthorne)

Theodore K. Pisciotta, FM Global, CT [I]

(Alt. to Craig P. Remsburg)

(Alt. to Paul Valentine)

(Alt. to Haruki Howell)

(Alt. to Thomas L. Caisse)

Rep. National Association of Fire Equipment Distributors

Kevin Phelan, Liberty Mutual Insurance, NH [I]

Craig P. Remsburg, Telgian Corporation, AZ [SE]

Jeffrey L. Robinson, Robinson Risk Consulting, LLC, SC [SE]

Robert H. Stagg, Guardsmark, LLC, NC [SE]

Jason Steele, Tennessee Valley Authority, AL [U]

Dariusz Szwarc, US Nuclear Regulatory Commission, IL [E]

Jeff Thomas, State Farm Insurance, IL [I]

Paul Valentine, TUV SUD America Inc./Global Risk Consultants, IL

Rep. International Fire Service Training Association

Randal Wakeman, Nuclear Service Organization (NSO), DE [I]

Alternates

Atif Shaikh, Nuclear Regulatory Commission, IL [E] (Alt. to Dariusz Szwarc)

Barry Lynn Snook, Snook Consulting, OH [SE]

(Alt. to Jeffrey L. Robinson)

Michael John Stanley, Nuclear Service Organization (NSO), DE [I] (Alt. to Randal Wakeman)

Ray A. Webber, The Procter & Gamble Company, OH [U] (Voting Alt.)

John A. Welling, III, Bristol-Myers Squibb Company, NJ [U] (Voting Alt.)

Nonvoting

William R. Hamilton, US Department of Labor, DC [E]

Jennifer E. Morris, McKee Foods Corporation, TN [U]

Stanford E. Davis, Hunlock Creek, PA [SE] (Member Emeritus)

Debra M. Gursha, NFPA Staff Liaison

This list represents the membership at the time the Committee was balloted on the final text of this edition. Since that time, changes in the membership may have occurred. A key to classifications is found at the back of the document.

NOTE: Membership on a committee shall not in and of itself constitute an endorsement of the Association or any document developed by the committee on which the member serves.

Committee Scope: This Committee shall have primary responsibility for documents on fire brigades, guard services, and techniques for securing effective fire loss prevention programs in industrial, commercial, institutional, and similar properties.

Contents

Chapter	1 Administration	600– 5	4.11	Fac	ility Fire Brigade Equipment	600– 11
$1.\hat{1}$	Scope	600– 5	4.12	Fac	ility Fire Brigade Apparatus	600– 11
1.2	Purpose.	600– 5				
1.3	Application	600– 5	Chapter	5	Facility Fire Brigades That Perform	
1.4	Equivalency	600– 5			Incipient Stage Fire Fighting	600– 12
1.5	Units and Formulas.	600– 5	5.1		neral	600– 12
			5.2	Lim	nits for Facility Fire Brigades Assigned	
Chapter	2 Referenced Publications	600– 5			ipient Fire-Fighting Response Duties	600– 12
2.1	General.	600– 5	5.3	Edι	ication, Training, and Drills	600– 12
2.2	NFPA Publications.	600– 5	5.4	Pro	tective Clothing and Protective Equipment.	600– 12
2.3	Other Publications.	600– 6	5.5	Mee	dical	600– 12
2.4	References for Extracts in Mandatory Sections.	600– 6				
			Chapter	6	Facility Fire Brigades That Perform	
Chapter		600– 6			Advanced Exterior or Interior Structural	
3.1	General.	600– 6			Fire Fighting	600– 12
3.2	NFPA Official Definitions	600– 6	6.1		neral	600– 12
3.3	General Definitions.	600– 6	6.2	Lim	nits of Facility Fire Brigades Assigned Both	
				Adv	ranced Exterior and Interior Structural Fire-	
Chapter	, 0	600 – 8		Figl	nting Response Duties	600– 12
4.1	General.	600 – 8	6.3		erational Requirements	600– 13
4.2	Organization and Administration	600– 8	6.4	Εdι	ication, Training, and Drills	600– 13
4.3	Standard Operating Procedures (SOP)	600– 9	6.5		tective Clothing and Protective Equipment.	600– 13
4.4	Incident Management System (IMS)	600– 9	6.6		dical	600– 13
4.5	Risk Management Policy	600– 9				
4.6	Training and Education.	600– 9	Annex A	1	Explanatory Material	600– 14
4.7	Drills.	600– 10				200 01
4.8	Training and Drill Records	600– 10	Annex I	3	Informational References	600 – 21
	Responsibilities in the Facility Fire Brigade		Total con			600– 23
	Organization.	600– 10	Index			
4.10	Medical and Job-Related Physical					
	Requirements.	600– 11				

NFPA 600

Standard on

Facility Fire Brigades

2020 Edition

IMPORTANT NOTE: This NFPA document is made available for use subject to important notices and legal disclaimers. These notices and disclaimers appear in all publications containing this document and may be found under the heading "Important Notices and Disclaimers Concerning NFPA Standards." They can also be viewed at www.nfpa.org/disclaimers or obtained on request from NFPA.

UPDATES, ALERTS, AND FUTURE EDITIONS: New editions of NFPA codes, standards, recommended practices, and guides (i.e., NFPA Standards) are released on scheduled revision cycles. This edition may be superseded by a later one, or it may be amended outside of its scheduled revision cycle through the issuance of Tentative Interim Amendments (TIAs). An official NFPA Standard at any point in time consists of the current edition of the document, together with all TIAs and Errata in effect. To verify that this document is the current edition or to determine if it has been amended by TIAs or Errata, please consult the National Fire Codes® Subscription Service or the "List of NFPA Codes & Standards" at www.nfpa.org/docinfo. In addition to TIAs and Errata, the document information pages also include the option to sign up for alerts for individual documents and to be involved in the development of the next edition.

NOTICE: An asterisk (*) following the number or letter designating a paragraph indicates that explanatory material on the paragraph can be found in Annex A.

A reference in brackets [] following a section or paragraph indicates material that has been extracted from another NFPA document. Extracted text may be edited for consistency and style and may include the revision of internal paragraph references and other references as appropriate. Requests for interpretations or revisions of extracted text shall be sent to the technical committee responsible for the source document.

Information on referenced and extracted publications can be found in Chapter 2 and Annex B.

Chapter 1 Administration

1.1* Scope.

- **1.1.1** This standard contains minimum requirements for organizing, operating, training, and equipping facility fire brigades for response to fires in industrial, commercial, institutional, and similar properties.
- **1.1.2** This standard provides minimum requirements for the occupational safety and health of facility fire brigade members while performing fire fighting and related response activities.
- **1.2* Purpose.** The purpose of this standard is to provide minimum requirements for organization, operation, training, and occupational safety and health for facility fire brigades.

1.3 Application.

Δ 1.3.1* This standard shall apply to any organized group of employees having fire-fighting response duties, such as emergency brigades, emergency response teams, fire teams, and plant emergency organizations.

- △ 1.3.2* This standard shall apply to facility fire brigades that respond to fire emergencies off-site when the fire brigade is trained and familiar with the hazards associated with the fire and when they are responding in support of another facility fire brigade.
- **N** 1.3.2.1 This standard shall apply if the facility fire brigade is responding to a fire emergency off-site in conjunction with a fire department subject to the requirements of NFPA 1500 and if the facility fire brigade is trained and familiar with the hazards associated with the incident.
 - 1.3.3* This standard shall not apply to medical response, confined space rescue response, and hazardous material response activities.
 - **1.3.4** This standard shall not apply to fire departments complying with NFPA 1500.
 - **1.4* Equivalency.** Nothing in this standard is intended to prevent the use of systems, methods, or devices of equivalent or superior quality, strength, fire resistance, effectiveness, durability, and safety over those prescribed by this standard.

1.5 Units and Formulas.

- **1.5.1** The units of measure in this standard are presented in the International System (SI) of Units. Where presented, U.S. customary units (inch-pound units) follow the SI units in parentheses.
- **1.5.2** Where both systems of units are presented, either system shall be acceptable for satisfying the requirements in this standard.
- **1.5.3** Where both systems of units are presented, users of this standard shall apply one set of units consistently and shall not alternate between units.
- **1.5.4** The values presented for measurements in this standard are expressed with a degree of precision appropriate for practical application and enforcement. It is not intended that the application or enforcement of these values be more precise than the precision expressed.
- 1.5.5 Where extracted text contains values expressed in only one system of units, the values in the extracted text have been retained without conversion to preserve the values established by the responsible technical committee in the source document.

Chapter 2 Referenced Publications

- **2.1 General.** The documents or portions thereof listed in this chapter are referenced within this standard and shall be considered part of the requirements of this document.
- **2.2 NFPA Publications.** National Fire Protection Association, 1 Batterymarch Park, Quincy, MA 02169-7471.

NFPA 30, Flammable and Combustible Liquids Code, 2018 edition.

NFPA 1081, Standard for Facility Fire Brigade Member Professional Qualifications, 2018 edition.

NFPA 1403, Standard on Live Fire Training Evolutions, 2018 edition.

NFPA 1500^{TM} , Standard on Fire Department Occupational Safety, Health, and Wellness Program, 2020 edition.

NFPA 1851, Standard on Selection, Care, and Maintenance of Protective Ensembles for Structural Fire Fighting and Proximity Fire Fighting, 2020 edition.

NFPA 1911, Standard for the Inspection, Maintenance, Testing, and Retirement of In-Service Emergency Vehicles, 2017 edition.

NFPA 1971, Standard on Protective Ensembles for Structural Fire Fighting and Proximity Fire Fighting, 2018 edition.

NFPA 1981, Standard on Open-Circuit Self-Contained Breathing Apparatus (SCBA) for Emergency Services, 2019 edition.

NFPA 1982, Standard on Personal Alert Safety Systems (PASS), 2018 edition.

2.3 Other Publications.

2.3.1 ASTM Publications. ASTM International, 100 Barr Harbor Drive, P.O. Box C700, West Conshohocken, PA 19428-2959.

ASTM D323, Standard Test Method for Vapor Pressure of Petroleum Products (Reid Method), 2015a.

2.3.2 Other Publications.

Merriam-Webster's Collegiate Dictionary, 11th edition, Merriam-Webster, Inc., Springfield, MA, 2003.

2.4 References for Extracts in Mandatory Sections.

NFPA 30, Flammable and Combustible Liquids Code, 2018 edition.

NFPA $1500^{\rm TM}$, Standard on Fire Department Occupational Safety, Health, and Wellness Program, 2020 edition.

NFPA 1521, Standard for Fire Department Safety Officer Professional Qualifications, 2020 edition.

NFPA 1561, Standard on Emergency Services Incident Management System and Command Safety, 2020 edition.

Chapter 3 Definitions

3.1 General. The definitions contained in this chapter shall apply to the terms used in this standard. Where terms are not defined in this chapter or within another chapter, they shall be defined using their ordinarily accepted meanings within the context in which they are used. *Merriam-Webster's Collegiate Dictionary*, 11th edition, shall be the source for the ordinarily accepted meaning.

3.2 NFPA Official Definitions.

- **3.2.1* Approved.** Acceptable to the authority having jurisdiction.
- **3.2.2* Authority Having Jurisdiction (AHJ).** An organization, office, or individual responsible for enforcing the requirements of a code or standard, or for approving equipment, materials, an installation, or a procedure.
- 3.2.3 Shall. Indicates a mandatory requirement.
- **3.2.4 Should.** Indicates a recommendation or that which is advised but not required.
- **3.2.5 Standard.** An NFPA Standard, the main text of which contains only mandatory provisions using the word "shall" to indicate requirements and that is in a form generally suitable for mandatory reference by another standard or code or for adoption into law. Nonmandatory provisions are not to be considered a part of the requirements of a standard and shall be located in an appendix, annex, footnote, informational

note, or other means as permitted in the NFPA Manuals of Style. When used in a generic sense, such as in the phrase "standards development process" or "standards development activities," the term "standards" includes all NFPA Standards, including Codes, Standards, Recommended Practices, and Guides.

3.3 General Definitions.

- **3.3.1* Combustible Liquid.** Any liquid that has a closed-cup flash point at or above 37.8°C (100°F), as determined by the test procedures and apparatus set forth in Section 4.4 of NFPA 30. Combustible liquids are classified according to Section 4.3 of NFPA 30. [**30**, 2018]
- **3.3.2* Control Zones.** The areas at an incident that are designated based upon safety and the degree of hazard. [1500, 2020]
 - **3.3.2.1** *Cold Zone.* The control zone of an incident that contains the command post and such other support functions as are deemed necessary to control the incident. [1500, 2020]
 - **3.3.2.2** *Hot Zone.* The control zone immediately surrounding a hazardous area, which extends far enough to prevent adverse effects to personnel outside the zone. [1500, 2020]
 - **3.3.2.3** *Warm Zone.* The control zone outside the hot zone where personnel and equipment decontamination and hot zone support takes place. [1500, 2020]
- **3.3.3 Designated Employee.** An employee who is not a member of a facility fire brigade but who has been trained to use portable fire extinguishers or small hose lines to fight incipient fires in the employee's immediate work area.
- **3.3.4 Drill.** An exercise involving a credible simulated emergency that requires personnel to perform emergency response operations for the purpose of evaluating the effectiveness of the training and education programs and the competence of personnel in performing required response duties and functions.
- **3.3.5 Drug.** Any substance, chemical, over-the-counter medication, or prescribed medication that can affect performance.
- **3.3.6* Education.** The process of imparting knowledge or skill through systematic instruction.
- **3.3.7 Emergency Response Operations.** Activities related to emergency incidents, including response to the scene of the incident and specific response duties performed at the scene.
- **3.3.8* Enclosed Structure.** A structure with a roof or ceiling and at least two walls that can present fire hazards to occupants.
- **3.3.9* Facility.** Any location or structure including industrial, commercial, mercantile, warehouse, power plant (utility), areas of assembly, institutional or similar occupancy, public, and private as well as for-profit, not-for-profit, and governmental facilities.
- △ 3.3.10 Facility Fire Brigade. An organized group of employees at a facility who are knowledgeable, trained, and skilled in at least basic fire-fighting operations, and whose full-time occupation might be the provision of fire suppression and related activities for their employer.

- 3.3.11 Facility Fire Brigade Apparatus. A facility fire brigade emergency response vehicle designed and intended primarily for fire suppression, rescue, or other specialized function that includes pumpers, foam apparatus, aerial ladders, rescue vehicles, and other such apparatus.
- 3.3.12 Facility Fire Brigade Leader. An individual responsible for overseeing the performance or activity of other members.
- 3.3.13 Facility Fire Brigade Management. The individual(s) designated by senior management to be responsible for the organization, management, and nonemergency response functions of the facility fire brigade.
- 3.3.14 Facility Fire Brigade Training Coordinator. The designated company representative with responsibility for coordinating effective, consistent, and quality training within the facility fire brigade training and education program.

3.3.15 Fire Fighting.

- 3.3.15.1* Advanced Exterior Fire Fighting. Offensive fire fighting performed outside of an enclosed structure when the fire is beyond the incipient stage.
- 3.3.15.2 Defensive Fire Fighting. The mode of manual fire control in which the only fire suppression activities taken are limited to those required to keep a fire from extending from one area to another.
- 3.3.15.3 Incipient Fire Fighting. Fire fighting performed inside or outside of an enclosed structure or building when the fire has not progressed beyond incipient stage.
- 3.3.15.4 Interior Structural Fire Fighting. The physical activity of fire suppression, rescue, or both inside of buildings or enclosed structures that are involved in a fire beyond the incipient stage.
 - 3.3.15.5 Offensive Fire Fighting. The mode of manual fire control in which manual fire suppression activities are concentrated on reducing the size of a fire to accomplish extinguishment.

3.3.16 Fit.

- **3.3.16.1** *Medically Fit.* As determined by a qualified health care professional, having no known medical limitations that would interfere with the process of making decisions and providing direction while exposed to a stressful environment.
- 3.3.16.2 Physically Fit. As determined by a qualified health care professional, having no known physical or medical limitations that would interfere with the performance of strenuous heavy lifting and pulling or with the use of selfcontained breathing apparatus (SCBA) that can be required during emergency response organizations.
- 3.3.17* Flammable Liquid. Any liquid that has a closed-cup flash point below 37.8°C (100°F), as determined by the test procedures and apparatus set forth in Section 4.4 of NFPA 30, and a Reid vapor pressure that does not exceed an absolute pressure of 276 kPa (40 psi) at 37.8°C (100°F), as determined by ASTM D323, Standard Test Method for Vapor Pressure of Petroleum Products (Reid Method). Flammable liquids are classified according to Section 4.3 of NFPA 30. [30, 2018]

N 3.3.18 Frequency.

- 3.3.18.1 Annually. Occurring once every 12 months with a minimum of 9 months and a maximum of 15 months between each occurrence.
- 3.3.18.2 Monthly. Occurring once per calendar month. N
- N**3.3.18.3** *Quarterly.* Occurring four times every 12 months with a minimum of 2 months and a maximum of 4 months between each occurrence.
- 3.3.18.4 Semiannually. Occurring twice every 12 months with a minimum of 4 months and a maximum of 8 months between each occurrence.
- **3.3.18.5** *Weekly.* Occurring once per calendar week.
 - 3.3.19* Incident Management System (IMS). A system that defines the roles and responsibilities to be assumed by responders and the standard operating procedures to be used in the management and direction of emergency incidents and other functions. [1561, 2020]
 - 3.3.20* Incipient Stage Fire. A fire which is in the initial or beginning stage and which can be controlled or extinguished by portable fire extinguishers, Class II standpipe, or small hose systems without the need for protective clothing or breathing apparatus.
 - 3.3.21 Master Stream. A portable or fixed fire-fighting appliance that is supplied by either hose lines or fixed piping and that has the capability of flowing in excess of 1140 L/min (300 gpm) of water or water-based extinguishing agent.
 - 3.3.22 Performance Standards. Minimum requirements for knowledge and skills that must be provided to or demonstrated by the facility fire brigade member upon completion of a training or education session.
 - 3.3.23* Qualified Health Care Professional. A licensed medical doctor or other licensed health care professional qualified to provide professional expertise in the areas of occupational safety and health as related to emergency response activities.
 - 3.3.24 Response Duty. A fire-related service, function, or task identified in the facility fire brigade organizational statement and assigned to a member to perform.
 - 3.3.25 Site-Specific Hazard. A hazard that is present at the specific facility for which the facility fire brigade has been organized.
 - 3.3.26 Specialized Agents. Fire-extinguishing agents, such as dry chemicals, dry powders, carbon dioxide, halon, and other such non-water-based agents.
 - 3.3.27 Standard Operating Procedure (SOP). A written organizational directive that establishes or prescribes specific operational or administrative methods to be followed routinely for the performance of designated operations or actions. [1521, 2020]
 - 3.3.28* Support Members. Personnel assigned to the facility fire brigade to perform specific response duties, including those people who have specific technical knowledge or skills or who have been given specific assignments that indirectly support manual fire suppression efforts.

- **3.3.29* Thermal Protective Clothing.** Protective clothing that is designed and manufactured to protect the facility fire brigade member from the adverse effects of fire.
- **3.3.30 Training.** The process of achieving proficiency through instruction and hands-on practice in the operation of equipment and systems that are expected to be used in the performance of assigned response duties.

Chapter 4 Facility Fire Brigade Fundamentals

4.1 General.

- **4.1.1** This chapter shall apply to all types of facility fire brigades.
- **4.1.2*** At facilities where designated workers, who are not facility fire brigade members, are trained to respond to incipient fires, the facility fire brigade shall assume command of the incident upon arrival.
- **4.1.3*** Facility fire brigades shall be classified into one or more of the following types:
- (1) Incipient stage fire fighting
- (2) Advanced exterior fire fighting only
- (3) Interior structural fire fighting only
- (4) Both advanced exterior and interior structural fire fighting
- **4.1.4** The actions and responsibilities of the facility fire brigade shall be limited.
- **4.1.4.1*** The potential exposure to a hazardous environment and the extent of training shall determine the limits of facility fire brigade actions and responsibilities.
- **4.1.4.2** The written facility fire brigade organizational statement and standard operating procedures (SOP) shall define these limits.
- **4.1.4.3*** The minimum number of facility fire brigade members required to operate at an incident shall be established.
- **4.1.5*** Facility fire brigade members shall be issued identification.

4.2 Organization and Administration.

- △ 4.2.1 Corporate or local management shall be responsible for all of the following:
 - (1) Evaluating site-specific conditions and hazards
 - (2)* Assigning site-specific duties for the facility fire brigade
 - (3)* Establishing a written policy for occupational safety and health of facility fire brigade members
 - (4)* Establishing a written policy for the medical and jobrelated physical performance requirements for facility fire brigade members
 - (5) Developing or adopting performance-based standards that establish baseline levels of proficiency in skills, knowledge, and the safety measures necessary for facility fire brigade members to accomplish assigned response duties
 - (6) Maintaining a system to advise facility fire brigade management of changes in a worker's eligibility for participation in a facility fire brigade
 - (7) Establishing a policy to maintain records required in this standard

- (8)* Budgeting funds for equipment, vehicles, training and education, medical and job-related physical performance evaluations, and other necessary items for operation of the facility fire brigade
- (9) A means for facility fire brigade communications to achieve the following:
 - (a) Notification of facility fire brigade members of an incident
 - (b) Communications between facility fire brigade members during an incident
- **4.2.2*** Management shall establish, review, and maintain a written facility fire brigade organizational statement.
- **4.2.2.1*** The existence of the facility fire brigade shall be established in the organizational statement.
- **4.2.2.2** The organizational statement shall include all of the following:
- (1)* Basic organizational structure
- (2) The type, amount, and frequency of training and education to be provided
- (3) The expected number of members in the brigade
- (4)* The response duties that the brigade is expected to perform
- (5) The shifts during which the brigade members are available for response
- **4.2.2.3** The organizational statement shall be available for inspection by the authority having jurisdiction, the facility fire brigade members, and the members' designated representatives.
- **4.2.3** Management shall establish lines of authority and assign responsibilities for operation of the facility fire brigade.
- **4.2.3.1** Management shall designate the responsible individual for the administration of the facility fire brigade, including the training and education program.
- **4.2.3.2** Management shall establish responsibility for initiating, maintaining, and enforcing SOP to ensure the safety and health of facility fire brigade members.
- **4.2.3.3** Management shall establish a policy to ensure that each facility fire brigade member cooperates, participates, and complies with the provisions of the facility fire brigade organizational statement and the training and education program.
- **4.2.4*** Management shall identify specific goals and objectives for the prevention and elimination of accidents, injuries, illness, and fatalities while performing facility fire brigade duties.
- **4.2.4.1** Management shall include facility fire brigade members on corporate or local company occupational safety and health committees.
- **4.2.4.2*** Management shall delegate the duties and responsibilities of the facility fire brigade safety program to qualified individuals.
- **4.2.4.3** The safety program shall include the following:
- (1) Records and data management
- Liaison with management, equipment suppliers, site or corporate safety, and medical and health departments
- (3) Development and maintenance of SOP
- (4) Accident prevention

- (5) Equipment specification and maintenance
- (6) Accident investigation
- (7) Incident scene safety
- (8) Training and education
- **4.2.5*** Records required in this standard shall be maintained in a location available for inspection by the authority having jurisdiction.

4.3 Standard Operating Procedures (SOP).

- **4.3.1** Standard operating procedures (SOP) shall be developed, reviewed, and maintained in written form.
- **4.3.1.1** The SOP shall cover site-specific conditions and hazards.
- **4.3.1.2** The SOP shall identify procedures for management of critical processes to be followed during incidents.
- **4.3.1.3** Procedures shall be written for the site-specific duties identified in the facility fire brigade organizational statement.
- **4.3.1.4** The SOP and pre-incident plans shall be reviewed periodically and updated to reflect changes at the site including, but not limited to, changes in special hazards.
- **4.3.2*** The SOP shall list special hazards, such as storage and use of flammable liquids and gases, toxic chemicals, radioactive sources, and water reactive substances, that facility fire brigade members can be exposed to during fire and other emergencies
- **4.3.2.1** Facility fire brigade members shall be advised of any changes that occur in relation to the special hazards.
- **4.3.2.2** Facility fire brigade members shall receive training and education on how to handle site-specific special hazards.
- **4.3.2.3** NFPA 1081 shall be used to establish minimum levels of proficiency in both skills and knowledge to permit facility fire brigade members to safely accomplish the site-specific response duties.
- **4.3.3** The SOP shall include all of the following for facility fire brigades:
- Organization and operation (incident and non-response duties)
- (2) Site-specific limitations
- (3) Pre-incident planning
 - (1) Implementation
 - (2) Periodic review and updates
 - (3) Pre-incident plan accessible to incident command
- **4.3.4** The SOP shall be accessible to all facility fire brigade members.
- **4.3.5** The SOP shall have procedures for activation, control, and use of fire protection systems and equipment.
- **4.3.6** The facility fire brigade leader or deputy facility fire brigade leader on duty shall be notified of fire protection systems and equipment status, including those that are out of service.
- **4.4 Incident Management System (IMS).** An incident management system (IMS) shall be utilized during incidents beyond the incipient stage and in training operations.
- **4.4.1*** An IMS shall be established with written procedures.

- **4.4.1.1** Facility fire brigade members shall be familiar with the IMS.
- **4.4.1.2** The IMS shall identify roles and responsibilities of leadership.
- **4.4.1.2.1** There shall be an incident commander at each incident where the IMS is used.
- **4.4.1.2.2** Leadership shall be responsible for safety during facility fire brigade operations.
- **4.4.2** Safety responsibilities shall be assigned to supervisory personnel at each level of the organization.
- **4.4.3** The IMS shall include the roles and responsibilities of any responding public fire department and other outside agencies.
- **4.4.4*** A standard system shall be used to identify and account for each facility fire brigade member present at the scene of the incident.
- **4.4.5** The incident commander shall ensure that the risk to members is evaluated prior to taking action.
- **4.4.5.1** In situations where the risk to facility fire brigade members is unacceptable, the incident response activities shall be limited to defensive fire fighting.
- **4.4.5.2** Regardless of the risk, actions shall not exceed the scope of the organizational statement and SOP.

4.5 Risk Management Policy.

- **4.5.1*** A risk management policy for incident response shall be established by facility fire brigade management.
- **4.5.1.1** The risk management policy shall include the following recognized principles:
- Some risk to the safety of facility fire brigade members shall be acceptable where saving human lives is possible.
- (2) Minimal risk to the safety of the facility fire brigade members, and only in a calculated manner, shall be acceptable where saving endangered property is possible.
- (3) No risk to the safety of facility fire brigade members shall be acceptable where saving lives or property is not possible.
- **4.5.1.2** The risk management policy shall be routinely reviewed with facility fire brigade members.
- **4.5.1.3** Corrective action plans shall be established for noncompliance with the risk management policy.
- **4.5.2*** Incident operations scenarios and drills shall be used to evaluate the risks.
- **4.5.3** The incident commander shall maintain control of all zones.

4.6 Training and Education.

- **4.6.1*** A training and education program shall be established and maintained.
- Δ 4.6.1.1 The goals for training and education shall include, but not be limited to, all of the following:
 - (1)* Preventing on-duty accidents that result in injury, illness, or death of facility fire brigade members

- (2)* Developing competency in life safety, property conservation, and reduction of business interruption
- (3) Controlling the fire within the limitations of the risk management policy established under Section 4.5
- **4.6.1.2** The training and education program shall include, but not be limited to, all of the following:
- (1)* A review of the applicable provisions of this standard
- (2) Basic fire chemistry
- (3) The principles and practices of fire fighting and emergency response to the extent required for the type of facility fire brigade and member's assignment within the brigade
- New hazards, equipment, and procedures introduced into the facility
- (5) Site-specific hazards
- **4.6.2*** A facility fire brigade training coordinator shall be designated to manage the training and education program.
- **4.6.2.1** The training coordinator shall conduct training and education or delegate the training and education to qualified instructors.
- **4.6.2.2** The training coordinator shall verify the qualifications of instructors.
- **4.6.3** Members shall be trained to a level of competency commensurate with the response duties and functions that they are expected to perform, including the operation of fire-fighting and rescue equipment and systems.
- **4.6.4*** Members shall meet the minimum job performance requirements of NFPA 1081 for each site-specific task they are expected to perform before their participation in emergency response operations.
- **4.6.5** Members shall be trained for site-specific tasks they are expected to perform.
- **4.6.6** The skills and knowledge of members shall be verified prior to their participation in emergency response operations.
- **4.6.7** Facility fire brigade members shall perform only those response duties that they have been trained and educated to perform.
- 4.6.8* Training and education shall be conducted periodically.
- **4.6.9*** Facility fire brigade members designated as leaders shall receive training and education commensurate with their response duties.
- **4.6.10** Facility fire brigade leader training and education shall be more comprehensive than training provided to facility fire brigade members.
- 4.7 Drills.
- **4.7.1*** A performance standard for drills shall be established.
- **4.7.1.1*** Drill scenarios shall be representative of conditions encountered during an actual fire.
- 4.7.1.2* Drills shall be conducted periodically.
- **4.7.1.3*** A fire brigade leader or a deputy fire brigade leader shall oversee the conduct of fire drills.

- **4.7.2*** Fire brigade members shall perform or simulate actions necessary to fight simulated fires consistent with the fire drill scenario and the type of facility fire brigade.
- **4.7.3** Drills shall be evaluated for all of the following:
- (1) Training and education program
- (2) Fire brigade member performance
- **4.7.3.1** A corrective action plan shall be created to improve efficiency in the training and education program.
- **4.7.3.2*** Fire brigade member performance shall be assessed to the standards established in 4.7.1.
- **4.7.3.3** Drill evaluations shall be documented.
- **4.7.3.4*** The competence of facility fire brigade members shall be evaluated by the facility fire brigade leader or a deputy facility fire brigade leader.
- **4.7.3.4.1** Only facility fire brigade members meeting the performance standard established in 4.7.1 shall be permitted to perform response duties.
- **4.7.3.4.2** Additional training shall be provided as necessary to improve performance that is below established standards.
- **4.7.3.4.3*** After completion of additional training, the facility fire brigade member's performance shall be re-evaluated.
- 4.8 Training and Drill Records.
- **4.8.1** Training and drill records shall be maintained for each member of the facility fire brigade.
- **4.8.2** Training records shall include, but not be limited to, the following:
- (1) Courses completed
- (2) Subjects studied
- (3) Refresher courses completed
- (4) Evaluations of skills and knowledge
- (5) Drill attendance records
- (6) Leadership or other special accomplishments
- **4.8.3** Training and drill records shall be available for inspection by the authority having jurisdiction.
- **4.8.4** Training and drill records shall be reviewed at least annually by facility fire brigade management and the facility fire brigade training coordinator to evaluate the following:
- (1) Training needs
- (2) Equipment needs
- (3) Fire-fighting operations effectiveness
- 4.9 Responsibilities in the Facility Fire Brigade Organization.
- **4.9.1 Facility Fire Brigade Management.** Facility fire brigade management shall be responsible for the following:
- (1) Establishing programs to accomplish the items identified in the facility fire brigade organizational statement
- (2) Coordinating and scheduling necessary meetings
- (3) Establishing and maintaining fire protection equipment inspection programs for facility fire brigade equipment
- (4) Coordinating the maintenance and review of necessary reports and records
- (5)* Maintaining liaison with local fire authorities
- (6)* Select facility fire brigade members

- △ 4.9.2 Facility Fire Brigade Leader. The facility fire brigade leader shall be responsible for the following:
 - (1) Establishing a chain of command within the brigade to act in the absence of the brigade leader
 - (2)* Evaluating brigade members' qualifications
 - (3) Establishing and maintaining a brigade roster
 - (4) Selecting deputy facility fire brigade leaders as appropriate to the size of the brigade and keeping them informed of all operations of the brigade
 - (5)* Developing pre-incident plans for and informing facility fire brigade members of site-specific hazards, hazardous materials, and processes to which the facility fire brigade member can be exposed
 - (6) Providing training for assigned response duties of fire brigade members and support members
 - (7) Selecting and maintaining equipment used by the brigade
 - (8) Issuing written reports on the status of the facility fire brigade to management, at least annually
 - (9) Assisting in fire investigations
 - **4.9.3 Deputy Facility Fire Brigade Leaders.** The deputy facility fire brigade leader shall do all of the following:
 - (1) Complete tasks assigned by the facility fire brigade leader
 - (2) Substitute in the leader's absence
- △ 4.9.4 Facility Fire Brigade Members. Each facility fire brigade member shall cooperate, participate, and comply with the provisions of the facility fire brigade organizational statement, SOP, and training and education program.

4.9.5 Support Members.

- **4.9.5.1** Prior to an incident, support members shall demonstrate all of the following:
- (1) Awareness of the pre-incident plan
- (2) Ability to perform assigned response duties consistent with the training provided
- **4.9.5.2** Support members shall not enter the warm zone or the hot zone.
- 4.10 Medical and Job-Related Physical Requirements.

4.10.1 General Fitness.

- **4.10.1.1*** Prior to acceptance for facility fire brigade membership, workers who are expected to perform advanced exterior or interior structural fire fighting shall be examined and certified as medically and physically fit by a qualified health care professional.
- **4.10.1.2** The medical and physical fitness requirements shall be based on the risks and tasks associated with the assigned facility fire brigade response duties.
- **4.10.1.3** Facility fire brigade members who are under the influence of alcohol or drugs shall not participate in facility fire brigade operations.
- **4.10.2 Medical Requirements.** Facility fire brigade members who perform advanced exterior fire fighting or interior structural fire fighting shall be medically evaluated annually and after each medical leave of absence by a qualified health care professional.

4.10.3* Job-Related Physical Performance Requirements.

- **4.10.3.1*** Facility fire brigade members shall meet the job-related physical performance requirements of 4.2.1(4) prior to assignment to the facility fire brigade.
- **4.10.3.2** Facility fire brigade members who are expected to perform advanced exterior or interior structural fire fighting shall be evaluated annually to ensure that they continue to meet the job-related physical performance requirements of 4.2.1(4).
- **4.10.3.3** When the evaluation required in 4.10.3.2 concludes that a facility fire brigade member does not meet the jobrelated physical performance requirements of 4.2.1(4), the member shall not continue to perform those task-specific activities.
- **4.10.4* Physical Fitness.** Facility fire brigade members shall report to management any changes in their physical condition that could impact their performance as a facility fire brigade member.

4.11 Facility Fire Brigade Equipment.

- **4.11.1** The facility fire brigade shall be provided with the appropriate equipment to enable performance of the response duties assigned in the organizational statement.
- **4.11.2*** The equipment shall be selected based on the needs presented by the type of facility and the site-specific hazards.
- **4.11.3** Storage space shall be provided for the facility fire brigade equipment.
- **4.11.3.1** The storage space shall be accessible when the fire-fighting equipment is needed.
- **4.11.3.2** Storage space shall meet the environmental recommendations of the fire-fighting equipment manufacturers.
- Δ 4.11.4 There shall be an inventory of facility fire brigade equipment, including the detailed location of the equipment, available onsite.
- **N 4.11.5** The inventory shall be reviewed annually and updated as needed for accuracy and new acquisitions.
 - **4.11.6** Methods for requisitioning the equipment as needed shall be part of the SOP.
 - **4.11.7** Facility fire brigade equipment shall be inspected and maintained in accordance with manufacturers' recommendations and applicable standards and at least annually.
 - **4.11.8** Operation and maintenance manuals for facility fire brigade equipment shall be available to the facility fire brigade.
 - **4.11.9** Maintenance reports of facility fire brigade equipment shall be available to the facility fire brigade.

4.12 Facility Fire Brigade Apparatus.

- **4.12.1** Facility fire brigade management shall include facility fire brigade health and safety as primary concerns in the specification, design, construction, acquisition, operation, maintenance, inspection, and repair of all apparatus.
- **4.12.2*** Only qualified facility fire brigade members shall operate facility fire brigade apparatus.

- **4.12.2.1** Qualified apparatus operators shall have completed formal training using performance-based standards.
- **4.12.2.2** Facility fire brigade apparatus operators shall have valid driver's licenses for the type of vehicle as required by state law or corporate policy.
- **4.12.2.3** Apparatus shall be operated in compliance with applicable traffic laws.
- **4.12.2.4** Facility fire brigade apparatus drivers shall be directly responsible for safe and prudent operation under all conditions.
- **4.12.3*** All persons riding on facility fire brigade apparatus shall be seated and secured with seat belts.
- **4.12.4** Facility fire brigade apparatus shall be maintained in accordance with the manufacturer's recommendations.
- **4.12.4.1*** Facility fire brigade apparatus shall be inspected at least weekly and prior to returning to service after any use or repair.
- **4.12.4.2** Facility fire brigade apparatus found unsafe shall be placed out of service until repaired.
- **4.12.5** Fire pumps on apparatus shall be service tested in accordance with the frequency and procedures specified in NFPA 1911.
- **4.12.6** Aerial devices shall be inspected and service tested in accordance with the frequency and procedures specified in NFPA 1911.

Chapter 5 Facility Fire Brigades That Perform Incipient Stage Fire Fighting

- **5.1 General.** Facility fire brigades organized to perform incipient stage fire fighting shall meet the requirements of Sections 5.3 through 5.5 in addition to all applicable requirements of Chapters 1 and 4 of this standard.
- **5.2** Limits for Facility Fire Brigades Assigned Incipient Fire-Fighting Response Duties. Interior and exterior fires shall be considered incipient stage when facility fire brigade members function as follows:
- They are able to safely fight the fire in normal work clothing.
- (2) They are not required to crawl or take other evasive action to avoid smoke and heat.
- (3) They are not required to wear thermal protective clothing or self-contained breathing apparatus (SCBA).
- (4) They are able to fight the fire effectively with portable extinguishers or handlines flowing up to 473 L/min (125 gpm).
- 5.3 Education, Training, and Drills.
- **5.3.1*** All facility fire brigade members shall receive training and education at least annually.
- **5.3.2** All facility fire brigade members shall participate in a drill at least annually.
- **5.3.3*** Training and drills involving live fire evolutions shall be performed in accordance with recognized safety precautions.

- **5.4 Protective Clothing and Protective Equipment.** Thermal protective clothing and SCBA shall not be required.
- **5.5 Medical.** Each facility fire brigade member shall meet the medical and job-related physical performance requirements as specified in Section 4.10.

Chapter 6 Facility Fire Brigades That Perform Advanced Exterior or Interior Structural Fire Fighting

- **6.1 General.** Facility fire brigades organized to perform advanced exterior or interior structural fire fighting shall meet the requirements of Sections 6.2 through 6.6 in addition to all applicable requirements of Chapters 1 and 4 of this standard.
- **6.1.1** Facility fire brigades organized to perform advanced exterior fire fighting shall perform only advanced exterior fire-fighting duties.
- **6.1.2** Facility fire brigades organized to perform interior structural fire fighting shall perform only interior structural firefighting duties.
- **6.1.3** Facility fire brigades organized to perform advanced exterior and interior structural fire fighting shall perform advanced exterior fire-fighting duties and interior structural fire-fighting duties.
- 6.2 Limits of Facility Fire Brigades Assigned Both Advanced Exterior and Interior Structural Fire-Fighting Response Duties.
- △ 6.2.1 Both exterior fires and interior structural fires shall be considered appropriate for offensive action within the hot zone for facility fire brigade members who have been assigned both advanced exterior and interior fire-fighting response duties when the following occur:
 - (1) The organizational statement lists it as a response duty of the facility fire brigade, and it is covered by the SOP.
 - (2) The facility fire brigade has received training for that activity.
 - (3) SCBA and thermal protective clothing are provided.
 - (4) The facility fire brigade is able to perform offensive action effectively using handlines flowing up to 1140 L/min (300 gpm), master streams, or similar devices for the manual application of specialized agents.
 - **6.2.2** Exterior fires shall be considered appropriate for defensive action outside of the hot and warm zones by facility fire brigade members who have been assigned fire-fighting response duties when the following occur:
 - (1) The organizational statement lists it as a response duty of the facility fire brigade, and it is covered by the SOP.
 - (2) The facility fire brigade has received training for that activity.
 - (3) SCBA and thermal protective clothing are not required.
 - (4) Personal evasive action is not required.
 - (5) The facility fire brigade is able to perform defensive action effectively using handlines flowing up to 1140 L/min (300 gpm), master streams, or similar devices for the manual application of specialized agents.
 - **6.2.3** Protective clothing for proximity fire fighting shall not be worn for interior structural fire fighting.

- Δ 6.3 Operational Requirements. As part of the site's pre-plans, the facility management shall develop standard operating guidelines to be used to instruct the facility fire brigade members on the proper way to deal with site and generic emergencies including, but not limited to, the following:
 - (1) Personnel accountability procedures
 - (a) Experienced facility fire brigade members shall oversee activities of less experienced brigade members during fire-fighting operations.
 - (b) Facility fire brigade members shall operate in teams of two or more in response to fires that have advanced beyond the incipient stage.
 - (2) Facility fire brigade escape and rescue
 - (a) Personnel and facility fire brigade members positioned in any fire zone shall have the opportunity to relocate to an alternate position should fire conditions change.
 - (3) Operating in cold, warm, and hot zone hazard conditions
 - (a) Personnel who are not trained in accordance with this standard shall not be permitted to enter the warm or hot zones established for a fire emergency.
 - (b) Facility fire brigade members operating in the hot and warm zones shall have an established communications system.
 - (4) Warm zone operational procedures
 - (a) Facility fire brigade members positioned in the warm zone shall be visible to command positions at all times.
 - (b) Thermal protective clothing shall be worn by facility fire brigade members entering the warm zone.
 - (5) Hot zone operational procedures
 - (a)* SCBA and thermal protective clothing shall be worn by facility fire brigade members entering the hot zone.
 - (b) When facility fire brigade members are operating in the hot zone, at least one facility fire brigade member with the capability to call for assistance shall remain outside the hot zone and shall maintain an awareness of the safety of facility fire brigade members located inside the hot zone.
 - (c) When facility fire brigade members are operating in the hot zone, additional brigade members shall be standing by in the warm zone with approved equipment to provide assistance or rescue.

6.4 Education, Training, and Drills.

- **6.4.1** All facility fire brigade members shall receive training and education at least quarterly to meet the requirements of Section 4.6.
- **6.4.2** All facility fire brigade members shall participate in a drill at least semiannually to meet the requirements of Section 4.6.
- **6.4.3** Live fire training shall be conducted at least annually. Training and drills involving a live fire evolution shall be performed in accordance with NFPA 1403.
- **6.4.4** Live fire training shall include props that are representative of and that simulate as closely as possible the hazards and conditions that could be encountered by the facility fire brigade member.

6.5 Protective Clothing and Protective Equipment.

- **6.5.1** Thermal protective clothing and protective equipment for structural fire fighting shall be available in sufficient quantities and sizes to fit each facility fire brigade member expected to enter the hot and warm zones.
- **6.5.2*** Thermal protective clothing and protective equipment meeting the requirements of 6.5.2.1 through 6.5.2.4 shall be required to be worn by all facility fire brigade members entering the hot and warm zones.
- **6.5.2.1** Protective clothing, helmets, gloves, and footwear shall be in accordance with NFPA 1971 and the manufacturers' instructions.
- **6.5.2.2** PASS devices shall be in accordance with NFPA 1982.
- **6.5.2.3** Open-circuit-type self-contained breathing devices shall be in accordance with NFPA 1981.
- **6.5.2.4** Closed-circuit-type self-contained breathing devices shall be approved by the National Institute for Occupational Health and Safety (NIOSH) and the Mine Safety and Health Administration (MSHA) with a minimum service duration of 30 minutes.
- **6.5.2.5** Closed-circuit-type self-contained breathing devices shall operate in the positive pressure mode only.
- **6.5.3** All facility fire brigade members entering the hot zone shall be provided with approved hoods that provide protection for the ears and neck and interface with the SCBA facepiece, a protective coat for structural fire fighting, and a helmet.
- **6.5.4** Thermal protective clothing and protective equipment shall be used and maintained in accordance with NFPA 1851 and the manufacturers' instructions.
- **6.5.4.1** A maintenance and inspection program shall be established for thermal protective clothing and protective equipment.
- **6.5.4.2** Specific responsibilities shall be assigned for inspection and maintenance.
- **6.5.5*** Facility fire brigade members using SCBA shall operate in teams of two or more members who are in communication with each other through visual, audible, or physical means or safety guide rope, in order to provide assistance in case of an emergency.
- **6.5.5.1** Where facility fire brigade members are involved in operations that require the use of SCBA, at least two members shall be assigned to remain outside the area where respiratory protection is required.
- **6.5.5.2** One member shall be responsible for maintaining a constant awareness of the number and identities of personnel using SCBA, their location(s), their function(s), and time(s) of entry.
- Δ 6.5.5.3 The members assigned in 6.5.5.1 shall be trained, equipped with SCBA, and available for rescue.
 - **6.6 Medical.** Each facility fire brigade member shall meet the medical and job-related physical performance requirements specified in Section 4.10.

Annex A Explanatory Material

Annex A is not a part of the requirements of this NFPA document but is included for informational purposes only. This annex contains explanatory material, numbered to correspond with the applicable text paragraphs.

Δ A.1.1 A major concern of facility fire protection professionals is the protection of employees and property from the threat of fire in the workplace. In 1980, the Occupational Safety and Health Administration (OSHA) defined its requirements for facility fire brigades. These requirements apply once corporate or local management, in the role as an authority having jurisdiction, has determined that they want a facility fire brigade at their facility.

In 29 CFR 1910.156, "Fire Brigades," two types of facility fire brigades are defined in an attempt to establish levels of function and to identify the training and safety requirements for each of those levels. Fire protection professionals have wrestled with categorizing every existing facility fire brigade into either the incipient stage category or the interior structural category.

In an attempt to develop a state-of-the-art facility fire brigade standard, the Technical Committee on Loss Prevention Procedures and Practices has followed OSHA's lead in setting requirements based on the incipient and interior structural facility fire brigade definitions.

The 1987 adoption of NFPA 1500 brought about an entirely new perspective — inclusion of the facility fire brigades in the same category as municipal fire departments. Although the work done by NFPA 1500's technical committee (Technical Committee on Fire Department Occupational Safety and Health) is admirable and is intended to safeguard all fire fighters, the Technical Committee on Loss Prevention Procedures and Practices believes that a separate standard on facility fire brigades is needed.

Although all facility fire brigades are unique, as are all municipal fire departments, they have far different needs in many respects from those of municipal fire departments — even those that can be referred to as facility fire departments.

The primary difference between facility fire brigades and municipal fire departments is that facility fire brigades must deal with limited conditions and hazards that exist within a given facility generally privately owned and operated. Although these site-specific hazards can and do represent the same degree of hazard to both facility fire brigade members and municipal fire fighters, facility fire brigade members are usually not concerned nor expected to deal with hazards and emergencies beyond the boundaries of the facility that the brigade serves.

Additionally, it must be remembered that a program of occupational safety and health has already been established for all personnel at the facility, including members of the facility fire brigade. Further, facility fire brigades constituted in accordance with this standard will, of necessity, have a more thorough knowledge of the buildings and facilities to which they respond than municipal fire fighters who must respond to a significantly greater variety of buildings and facilities with unidentified and undisclosed hazards.

A municipal fire department, as a local government function, must provide a service to a broadly based municipality with a multitude of unknown factors at every given response.

Variables such as property size and accessibility; building size, construction, and contents; manufacturing process hazards; fixed fire-extinguishing systems and special agent availability; and storage and use of solvents, oils, chemicals, or other hazardous materials are all potential unknown factors that can hinder the effectiveness of any municipal fire department and place a greater safety risk on the fire fighters.

This distinct advantage of familiarity achieves a higher level of facility fire brigade safety and allows for the fundamental difference between a municipal fire department and a facility fire brigade.

- **A.1.2** To meet the intent of this standard, all the requirements of the standard should be followed.
- Δ A.1.3.1 This standard is intended to meet or exceed the facility fire brigade–related requirements of 29 CFR 1910, Subpart L, "Fire Protection." Further, this standard is intended to assure facility fire brigade members with an appropriate degree of occupational safety and health while performing their duties, just as NFPA 1500 assures an appropriate degree of occupational safety and health for municipal fire department members.

For additional information on facility fire brigade organization, see Chapter 4 of NFPA's *Industrial Fire Hazards Handbook*.

Δ A.1.3.2 This standard contains minimum requirements for facility fire brigades when responding to fires in industrial, commercial, institutional, and similar properties. Facility fire brigades might provide mutual aid to other facility fire brigades or specialized assistance to fire departments subject to the requirements of NFPA 1500. When the facility fire brigade's mission is expanded to perform those roles, additional risk assessments must be made, organizational statements must be updated, and additional training, competencies, equipment, and procedures must be introduced.

A facility fire brigade complying with the requirements of this standard should be permitted to respond to fires outside the boundaries of the facility only when it is trained and familiar with the hazards associated with the fire.

The following are examples of a few ways this could be done:

- (1) A facility fire brigade's role at a refinery is expanded to include response to the community to assist the local volunteer fire department in dealing with structure fires during the daytime due to limited staffing at that time. A select group of facility fire brigade members are trained to the professional qualifications of NFPA 1001 to operate with the local volunteer fire department, the necessary equipment is obtained, and procedures consistent with NFPA 1500 are developed. The two organizations train together and develop a common incident management system (IMS). The remainder of the facility fire brigade remain at the facility to deal with potential incidents there.
- (2) A fire brigade's role at a chemical plant is expanded to include mutual aid response to other chemical plants in the mutual aid system and to the local fire department to provide them with specialized equipment (e.g., foam) and knowledge for chemical fire emergencies. The facility fire brigade participates with the mutual aid organization in regular training, exercises, and preplanning for such events. The facility fire brigade continues to use the same organizational structure with minor updates.

- **N A.1.3.3** When the facility fire brigade's mission is expanded to perform those roles, additional NFPA standards and regulations might apply (e.g., NFPA 1006, NFPA 472, applicable medical standards). Those standards and regulations should be used to provide additional risk assessments, update organizational statements, and introduce additional training, competencies, equipment, and procedures.
 - A.1.4 The application of the performance objectives of this standard can vary for many facility fire brigade operations.
 - **A.3.2.1 Approved.** The National Fire Protection Association does not approve, inspect, or certify any installations, procedures, equipment, or materials; nor does it approve or evaluate testing laboratories. In determining the acceptability of installations, procedures, equipment, or materials, the authority having jurisdiction may base acceptance on compliance with NFPA or other appropriate standards. In the absence of such standards, said authority may require evidence of proper installation, procedure, or use. The authority having jurisdiction may also refer to the listings or labeling practices of an organization that is concerned with product evaluations and is thus in a position to determine compliance with appropriate standards for the current production of listed items.
 - A.3.2.2 Authority Having Jurisdiction (AHJ). The phrase "authority having jurisdiction," or its acronym AHJ, is used in NFPA documents in a broad manner, since jurisdictions and approval agencies vary, as do their responsibilities. Where public safety is primary, the authority having jurisdiction may be a federal, state, local, or other regional department or individual such as a fire chief; fire marshal; chief of a fire prevention bureau, labor department, or health department; building official; electrical inspector; or others having statutory authority. For insurance purposes, an insurance inspection department, rating bureau, or other insurance company representative may be the authority having jurisdiction. In many circumstances, the property owner or his or her designated agent assumes the role of the authority having jurisdiction; at government installations, the commanding officer or departmental official may be the authority having jurisdiction.
 - **A.3.3.1 Combustible Liquid.** Combustible liquids are defined in NFPA 30. Combustible liquids are classified in accordance with the following:
 - Class II Liquid Any liquid that has a flash point at or above 37.8°C (100°F) and below 60°C (140°F)
 - Class III Liquid Any liquid that has a flash point at or above 60°C (140°F)
 - Class IIIA Liquid Any liquid that has a flash point at or above 60°C (140°F), but below 93°C (200°F)
 - Class IIIB Liquid Any liquid that has a flash point at or above 93°C (200°F)
 - A.3.3.2 Control Zones. The definitions from NFPA 1500 were extracted to provide conformity at fireground operations between the documents. It is foreseeable that a fire department operating in accordance with NFPA 1500 would work alongside a facility fire brigade at a fire incident. For the safety of both groups, they should operate under the same assumptions in fireground definitions.

Decontamination as used in the definitions of cold, hot, or warm zones should not contradict the nonapplicability of this standard to hazardous material response activities. Decontamination as related to the requirements of this standard should apply to products of combustion.

- **A.3.3.6 Education.** Formal classroom instruction is not necessarily required.
- **N A.3.3.8 Enclosed Structure.** Examples of fire hazards that can occur in enclosed structures include, but are not limited to, accumulations of smoke, toxic gases, or heat - similar to those found in buildings.
 - **A.3.3.9 Facility.** The extent or limits for the location or facility at which a fire brigade operates might not coincide with property boundaries. The boundaries could be set by the authority having jurisdiction or in the organizational statement. The fire brigade can respond to fire incidents at locations that are familiar workplaces or have been prefire planned. At a facility or complex, there might be many different hazards or occupancy uses of structures. A fire brigade can respond at part of a site or at multiple structures at one location. The following are some examples:
 - (1) Nuclear power plant. The fire brigade at a nuclear power plant responds inside the protected area. Beyond these limits, to the site property lines, is a security area that might contain structures. Typically these structures in the security area would be protected by a fire department complying with NFPA 1500.
 - College or university campus. A science laboratory might need a fire brigade dedicated to the special hazards of the laboratory. Other occupancy uses on campus, including large assembly spaces and dormitories, might have fire brigades separate from the one at the science laboratory.
 - Recreational areas. A recreational area such as a state or national park might have several lodge areas within the limits of the park. Due to distance, each lodging facility could have its own fire brigade.
 - Industrial park. There might be several structures at an industrial park that could be protected by a fire brigade.
 - A.3.3.15.1 Advanced Exterior Fire Fighting. Advanced exterior fire fighting often requires facility fire brigade members to contain, control, and extinguish exterior fires involving sitespecific hazards, such as flammable and combustible liquid spills or leaks, liquefied petroleum gas releases, and electrical substations. Advanced exterior fire fighting is usually performed using handlines flowing up to 1140 L/min (300 gpm), master streams, or similar devices for the manual application of specialized agents. Thermal protective clothing is required and the use of SCBA could be required.
- △ A.3.3.17 Flammable Liquid. Flammable liquids are defined in NFPA 30. Flammable liquids (Class I) are classified as Class I liquids and are further subclassified in accordance with the following:
 - Class IA Liquid Any liquid that has a flash point below 22.8°C (73°F) and a boiling point below 37.8°C (100°F)
 - Class IB Liquid Any liquid that has a flash point below 22.8°C (73°F) and a boiling point at or above 37.8°C
 - Class IC Liquid Any liquid that has a flash point at or above 22.8°C (73°F) but below 37.8°C (100°F)
 - A.3.3.19 Incident Management System (IMS). The system is also referred to as an incident command system (ICS). [1561, 2020]

The implementation of [Homeland Security Presidential Directive 5] HSPD-5 led to the development of the National Incident Management System (NIMS). The NIMS is a system mandated by HSPD-5 that provides a consistent nationwide approach for federal, state, local, and tribal governments; the private sector; and nongovernmental organizations to work effectively and efficiently together to prepare for, respond to, and recover from domestic incidents, regardless of cause, size, or complexity. To provide for interoperability and compatibility among federal, state, local, and tribal capabilities, the NIMS includes a core set of concepts, principles, and terminology. HSPD-5 identifies these as the ICS; multi-agency coordination systems; training; identification and management of resources (including systems for classifying types of resources); qualification and certification; and the collection, tracking, and reporting of incident information and incident resources. [1561, 2020]

In addition to the NIMS, the process also incorporates the National Response Plan. The National Response Plan is defined as a plan mandated by HSPD-5 that integrates federal domestic prevention, preparedness, response, and recovery plans into one all-discipline, all-hazards plan. [1561, 2020]

- **A.3.3.20 Incipient Stage Fire.** A fire is considered to be beyond the incipient stage when the use of thermal protective clothing or self-contained breathing apparatus (SCBA) is required or a facility fire brigade member is required to crawl on the ground or floor to stay below smoke and heat.
- **A.3.3.23 Qualified Healthcare Professional.** Individuals who meet the definition of physician or other licensed health careprofessional (PLHCP) as defined by OSHA standards and who have professional expertise in the areas of occupational safety and health as they relate to emergency response activities would meet this requirement.
- **A.3.3.28 Support Members.** When organizing the facility fire brigade, management should take into consideration the need for specialized response duties required in the event of a fire or related emergency and should assign personnel to the brigade to ensure that these response duties are accomplished.

In most cases, personnel are not expected to perform manual fire suppression activities in the event of an emergency but are expected to perform only those specialized tasks for which they have been chosen. Some of these specialized assignments include the following:

- (1) Building evacuation. Personnel are expected to perform specialized response duties to ensure that personnel are safely evacuated from an enclosed structure or the facility in the event of fire. They can be known as facility fire brigade wardens or by a variety of other titles.
- (2) Sprinkler system control. Personnel are assigned to perform specialized response duties to ensure that control of the automatic sprinkler protection system within the fire area or the facility is maintained by facility personnel in the event of fire. These personnel can be known as facility fire brigade sprinkler valve operators or a variety of other titles.
- (3) Electrical power control. Personnel are expected to perform specialized response duties to ensure that control of electrical power within the fire area or the facility is maintained by facility personnel in the event of fire. These personnel can be known as facility fire brigade electricians or by a variety of other titles.

- (4) Utility control. Personnel are expected to perform specialized response duties to ensure that control of plant utilities within the fire area or the facility for example, steam, water, natural gas, and other liquid or vapor piping systems is maintained by facility personnel in the event of fire. These personnel can be known as facility fire brigade utility control technicians or by a variety of other titles.
- (5) Fire pump operation. Personnel are expected to perform specialized response duties to ensure that stationary fire pumps are placed into operation or are operating properly in the event of fire. They can be known as facility fire brigade fire pump operators or by a variety of other titles.
- (6) Salvage. Personnel are expected to perform specialized response duties to ensure that actions are taken during and after manual fire suppression activities to minimize the resultant damage from the fire. These personnel can be known as facility fire brigade salvage personnel or by a variety of other titles.
- (7) Traffic control. Personnel are expected to perform specialized response duties to ensure that control of foot and vehicular traffic in and around the fire area or the facility is maintained in the event of fire and to ensure that any responding agency is directed to the fire area. These operations can be accomplished by facility security personnel who have been assigned to the facility fire brigade.
- **N A.3.3.29 Thermal Protective Clothing.** Examples of thermal protective clothing include, but are not limited to, helmets, footwear, gloves, hoods, trousers, and coats.
 - **A.4.1.2** Designated workers who are intended to respond to incipient fires in their immediate work area should receive training commensurate with the response duties they are expected to perform. Their responsibilities normally are limited to sounding an alarm, taking immediate action to extinguish the fire, and evacuating the area.
 - **A.4.1.3** A facility fire brigade operating in multiple types (e.g., incipient stage fire fighting, advanced exterior fire fighting only, interior structural fire fighting only, or both advanced exterior and interior structural fire fighting) should clearly identify the type of fire incident activities for which each facility fire brigade member is trained.
 - **A.4.1.4.1** The potential exposure and training separates an organized facility fire brigade from designated workers (as defined by OSHA) who have some fire response duties in the general work area. The scope of facility fire brigade actions and responsibilities should be based on the specific response duties that the facility fire brigade members are expected to perform. If a facility fire brigade member is not expected to perform a particular fire-fighting function, then management should not have an obligation to train or equip the facility fire brigade member to perform that function.
 - **A.4.1.4.3** The minimum number varies depending on the operational limits of the facility fire brigade. As the duties increase, the number of members might need to be increased.

A facility fire brigade doing interior structural fire fighting should logically have at least five members: two for work in the hot zone, two for relief and safety in the warm zone, and one managing the fire-fighting activities.

- **A.4.1.5** Identification serves the following purposes:
- (1) Assistance in reaching the incident in an emergency
- (2) Identification by security personnel
- (3) Establishing authority
- **A.4.2.1(2)** Facility fire brigade duties should be determined based on an analysis of all factors present in the areas where the brigade will operate, including, but not limited to, the following:
- (1) Property size
- (2) Property accessibility
- (3) Building size and construction
- (4) Building contents
- (5) Fire protection equipment
- (6) Fire hazards
- (7) Personnel safety
- (8) Public fire department assistance
- (9) Availability of personnel
- (10) Shift and vacation schedule of the facility
- (11) Other response duties of the brigade, such as fire watch and maintenance of fire-fighting equipment
- △ A.4.2.1(3) The establishment of a written policy for the occupational safety and health of facility fire brigade members is intended to prevent and reduce the severity of accidents, injuries, and exposures that could occur. An existing corporate safety program or policy could satisfy the requirements of this standard.
 - **A.4.2.1(4)** The establishment of a written policy for medical and job-related physical performance requirements is intended to ensure facility fire brigade members are medically and physically capable of performing their required duties and to reduce the risk of injuries and illnesses.
 - **A.4.2.1(8)** Even during times of economic stress, providing adequate funds for proper equipment and training is necessary in order to maintain the safety and operational effectiveness of the facility fire brigade.
- Δ A.4.2.2 The facility fire brigade organizational statement represents the foundation of the facility fire brigade and is similar to the mission statement of the organization. The organizational statement should be revised periodically as the mission, organization, or response duties of the brigade change. The following is a sample facility fire brigade organizational statement.

ABC Facility Fire Brigade Organizational Statement

November 2018

Purpose: The ABC Facility Fire Brigade was organized to safeguard the workers and the property of the ABC Corporation from the threat of fire. The facility fire brigade is intended to function as an incipient stage facility fire brigade as identified by OSHA in 29 CFR 1910.

Membership: Anyone who works at the ABC Corporation is welcome to join the facility fire brigade, although certain specific members are appointed based on their particular job and location within the facility. At the present time, there are a total of 25 members in the brigade.

Members are identified as fire-fighting members and support members. Fire-fighting members are expected to perform fire-fighting response duties, utilizing both handportable fire extinguishers and wheeled fire extinguishers and the 38 mm ($1\frac{1}{2}$ in.) hose lines stationed throughout the facility. Support members are not expected to fight fires but are expected to perform specialized response duties that are intended to support the fire-fighting operations. These support functions ensure the following:

- (1) Building is evacuated.
- (2) Sprinkler valves are open.
- (3) Fire department is directed to the scene of the fire.
- (4) Fire pump is operating properly.
- (5) Other logistical needs of the fire-fighting members are met.

Organization: The brigade is headed by a brigade chief. A shift facility fire brigade leader is also assigned to each shift. In the absence of the chief, the shift chief is in charge of the brigade. During a fire incident, the shift chief or brigade chief is in charge of the incident until the local municipal fire department arrives. At this time, the officer in charge of the fire department forces on scene and the shift chief will establish a joint incident command.

Functions: The primary function of the facility fire brigade is to perform fire-fighting operations prior to the arrival of the fire department or operation of the sprinkler system. The fire-fighting operations cannot exceed the capabilities of the brigade members present to prevent fires from spreading.

Additional functions include the provision of advanced first aid assistance in any salvage operations that are necessary during any type of incident, including a fire, and the checking of fire protection and life safety equipment throughout the facility on a daily basis.

Training: The primary source of training for fire-fighting members is that conducted within the facility by the facility fire brigade training officer. This training is conducted on a monthly basis.

Support members receive training on a bimonthly basis in the operation of the fire protection equipment, building evacuation information, and other related topics. This training is provided by the facility fire brigade training officer and other personnel from the facility, such as the maintenance supervisor, the emergency coordinator, and the safety director.

Safety: While this facility fire brigade exists to help safeguard the people and property of the ABC Corporation, the first and foremost consideration must be for the safety of the facility fire brigade members. The brigade has limited resources and training and thus has limited abilities. These limits must be recognized by all members to ensure that members are not extended beyond their capabilities or the limitations imposed by the equipment with which they must operate.

Sample Organizational Statement — An Alternative Sample

The ABC Corporation, under contract with the XYZ Company for management and operation of the XYZ plant, will use an emergency response team (ERT) for the protection of those facilities.

The ERT is composed of workers whose normal job duties are not that of an ERT. In the event of an incident, ERT members will leave their normal assigned duties and assume the response duties of the ERT. Responding ERT members will be grouped into teams, and designated ERT leaders (ERTLs) using the Incident Management System will direct and supervise emergency response operations. The total number of avail-

able ERT members responding to an incident will vary from 2 to 40 depending on the particular site, the time of day, and response times. As dictated by the size and duration of the incident, this number could increase to more than 100 with response by trained ERT members and leaders from other XYZ plant sites.

For fires involving enclosed structures, the ERT will perform only incipient fire fighting and will not enter into a building or enclosed structure involved with fire beyond the incipient stage. For a building involved with fire beyond the incipient stage, ERT members will notify local municipal fire departments or mutual aid organizations to respond and will assist with evacuation, account for personnel, perform first aid, and protect adjacent exposures.

For emergency fire response to the site-specific hazards associated with the storage and transfer of crude oil, the ERT will perform advanced exterior fire fighting. In performing advanced exterior fire fighting, ERT members will wear protective gear and will have responsibilities for rescue, emergency first aid, isolation of fuel sources, and application of water, foam, and dry chemical from the perimeter of the fire, which does not require entry into the interior of enclosed structures involved with fire beyond the incipient stage. Emergency contractors will be employed as necessary for complex fire emergencies that are beyond the training of the ERT.

For response to site-specific hazardous materials emergencies, the ERT will perform limited functions. In performing the limited hazardous materials functions, ERT members will be provided with appropriate personal protective equipment and will approach the source of a spill or leak and attempt to contain, control, and terminate the emergency conditions for which they have been trained. Emergency contractors will be employed as necessary for complex spills, leaks, and cleanups that are beyond that for which the ERT are trained.

Each ERT member will receive training and education commensurate with the response duties and functions they are expected to perform. Forty hours of fire, safety, and hazardous materials response training will be provided annually at the ERT Training Academy using established performance-based standards. Training at the academy will include, but not be limited to, hose and nozzle handling, fire fighter safety, use of protective gear, strategies and tactics, first aid, cardiopulmonary resuscitation (CPR), hazard identification, spill control, and live fire fighting involving flammable liquids and gases. ERT members must attend and successfully complete one ERT Training Academy program before participating in emergency response organizations.

ERT members will receive additional fire training quarterly. Training will be provided at each of the ABC Corporation facilities by qualified personnel to meet established performance standards. Such training will include classroom instruction and hands-on training that has been selected to keep ERT members familiar with site-specific equipment, systems, and standard operating procedures.

Designated ERTLs will annually receive 8 hours of specialized classroom instruction and will train and function as leaders in all live fire and hazardous materials training exercises at the ERT Training Academy and at the sites. Such training will be over and above that provided to other members and will be provided by qualified personnel. Instruction will include, but not be limited to, such subjects as leadership, methods of

teaching, incident command, communications, tactics and strategies, and standard operating procedures.

A.4.2.2.1 The purpose of the facility fire brigade's organizational statement is to demonstrate management's commitment to the establishment of a facility fire brigade. This statement identifies all of the information pertinent to the facility fire brigade and is intended to provide the facility fire brigade member with a clear picture of the organization of the brigade and the response duties that he or she is expected to perform as they relate to the facility fire brigade.

A.4.2.2.2(1) The organizational structure should include, but not be limited to, all of the following:

- (1) Line of authority of each facility fire brigade member
- (2) Number of deputy facility fire brigade leaders
- (3) Number of facility fire brigade instructors
- (4) List and description of the types of awards or recognition that brigade members are eligible to receive

A.4.2.2.2(4) Everything the brigade does should be in accordance with the information in the organizational statement.

A.4.2.4 The following is an example of a safety policy statement:

It is corporate or local company policy to operate a facility fire brigade and to provide all facility fire brigade members with the highest practicable levels of safety and health while they are performing their assigned facility fire brigade response duties.

A.4.2.4.2 The determination of whether the individual will have a full-time or part-time assignment should be made by management. This determination should depend on the size and structure of the facility fire brigade; the activity level; the level of risk in the facility fire brigade's work environment; and the history of accidents, injuries, occupational illness, deaths, and exposures.

A.4.2.5 Medical records can be stored elsewhere in accordance with company policies.

A.4.3.2 Site-specific special hazards should be identified and itemized for the facility fire brigade, along with a detailed explanation of each hazard. Special hazards can consist of unique operations or hazardous materials. Examples of special operations are emergency response activities for data processing and electronic control equipment. Special hazards can include, but not be limited to the following:

- (1) Discharge of a special extinguishing agent
- (2) Engine test areas
- (3) Paint dip, mix, and storage rooms
- (4) Spray booths
- (5) Flammable liquid tank farms
- (6) Oil quenching and machinery operations
- (7) Energized electrical equipment
- (8) Hazardous materials
- (9) Combustible dusts

A.4.4.1 For information on incident management systems, see NFPA 1561.

A.4.4. Facility fire brigades are often organized in such a manner that they respond to the incident scene and assemble upon arrival. A system should be established to identify each facility fire brigade member arriving at the incident scene and to organize them into groups with appropriate supervision.

- A.4.5.1 Review NFPA 1250 for guidance.
- **A.4.5.2** Incident operations can be exercised using scenarios played out on tabletop as well as drills used for training. The risks identified in such exercises should validate or provide input to changes in the risk management plan.
- **A.4.6.1** The training program should ensure that brigade members are able to perform their assigned response duties in a manner that does not pose a hazard to themselves or other members.
- **A.4.6.1.1(1)** Illness can occur some time after performing the duties rather than during fire brigade activities.
- **A.4.6.1.1(2)** Members of the facility fire brigade should be afforded opportunities to improve their skills and knowledge of fire prevention and fire fighting through attendance at outside meetings and special training classes. Members who belong to volunteer fire departments and who receive certified training from a qualified instructor as a part of their public fire department activities can have this training documented in their individual facility fire brigade training records.
- **A.4.6.1.2(1)** Because members will be required to meet the provisions of this standard that apply to the type of facility fire brigade of which they are members, it is important that the applicable provisions of this standard be reviewed in the training program.
- △ A.4.6.2 The facility fire brigade training coordinator should be a worker who is recognized or certified as a facility fire brigade or fire service instructor by a government authority or national certification organization, or should demonstrate the competency to meet the requirements of management in its role as an authority having jurisdiction.

Where facility fire brigade training is contracted and provided by individuals or agencies outside of the company organization, the designated fire training coordinator should verify and ensure that instructors providing the training are knowledgeable in the subjects being presented. Such training should be accomplished using prepared lesson plans and performance-based standards that have been approved by the facility fire brigade training coordinator.

Workers and members of the facility fire brigade who have been trained in the methods of teaching and are recognized by the fire training coordinator as knowledgeable in the subject being presented can provide instruction to the facility fire brigade with the use of prepared lesson plans and performance-based standards that have been approved by the fire training coordinator.

The facility fire brigade training coordinator should oversee the facility fire brigade training and education program to ensure quality and consistency of the training provided.

For information on performance standards for facility fire brigade instructors, see NFPA 1041 or equivalent performance standards.

A.4.6.4 Job training requirements can vary significantly from one location to another. Those requirements should be documented based on site-specific needs. In order to meet the requirements of 4.6.4, facility fire brigade management should perform an analysis of required facility fire brigade response duties.

Δ A.4.6.8 Management should develop a plan and schedule to provide training, education, and drills to ensure facility fire brigade members are capable of performing their assigned response duties. Members should also be able to perform their duties without presenting a hazard to themselves or others. Specific minimum frequencies might be required by this standard.

Scheduling difficulties in the facility setting can make it difficult to provide training, education, or drills for each individual member on a specific day. For this reason, the following clarifications are intended to provide the necessary flexibility for planning and scheduling these activities:

- (1) Quarterly requirements should be accomplished every 90 days and should not exceed 120 days between sessions.
- (2) Semiannual requirements should be accomplished every 183 days and should not exceed 243 days between sessions.
- (3) Annual requirements should be accomplished every 365 days and should not exceed 455 days between sessions.
- △ A.4.6.9 Facility fire brigade leaders should be provided training on the incident management system (IMS). For information on performance standards for facility fire brigade leaders, see Chapter 4 of NFPA 1021, NFPA 1081, or other relevant performance standards.
 - **A.4.7.1** Drill performance standards should be based on realistic scenarios for credible site-specific incidents (see NFPA 1410 for examples). Drills can be either announced or unannounced as determined by the authority having jurisdiction. Management should consider the use of periodic unannounced drills. Announced drills can vary in types of response, speed of response, and use of equipment. Unannounced drills can be used to evaluate the fire-fighting readiness of the facility fire brigade, facility fire brigade leader, and fire protection systems and equipment.

Where mutual aid or other outside agencies play an important role in the emergency response procedures of the site, drills and pre-incident planning should be conducted in conjunction with these agencies.

Responses to actual incidents can reduce the necessity to conduct drills providing the responses occur with sufficient frequency and the facility fire brigade performance is evaluated in accordance with established performance objectives. The evaluation should be properly documented.

- **A.4.7.1.1** Drill scenarios should be realistic to the maximum extent practicable without undue risk to the fire brigade members or facility operations.
- **A.4.7.1.2** Drills should be conducted as often as necessary to keep facility fire brigade performance at established standards.
- **A.4.7.1.3** The fire brigade leader should ensure that the drill presents no undue risk to the fire brigade members or facility operations.
- **A.4.7.2** Fire brigade members should respond to a drill in the same manner that they would for a real fire. For example, fire brigade members entering a hot zone should be using protective gear and equipment such as protective clothing, SCBAs, and PASS devices. Hose lines should be laid out and pressurized. Doors should be checked for high temperatures prior to opening. However, some fire-fighting activities, such as

discharging a fire hose in certain areas, can pose undue risk to facility operations.

- **A.4.7.3.2** The evaluation should not only be pass/fail, but include a report of the adequacy of the performance. For example, a fire brigade member could have come to the correct result in the scenario, but performed in a manner that might have taken too much time or been dangerous to themselves or others.
- **A.4.7.3.4** The evaluation should be conducted by an individual other than the facility fire brigade members being evaluated. The person conducting the evaluation should be qualified in the subject of the drill.
- **A.4.7.3.4.3** Facility fire brigade members should be given the chance to retrain and requalify for their position. The facility fire brigade leader should evaluate the entire record before reinstating a member.
- △ A.4.9.1(5) Facility fire brigade management should maintain a close working relationship with all emergency response organizations that could reasonably be expected to respond to the facility during an incident. This relationship should include the following:
 - (1) A written mutual aid agreement signed by management and the emergency response organization
 - (2) Establishment of an incident management system (IMS) that identifies the roles and responsibilities of both the facility fire brigade and the emergency response organization
 - (3) An invitation to the emergency response organizations to participate in a pre-fire planning walk-through or tour of the facility
 - (4) An invitation to the emergency response organizations to participate in facility fire brigade drills at least annually
 - (5) A means of communication between the facility fire brigade and the emergency response organizations (e.g., the use of common radio frequencies, the exchange of respective portable radios, or other means)
 - (6) A means to ensure that fire hose threads are compatible or that adequate adapters are provided and available
 - (7) Knowledge by both the facility fire brigade and the emergency response organizations of the other's available equipment (e.g., water supply; pump size; foam capabilities; portable or fixed master stream devices, or both; and other specialized equipment)
 - **A.4.9.1(6)** Facility fire brigade members should represent as many separate areas and departments of the facility as is practical.
 - **A.4.9.2(2)** Fire brigade leader duties might be collateral duty to a worker's normal job. While it would be desirable for the leader to assist in the selection of fire brigade members, it might not be practical within the allowable time commitment. The fire brigade leader should enforce qualifications so that fire brigade members are prepared to respond efficiently and safely to an incident.
- **N A.4.9.2(5)** Developing pre-incident plans, including the necessary operational requirements for the site-specific hazards that the fire brigade could encounter, should include the following:
 - (1) Developing site-specific job performance requirements (JPRs) for the site-specific hazards that the facility brigade could face. The management of the facility fire brigade should determine the site-specific requirements that are

- applicable to advanced exterior and interior fire brigade members, if the facility fire brigade provides that level of response service. The process used should be documented, and these additional JPRs should be added to those identified in Sections 5.1, 5.2, 6.1, and 6.2 of NFPA 1081.
- (2) Providing site-specific training for the necessary preincident plans and procedures to deal with the unique hazards of that facility, such as radiation hazards, biomedical hazards, high-energy hazards, and chemical hazards. This training should be aligned with the JPRs outlined in section (1) above.
- **A.4.10.1.1** For information on medical requirements, see OSHA requirements in 29 CFR 1910.156, 29 CFR 1910.134, or NFPA 1582.
- **A.4.10.3** Minimum physical performance requirements should be established to ensure that facility fire brigade members are able to satisfactorily perform their assigned emergency response activities under adverse conditions.
- **A.4.10.3.1** Many critical emergency response activities can be physically demanding. These tasks require muscular strength, muscular endurance, aerobic capacity, flexibility, equilibrium, and anaerobic power. Facility fire brigade management should include these capabilities for the evaluation of facility fire brigade members.
- **A.4.10.4** Facility fire brigade members should be encouraged to maintain good physical condition.
- **A.4.11.2** In selecting the equipment necessary to allow the facility fire brigade members to perform their response duties as specified in the facility fire brigade organizational statement, management should recognize that such a selection can be drawn from a wide range of equipment. The following is a sample of the equipment more commonly selected:
- (1) Portable fire extinguishers in accordance with NFPA 10
- (2) Hose and hose accessories in accordance with NFPA 1961 and maintained in accordance with NFPA 1962
- (3) Portable lighting equipment, including portable electric generators, extension cords, electrical adapters, handheld lights, and spare batteries
- (4) Forcible entry tools, including axes, saws, power tools, plaster hooks, pike poles, claw tools, door openers, crowbars, sledgehammers, wire and bolt cutters, and battering rams
- (5) Ladders
- (6) Salvage and overhaul equipment
- (7) Rescue and first aid equipment
- (8) Special purpose equipment, such as portable foammaking equipment
- (9) Personnel protective equipment
- △ A.4.12.2 For information on performance standards for facility fire brigade apparatus operators, see Chapters 4 through 8 of NFPA 1002, NFPA 1081, or other performance standards.
 - **A.4.12.3** On existing fire apparatus where there is an insufficient number of seats available for the number of members assigned to or expected to ride on that piece of apparatus, alternate means of transportation that provide seated and belted positions should be used.
 - **A.4.12.4.1** The inspection should identify deficiencies in the operation of the apparatus or unsafe conditions.

- A.5.3.1 Training and education objectives can be accomplished in the same session.
- **A.5.3.3** Live training fire field safety recommendations are as follows:
- Site selection preparation. Select an open area with a safe clearance from important buildings, dry vegetation, and storage containers holding flammable liquids and gases and compressed gases.
- Safety procedures. The following procedures should be followed:
 - (a) Smoking should be permitted only in designated
 - (b) Fuel and ignition sources should be separated by safe distances.
 - If high winds or other adverse weather conditions (c) present a hazard to members or adjacent property, live fire training should not be conducted.
 - Only appropriate ignition sources should be used.
 - When participating in an evolution, each student should utilize a charged extinguisher.
 - Fire attack should be from the upwind side.
 - Care should be taken to ensure that members are not placed at risk of being exposed to the products of combustion.
 - For Class B fires, at least two portable extinguishers of the applicable size and rating should be available for each evolution.
 - (i) Participants should retreat from an extinguished fire in an organized manner, always being alert for possible reflash or rekindle.
- Fire training evolutions. Evolutions should be commensurate with the size of fires that the members are expected to extinguish in their normal response duties.
- Student clothing. Individuals participating in field evolutions should be attired in the type of clothing they would normally wear during the performance of their day-to-day job function.
- *Instructors.* The instructor should perform the following functions:
 - Guide each student while he or she is approaching, extinguishing, and retreating from each live fire training evolution
 - Provide for the proper supervision of members who are not participating in the current evolution
- Fuels. Fuels and handling procedures should meet the following criteria:
 - Flammable liquids should not be used as accelerants to ignite Class A training fires.
 - Only approved safety containers should be used to dispense combustible liquids used as accelerants.
 - The person fueling and lighting the fire should be properly instructed and should wear appropriate protective clothing.
 - A qualified person equipped with a charged handline or appropriate extinguisher should stand by in any case where a combustible liquid is being used to light a training fire.
- NA.6.3(5)(a) Facility fire brigade members using SCBA should be fit-tested to meet the requirements of any applicable NFPA standards and 29 CFR 1910.134, "Respiratory Protection."

- A.6.5.2 Based on site-specific hazards, the authority having jurisdiction can choose either structural or proximity thermal protective clothing for advanced exterior fire fighting. In most situations, structural fire-fighting clothing will provide an appropriate level of protection. However, in special circumstances, proximity clothing can be used to provide an additional level of protection from high levels of radiant heat.
- A.6.5.5 Radios can be used for communication on the fireground; however, they cannot be the sole tool for accounting for one's partner in the interior of a structure fire.

One of the two individuals located outside the hot zone can be assigned to an additional role, such as incident commander in charge of the emergency or safety officer, so long as this individual is able to perform assistance or rescue activities without jeopardizing the safety or health of any fire fighters working at the incident. Nothing in this subsection is meant to preclude fire fighters from performing emergency rescue activities before facility fire brigade team members have assembled.

Separate teams of two or more who remain outside the structure are not required for each team operating in the interior of a structure fire. If a structure is so large that accountability cannot be maintained from a single entry point, or rapid rescue is not possible, additional teams of at least two members should be assigned to appropriate divisions or sectors in accordance with the incident management system (IMS) for the site.

Annex B Informational References

- B.1 Referenced Publications. The documents or portions thereof listed in this annex are referenced within the informational sections of this standard and are not part of the requirements of this document unless also listed in Chapter 2 for other reasons.
- △ B.1.1 NFPA Publications. National Fire Protection Association, 1 Batterymarch Park, Quincy, MA 02169-7471.
 - NFPA 10, Standard for Portable Fire Extinguishers, 2018 edition.
 - NFPA 30, Flammable and Combustible Liquids Code, 2018 edition.
 - NFPA 472, Standard for Competence of Responders to Hazardous Materials/Weapons of Mass Destruction Incidents, 2018 edition.
 - NFPA 1001, Standard for Fire Fighter Professional Qualifications, 2019 edition.
 - NFPA 1002, Standard for Fire Apparatus Driver/Operator Professional Qualifications, 2017 edition.
 - NFPA 1006, Standard for Technical Rescue Personnel Professional Qualifications, 2017 edition.
 - NFPA 1021, Standard for Fire Officer Professional Qualifications, 2020 edition.
 - NFPA 1041, Standard for Fire and Emergency Services Instructor Professional Qualifications, 2019 edition.
 - NFPA 1081, Standard for Facility Fire Brigade Member Professional Qualifications, 2018 edition.
 - NFPA 1250, Recommended Practice in Fire and Emergency Service Organization Risk Management, 2020 edition.

NFPA 1410, Standard on Training for Emergency Scene Operations, 2020 edition.

NFPA 1500^{TM} , Standard on Fire Department Occupational Safety, Health, and Wellness Program, 2020 edition.

NFPA 1561, Standard on Emergency Services Incident Management System and Command Safety, 2020 edition.

NFPA 1582, Standard on Comprehensive Occupational Medical Program for Fire Departments, 2018 edition.

NFPA 1961, Standard on Fire Hose, 2020 edition.

NFPA 1962, Standard for the Care, Use, Inspection, Service Testing, and Replacement of Fire Hose, Couplings, Nozzles, and Fire Hose Appliances, 2018 edition.

Industrial Fire Hazards Handbook, 1990.

B.1.2 Other Publications.

△ B.1.2.1 U.S. Government Publications. U.S. Government Publishing Office, 732 North Capitol Street, NW, Washington, DC 20401-0001.

Homeland Security Presidential Directive 5 (HSPD-5), "Management of Domestic Incidents," February 2003.

Title 29, Code of Federal Regulations, Part 1910, Subpart L, "Fire Protection."

Title 29, Code of Federal Regulations, Part 1910.134, "Respiratory Protection."

Title 29, Code of Federal Regulations, Part 1910.156, "Fire Brigades."

B.2 Informational References. The following documents or portions thereof are listed here as informational resources only. They are not a part of the requirements of this document.

NFPA 1001, Standard for Fire Fighter Professional Qualifications, 2019 edition.

B.3 References for Extracts in Informational Sections.

NFPA 1561, Standard on Emergency Services Incident Management System and Command Safety, 2020 edition.